

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	RAPID RIVER MOBILEHOME PARK
Water System Number:	CA4500203

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Daniel Bennett	
	Signature:		
	Title:	Managing Member/ MHP Properties LLC	
	Phone Number:	(925) 376-8543	Date: 6/28/24

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

Copies posted at the office, mailboxes, laundryroom.

- ☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☒ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2023 Consumer Confidence Report

Water System Name: RAPID RIVER MOBILEHOME PARK

Report Date: June 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: does not have a DWSAPP on file.

Your water comes from 1 source(s): WELL 01 - RAW

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are currently not held.

For more information about this report, or any questions relating to your drinking water, please call (925)376-8543 and ask for Daniel Bennett or email dano5799@yahoo.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3 and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	9.1	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	97	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (mg/L)	(2023)	1.7	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Total Radium 228 (pCi/L)	(2022)	1.5	n/a	none	n/a	Erosion of natural deposits

Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2016)	4	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2016)	224	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2016)	5.9	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes

Total Dissolved Solids (mg/L)	(2016)	149	n/a	1000	n/a	Runoff/leaching from natural deposits
-------------------------------	--------	-----	-----	------	-----	---------------------------------------

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Rapid River Mobile Home Park* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2023 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment (DWSAPP) has not been completed for the WELL 01 - RAW of the RAPID RIVER MOBILEHOME PARK water system.

WELL 01 - RAW - does not have a DWSAPP on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local DDW district office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:

Shasta County Environmental Health
1855 Placer Street, Suite 201
Redding, CA 96001

Rapid River Mobile Home Park

Analytical Results By FGL - 2023

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			9.1	9.1 - 9.1
WELL 01 - RAW	CH 2390975-20	mg/L				2022-08-02	9.1		
Hardness		mg/L		none	none			97	97 - 97
WELL 01 - RAW	CH 2390975-20	mg/L				2022-08-02	97		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate as N		mg/L		10	10			1.7	1.67 - 1.67
WELL 01 - RAW	CH 2390975-7	mg/L				2023-05-02	1.67		
Total Radium 228		pCi/L	0.019	none	n/a			1.5	1.5 - 1.5
WELL 01 - RAW	CH 2390975-21	pCi/L				2022-02-02	1.5		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			4	4 - 4
WELL 01 - RAW	CH 2390975-22	mg/L				2016-06-07	4		
Specific Conductance		umhos/cm		1600	n/a			224	224 - 224
WELL 01 - RAW	CH 2390975-22	umhos/cm				2016-06-07	224		
Sulfate		mg/L		500	n/a			5.9	5.9 - 5.9
WELL 01 - RAW	CH 2390975-22	mg/L				2016-06-07	5.9		
Total Dissolved Solids		mg/L		1000	n/a			149	149 - 149
WELL 01 - RAW	CH 2390975-22	mg/L				2016-06-07	149		

Rapid River Mobile Home Park

CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
OFFICE	CH 2390975-10	2023-07-07		OFFICE	CCR 2023
	CH 2390975-18	2023-09-05		OFFICE	CCR 2023
ROUT4	CH 2390629-1	2023-12-19	Coliform	Office Bib	Bacteriological Monitoring
OFFICE HOSE BIB	CH 2390975-1	2023-01-03	Sub Contracted	OFFICE HOSE BIBB	CCR 2023
	CH 2390975-1	2023-01-03		OFFICE HOSE BIBB	CCR 2023
	CH 2390975-2	2023-02-07		OFFICE HOSE BIBB	CCR 2023
	CH 2390975-4	2023-03-07		OFFICE HOSE BIBB	CCR 2023
	CH 2390975-8	2023-06-06		OFFICE HOSE BIBB	CCR 2023
SPACE 16	CH 2390975-15	2023-07-28		SPACE 16	CCR 2023
SPACE 31	CH 2390975-5	2023-04-04		SPACE 31	CCR 2023
	CH 2390975-19	2023-10-03		SPACE 31	CCR 2023
SPACE 32	CH 2390975-16	2023-08-01		SPACE 32	CCR 2023
SPACE 34	CH 2390975-9	2023-07-06		SPACE 34	CCR 2023
	CH 2390975-11	2023-07-07		SPACE 34	CCR 2023
SPACE 38	CH 2390975-13	2023-07-07		SPACE 38	CCR 2023
SPACE 41	CH 2390975-14	2023-07-07		SPACE 41	CCR 2023
SPACE 8	CH 2390975-6	2023-05-02		SPACE 8	CCR 2023
TWRAW	CH 2390697-1	2023-12-20	Coliform	Tank Well	Bacteriological Monitoring
WELL 01 - RAW	CH 2390975-22	2016-06-07		WELL 01 - RAW	CCR 2023
	CH 2390975-21	2022-02-02		WELL 01 - RAW	CCR 2023
	CH 2390975-20	2022-08-02		WELL 01 - RAW	CCR 2023
	CH 2390975-7	2023-05-02		WELL 01 - RAW	CCR 2023