

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

| | |
|----------------------|----------------------------------|
| Water System Name: | WOODRIDGE MUTUAL WATER CO |
| Water System Number: | CA4500235 |

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

| | | | |
|---------------|---------------|---------|-------|
| Certified By: | Name: | | |
| | Signature: | | |
| | Title: | | |
| | Phone Number: | () | Date: |

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
- _____
- _____
- ☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
- ☐ Posted the CCR on the internet at <http://> _____
 - ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2024 Consumer Confidence Report

Water System Name: WOODRIDGE MUTUAL WATER CO

Report Date: March 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method

Your water comes from 3 source(s): WELL 01 - NOT TREATED, WELL 02 - NOT TREATED and WELL 04 - NOT TREATED

Opportunities for public participation in decisions that affect drinking water quality: The Annual Property Owners Meeting is in May. The date and location of periodic Board meeting will be posted on our website at www.woodridgepoa.org

For more information about this report, or any questions relating to your drinking water, please call (858) 354 8885 and ask for Mark Bantz or email Markb.wpoa@gmail.com or visit our website at www.woodridgepoa.org.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

| Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA | | | | | |
|--|----------------------------------|-----------------------------------|--|-------------|---------------------------------------|
| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Sources of Contaminant |
| Total Coliform Bacteria | 0 (2024) | ND | no more than 1 positive monthly sample | 0 | Naturally present in the environment. |

| Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER | | | | | | | |
|--|--------------------|-----------------------|---------------------------------------|-------------------------------|-----------|------------|---|
| Lead and Copper (complete if lead or copper detected in last sample set) | Sample Date | No. of Samples | 90th percentile level detected | No. Sites Exceeding AL | AL | PHG | Typical Sources of Contaminant |
| Lead (ug/L) | (2024) | 5 | 0 | 0 | 15 | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits |
| Copper (mg/L) | (2024) | 5 | 0.36 | 0 | 1.3 | .3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

| Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | |
|---|--------------------|-------------------------------|----------------------------|------------|-------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
| Sodium (mg/L) | (2021) | 6 | n/a | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (mg/L) | (2021) | 112 | 108 - 117 | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|---|--------------------|-------------------------------|----------------------------|-------------------|---------------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
| Hexavalent Chromium (ug/L) | (2017) | 1.6 | ND - 2.8 | | 0.02 | Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits. |
| Gross Alpha (pCi/L) | (2019 - 2020) | 1.217 | ND - 3.65 | 15 | (0) | Erosion of natural deposits. |
| Total Radium 228 (pCi/L) | (2023 - 2024) | ND | ND - 1.26 | none | n/a | Erosion of natural deposits |

| Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD | | | | | | |
|---|--------------------|-------------------------------|----------------------------|------------|-------------------|---|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
| Chloride (mg/L) | (2021) | 1 | ND - 1 | 500 | n/a | Runoff/leaching from natural deposits; seawater influence |
| Specific Conductance (umhos/cm) | (2021) | 226 | 223 - 230 | 1600 | n/a | Substances that form ions when in water; seawater influence |
| Sulfate (mg/L) | (2021) | 0.7 | 0.6 - 0.7 | 500 | n/a | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (mg/L) | (2021) | 163 | 160 - 170 | 1000 | n/a | Runoff/leaching from natural deposits |
| Turbidity (NTU) | (2021) | 0.5 | 0.1 - 0.9 | 5 | n/a | Soil runoff |
| Zinc (mg/L) | (2021) | 0.04 | ND - 0.07 | 5 | n/a | Runoff/leaching from natural deposits |

| Table 6 - ADDITIONAL DETECTIONS | | | | | |
|---|--------------------|-------------------------------|----------------------------|---------------------------|---------------------------------------|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Typical Sources of Contaminant |
| Calcium (mg/L) | (2021) | 21 | 20 - 22 | n/a | n/a |
| Magnesium (mg/L) | (2021) | 14 | 14 - 15 | n/a | n/a |
| pH (units) | (2021) | 7 | 6.89 - 7.11 | n/a | n/a |
| Alkalinity (mg/L) | (2021) | 113 | 110 - 120 | n/a | n/a |
| Aggressiveness Index | (2021) | 10.8 | 10.6 - 10.9 | n/a | n/a |
| Langelier Index | (2021) | -1 | -1.2 - -0.9 | n/a | n/a |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Woodridge Mutual Water Co.* is responsible for

providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2024 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment was conducted for the WELL 01, WELL 02, WELL 03, WELL 04 of the WOODRIDGE MUTUAL WATER CO water system on April, 2002.

WELL 01 - NOT TREATED - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [$<1/\text{acre}$]

WELL 02 - NOT TREATED - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [$<1/\text{acre}$]

WELL 04 - NOT TREATED - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [$<1/\text{acre}$]

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source. These activities include the use of private septic systems in the area of the wells. The water system conducts monthly laboratory testing of the water to check for bacteriological contaminants associated with septic systems.

Acquiring Information

A copy of the complete assessment may be viewed at:

Shasta County Environmental Health Division

1855 Placer Street, Suite 201

Redding, CA 96001

You may request a summary of the assessment be sent to you by contacting:

Environmental Health

R.E.H.S. - Water Systems Program Manager

(530)225-5787

(530)225-5413 FAX (fax)

scehd@co.shasta.ca.us

Woodridge Mutual Water Co.

Analytical Results By FGL - 2024

| MICROBIOLOGICAL CONTAMINANTS | | | | | | | | | |
|-----------------------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Total Coliform Bacteria | | | 0 | 5% | n/a | | | ND | - |
| 31143 Woodridge Drive | CH 2491569-1 | | | | | 2024-12-23 | Absent | | |
| 31143 Woodridge Drive | CH 2479518-1 | | | | | 2024-10-14 | Absent | | |
| 31143 Woodridge Drive | CH 2475477-1 | | | | | 2024-06-26 | Absent | | |
| 31143 Woodridge Drive | CH 2471497-1 | | | | | 2024-02-28 | Absent | | |
| 31399 Woodridge Drive | CH 2478862-1 | | | | | 2024-09-23 | Absent | | |
| 31399 Woodridge Drive | CH 2473548-1 | | | | | 2024-05-07 | Absent | | |
| 31399 Woodridge Drive | CH 2470679-1 | | | | | 2024-01-25 | Absent | | |
| 6805 Winterwood Drive | CH 2490485-1 | | | | | 2024-11-18 | Absent | | |
| 6805 Winterwood Drive | CH 2475336-1 | | | | | 2024-07-01 | Absent | | |
| 6805 Winterwood Drive | CH 2472083-1 | | | | | 2024-03-20 | Absent | | |
| 6824 Wilson Hill Road | CH 2477474-1 | | | | | 2024-08-19 | Absent | | |
| 6824 Wilson Hill Road | CH 2473077-1 | | | | | 2024-04-23 | Absent | | |
| Fecal coliform and E. coli | | | | 0 | n/a | | | ND | - |
| 31143 Woodridge Drive | CH 2491569-1 | | | | | 2024-12-23 | Absent | | |
| 31143 Woodridge Drive | CH 2479518-1 | | | | | 2024-10-14 | Absent | | |
| 31143 Woodridge Drive | CH 2475477-1 | | | | | 2024-06-26 | Absent | | |
| 31143 Woodridge Drive | CH 2471497-1 | | | | | 2024-02-28 | Absent | | |
| 31399 Woodridge Drive | CH 2478862-1 | | | | | 2024-09-23 | Absent | | |
| 31399 Woodridge Drive | CH 2473548-1 | | | | | 2024-05-07 | Absent | | |
| 31399 Woodridge Drive | CH 2470679-1 | | | | | 2024-01-25 | Absent | | |
| 6805 Winterwood Drive | CH 2490485-1 | | | | | 2024-11-18 | Absent | | |
| 6805 Winterwood Drive | CH 2475336-1 | | | | | 2024-07-01 | Absent | | |
| 6805 Winterwood Drive | CH 2472083-1 | | | | | 2024-03-20 | Absent | | |
| 6824 Wilson Hill Road | CH 2477474-1 | | | | | 2024-08-19 | Absent | | |
| 6824 Wilson Hill Road | CH 2473077-1 | | | | | 2024-04-23 | Absent | | |

| LEAD AND COPPER RULE | | | | | | | | | |
|-----------------------|--------------|-------|------|--------|-----|------------|--------|-----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | 90th Percentile | # Samples |
| Lead | | ug/L | 0 | 15 | 0.2 | | | 0 | 5 |
| CuPb-31091 Woodridge | CH 2478788-3 | ug/L | | | | 2024-09-17 | ND | | |
| CuPb-31143 Woodridge | CH 2478788-4 | ug/L | | | | 2024-09-14 | ND | | |
| CuPb-6822 Winterwood | CH 2478788-5 | ug/L | | | | 2024-09-15 | ND | | |
| CuPb-6824 Wilson Hill | CH 2478788-1 | ug/L | | | | 2024-09-15 | ND | | |
| CuPb-6867 Cedarwood | CH 2478788-2 | ug/L | | | | 2024-09-14 | ND | | |
| Copper | | mg/L | | 1.3 | .3 | | | 0.355 | 5 |
| CuPb-31091 Woodridge | CH 2478788-3 | mg/L | | | | 2024-09-17 | 0.17 | | |
| CuPb-31143 Woodridge | CH 2478788-4 | mg/L | | | | 2024-09-14 | ND | | |
| CuPb-6822 Winterwood | CH 2478788-5 | mg/L | | | | 2024-09-15 | 0.37 | | |
| CuPb-6824 Wilson Hill | CH 2478788-1 | mg/L | | | | 2024-09-15 | 0.26 | | |
| CuPb-6867 Cedarwood | CH 2478788-2 | mg/L | | | | 2024-09-14 | 0.34 | | |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | | | | |
|--|--------------|-------|------|--------|------|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Sodium | | mg/L | | none | none | | | 6 | 6 - 6 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 6 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 6 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 6 | | |
| Hardness | | mg/L | | none | none | | | 112 | 108 - 117 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 110 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 108 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 117 | | |

| PRIMARY DRINKING WATER STANDARDS (PDWS) | | | | | | | | | |
|---|--------------|-------|-------|--------|------|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Hexavalent Chromium | | ug/L | | | 0.02 | | | 1.6 | ND - 2.8 |
| WELL 01 - NOT TREATED | CH 1771107-1 | ug/L | | | | 2017-05-03 | 1.9 | | |
| WELL 02 - NOT TREATED | CH 1771107-2 | ug/L | | | | 2017-05-03 | ND | | |
| WELL 04 - NOT TREATED | CH 1771107-3 | ug/L | | | | 2017-05-03 | 2.8 | | |
| Gross Alpha | | pCi/L | | 15 | (0) | | | 1.217 | ND - 3.65 |
| WELL 01 - NOT TREATED | CH 1971878-1 | pCi/L | | | | 2019-03-20 | ND | | |
| WELL 02 - NOT TREATED | CH 1971878-2 | pCi/L | | | | 2019-03-20 | ND | | |
| WELL 04 - NOT TREATED | CH 2071594-1 | pCi/L | | | | 2020-03-25 | 3.65 | | |
| Total Radium 228 | | pCi/L | 0.019 | none | n/a | | | ND | ND - 1.26 |
| WELL 01 - NOT TREATED | CH 2472082-1 | pCi/L | | | | 2024-03-20 | ND | | |
| WELL 02 - NOT TREATED | CH 2390800-1 | pCi/L | | | | 2023-12-27 | 1.26 | | |
| WELL 04 - NOT TREATED | CH 2371956-1 | pCi/L | | | | 2023-03-27 | ND | | |

| SECONDARY DRINKING WATER STANDARDS (SDWS) | | | | | | | | | |
|---|--------------|----------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Chloride | | mg/L | | 500 | n/a | | | 1 | ND - 1 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 1 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 1 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | ND | | |
| Specific Conductance | | umhos/cm | | 1600 | n/a | | | 226 | 223 - 230 |
| WELL 01 - NOT TREATED | CH 2174339-1 | umhos/cm | | | | 2021-06-18 | 226 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | umhos/cm | | | | 2021-06-18 | 223 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | umhos/cm | | | | 2021-06-18 | 230 | | |
| Sulfate | | mg/L | | 500 | n/a | | | 0.7 | 0.6 - 0.7 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 0.7 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 0.7 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 0.6 | | |
| Total Dissolved Solids | | mg/L | | 1000 | n/a | | | 163 | 160 - 170 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 160 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 170 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 160 | | |
| Turbidity | | NTU | | 5 | n/a | | | 0.5 | 0.1 - 0.9 |
| WELL 01 - NOT TREATED | CH 2174339-1 | NTU | | | | 2021-06-18 | 0.1 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | NTU | | | | 2021-06-18 | 0.4 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | NTU | | | | 2021-06-18 | 0.9 | | |
| Zinc | | mg/L | | 5 | n/a | | | 0.04 | ND - 0.07 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | ND | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 0.07 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 0.04 | | |

| ADDITIONAL DETECTIONS | | | | | | | | | |
|-----------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-------------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Calcium | | mg/L | | | n/a | | | 21 | 20 - 22 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 21 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 20 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 22 | | |
| Magnesium | | mg/L | | | n/a | | | 14 | 14 - 15 |
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 14 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 14 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 15 | | |
| pH | | units | | | n/a | | | 7.00 | 6.89 - 7.11 |
| WELL 01 - NOT TREATED | CH 2174339-1 | units | | | | 2021-06-18 | 7.11 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | units | | | | 2021-06-18 | 6.89 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | units | | | | 2021-06-18 | 7 | | |
| Alkalinity | | mg/L | | | n/a | | | 113 | 110 - 120 |

| | | | | | | | | | |
|-----------------------------|--------------|------|--|--|-----|------------|------|------|-------------|
| WELL 01 - NOT TREATED | CH 2174339-1 | mg/L | | | | 2021-06-18 | 110 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | mg/L | | | | 2021-06-18 | 110 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | mg/L | | | | 2021-06-18 | 120 | | |
| Aggressiveness Index | | | | | n/a | | | 10.8 | 10.6 - 10.9 |
| WELL 01 - NOT TREATED | CH 2174339-1 | | | | | 2021-06-18 | 10.9 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | | | | | 2021-06-18 | 10.6 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | | | | | 2021-06-18 | 10.8 | | |
| Langelier Index | | | | | n/a | | | -1.0 | -1.2 - -0.9 |
| WELL 01 - NOT TREATED | CH 2174339-1 | | | | | 2021-06-18 | -0.9 | | |
| WELL 02 - NOT TREATED | CH 2174336-1 | | | | | 2021-06-18 | -1.2 | | |
| WELL 04 - NOT TREATED | CH 2174337-1 | | | | | 2021-06-18 | -1.0 | | |

Woodridge Mutual Water Co.

CCR Login Linkage - 2024

| FGL Code | Lab ID | Date_Sampled | Method | Description | Property |
|-----------------|--------------|--------------|-----------------|-----------------------|--------------------------------------|
| Bacti-Rout-ss02 | CH 2471497-1 | 2024-02-28 | Coliform | 31143 Woodridge Drive | Routine Bacteriological Monitoring-2 |
| | CH 2475477-1 | 2024-06-26 | Coliform | 31143 Woodridge Drive | Routine Bacteriological Monitoring-2 |
| | CH 2479518-1 | 2024-10-14 | Coliform | 31143 Woodridge Drive | Routine Bacteriological Monitoring-2 |
| | CH 2491569-1 | 2024-12-23 | Coliform | 31143 Woodridge Drive | Routine Bacteriological Monitoring-4 |
| Bacti-Rout-ss01 | CH 2470679-1 | 2024-01-25 | Coliform | 31399 Woodridge Drive | Routine Bacteriological Monitoring-1 |
| | CH 2473548-1 | 2024-05-07 | Coliform | 31399 Woodridge Drive | Routine Bacteriological Monitoring-1 |
| | CH 2478862-1 | 2024-09-23 | Coliform | 31399 Woodridge Drive | Routine Bacteriological Monitoring-1 |
| Bacti-Rout-ss03 | CH 2472083-1 | 2024-03-20 | Coliform | 6805 Winterwood Drive | Routine Bacteriological Monitoring-3 |
| | CH 2475336-1 | 2024-07-01 | Coliform | 6805 Winterwood Drive | Routine Bacteriological Monitoring-3 |
| | CH 2490485-1 | 2024-11-18 | Coliform | 6805 Winterwood Drive | Routine Bacteriological Monitoring-3 |
| Bacti-Rout-ss04 | CH 2473077-1 | 2024-04-23 | Coliform | 6824 Wilson Hill Road | Routine Bacteriological Monitoring-4 |
| | CH 2477474-1 | 2024-08-19 | Coliform | 6824 Wilson Hill Road | Routine Bacteriological Monitoring-4 |
| DST_LCR | CH 2478788-3 | 2024-09-17 | Metals, Total | CuPb-31091 Woodridge | Copper & Lead Monitoring |
| | CH 2478788-4 | 2024-09-14 | Metals, Total | CuPb-31143 Woodridge | Copper & Lead Monitoring |
| | CH 2478788-5 | 2024-09-15 | Metals, Total | CuPb-6822 Winterwood | Copper & Lead Monitoring |
| | CH 2478788-1 | 2024-09-15 | Metals, Total | CuPb-6824 Wilson Hill | Copper & Lead Monitoring |
| | CH 2478788-2 | 2024-09-14 | Metals, Total | CuPb-6867 Cedarwood | Copper & Lead Monitoring |
| WELL 01 | CH 1771107-1 | 2017-05-03 | Wet Chemistry | WELL 01 - NOT TREATED | CrVI Monitoring |
| | CH 1971878-1 | 2019-03-20 | Radio Chemistry | WELL 01 - NOT TREATED | Radiological - Gross Alpha |
| | CH 2174339-1 | 2021-06-18 | General Mineral | WELL 01 - NOT TREATED | Well 1 - Water Quality |
| | CH 2174339-1 | 2021-06-18 | Wet Chemistry | WELL 01 - NOT TREATED | Well 1 - Water Quality |
| | CH 2472082-1 | 2024-03-20 | Radio Chemistry | WELL 01 - NOT TREATED | Radiological - Radium 228 |
| WELL 02RAW | CH 1771107-2 | 2017-05-03 | Wet Chemistry | WELL 02 - NOT TREATED | CrVI Monitoring |
| | CH 1971878-2 | 2019-03-20 | Radio Chemistry | WELL 02 - NOT TREATED | Radiological - Gross Alpha |
| | CH 2174336-1 | 2021-06-18 | General Mineral | WELL 02 - NOT TREATED | Well 2 - Water Quality |
| | CH 2174336-1 | 2021-06-18 | Wet Chemistry | WELL 02 - NOT TREATED | Well 2 - Water Quality |
| | CH 2390800-1 | 2023-12-27 | Radio Chemistry | WELL 02 - NOT TREATED | Well 2 - Radium 228 |
| WELL 04 | CH 1771107-3 | 2017-05-03 | Wet Chemistry | WELL 04 - NOT TREATED | CrVI Monitoring |
| | CH 2071594-1 | 2020-03-25 | Radio Chemistry | WELL 04 - NOT TREATED | Well 4 - Gross Alpha |
| | CH 2174337-1 | 2021-06-18 | Wet Chemistry | WELL 04 - NOT TREATED | Well 4 - Water Quality |
| | CH 2174337-1 | 2021-06-18 | General Mineral | WELL 04 - NOT TREATED | Well 4 - Water Quality |
| | CH 2371956-1 | 2023-03-27 | Radio Chemistry | WELL 04 - NOT TREATED | Well 4 - Radium 228 |