

Consumer Confidence Report
Certification Form

Submit by July 1, 2022 to:

Shasta County Environmental Health
1855 Placer Street, Suite 201
Redding, CA 96001

DEPT OF RESOURCE MGMT
RECEIVED

JUL 05 2023

Water System Name: Pine Grove Mobile Home Park

ENVIRONMENTAL HEALTH
DIVISION

Water System Number 4500290

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6-26-23 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by: Name: KATHARINE HOWARD
Signature: Katharine Howard
Title: CO-OWNER
Phone Number: (530) 941-0211 Date: 6-29-23

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations) -laundry room
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☒ Other (attach a list of other methods used) posted at each address
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☒ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

To certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml

JUL 05 2023

ENVIRONMENTAL HEALTH
DIVISION

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Pine Grove Mobilehome Park Has Levels of Manganese Above the Secondary Maximum Contaminant Level and the U.S. EPA Lifetime Health Advisory

Our water system recently violated the Secondary Maximum Contaminant Level (MCL). A secondary standard affects the color and taste of the water delivered to customers. As our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. This well has been tested 25 times for manganese since it 2012; results ranged from 350 to 506 ppb. Samples sample collected in December 2016 had manganese measured at 506 ppb and the samples collected November 2021 had manganese measured at 433 ppb. This is above the secondary MCL of 0.05 milligrams per liter (mg/L) and above the U.S. EPA lifetime health advisory (HA) level of 0.3 mg/L.

What should I do?

- Infants younger than 6 months could experience *neurological effects from **continuous** manganese exposures above 0.3 mg/L*. The State Water Board strongly recommends the use of an alternate water source when preparing food, specifically baby formula and juice, for infants.
- **For all other consumers, you do not need to use an alternative water supply (e.g., bottled water).**
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing manganese in excess of the U.S. EPA lifetime HA level (0.3 mg/L) over many years may experience potential neurological effects.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

We are testing the drinking water source quarterly. We will be working with a certified water treatment engineer to come up with a filtration and/or treatment system, which can be approved by Shasta County Environmental Health, to remove the manganese out of the drinking water. We are also working towards consolidating with the Fall River Valley Community Service District (CSD).

For more information, please contact Kathrine Howard at 530-200-7168 or Shasta County Environmental Health Division at 530-225-5787

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Should the water sample results exceed the U.S. EPA HA of 0.3 mg/L [Health and Safety Code Section 116450(e)].

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Pine Grove Mobilehome Park.

State Water System Number: 4500290.

Date distributed: **June 2, 2023**