



# SID-Quail Canyon Public Water System

## 2020 Annual Water Quality Report

Solano Irrigation District welcomes this yearly opportunity to communicate our commitment to delivering quality water to our SID-Quail Canyon Public Water System customers. Your ground water is supplied from one well in your local area. Public involvement in SID decisions is welcome. SID Board meetings are held regularly the third Tuesday of the month at 7:00 p.m. at 810 Vaca Valley Parkway, Suite 201, Vacaville, CA 95688.

***This report tells you that after testing for over 100 different constituents, your drinking water supply meets all health related standards established by the State Water Resources Control Board, and the U.S. Environmental Protection Agency.***

All source waters used for drinking water are required to be assessed for the vulnerability to possible contaminants. A Source Water Assessment for the well was completed in 2003. The source is considered most vulnerable to the following activities not associated with any detected contaminants: above ground storage tanks, and metal plating/finishing/fabricating. A summary of the assessment can be obtained by contacting SID.

For more information, contact Sue Murphy-Water Quality Specialist, 707-455-4021.

**Este informe contiene información muy importante sobre su agua potable.**

**Tradúzcalo ó hable con alguien que lo entienda bien.**

### **TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**ppm:** parts per million or milligrams per liter (mg/L)

**Primary Drinking Water Standards (PDWS):** MCLs or MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Notification Level (NL):** Health based advisory level set by the Department for constituents with no MCL. This is not an enforceable standard, although requirements and recommendations may apply if detected above this level.

**Variances and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**NA:** not applicable

**ND:** not detectable at testing limit

**µS/cm:** microsiemens per centimeter

**ppb:** parts per billion or micrograms per liter (ug/L)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**The tables below list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows systems to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF BACTERIA**

Microbiological Constituents	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
E. Coli	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects E. coli	0	Human and animal fecal waste

**TABLE 2 – CUSTOMER TAP SAMPLING RESULTS FOR LEAD AND COPPER**

Lead and Copper (reporting units)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. of sites exceeding AL	AL	PHG	Typical Source of Constituent
Lead (ppb) 7/3/2018	5	ND	0	15	0.2	Internal corrosion of household water plumbing systems
Copper (ppm) 7/3/2018	5	0.215	0	1.3	0.30	Internal corrosion of household water plumbing systems

**TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Constituent (reporting units)	Sample Date	Average Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Constituent
Sodium (ppm)	7/6/2020	19	19	none	none	Generally found in ground & surface water
Hardness (ppm)	7/6/2020	270	270	none	none	Generally found in ground & surface water

**TABLE 4 - DETECTION OF CONSTITUENTS WITH A PRIMARY DRINKING WATER STANDARD**

Constituent (reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Constituent
Barium (ppm)	7/6/2020	0.13	0.13	1	2	Discharge of oil drilling wastes, metal refineries; erosion of natural deposits
Copper (ppm)	7/6/2020	0.002	0.002	(AL=1.3)	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits
Fluoride (ppm)	7/6/2020	0.15	0.15	2.0	1	Erosion of natural deposits
<b>Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors in Distribution System</b>						
Total Trihalomethanes (ppb)	7/6/2020	8.7	ND	80 <sup>1</sup>	NA	By-product of drinking water chlorination
Haloacetic Acids (ppb)	7/6/2020	ND	ND	60 <sup>1</sup>	NA	By-product of drinking water chlorination
Chlorine (ppm)	Monthly 2020	0.54	0.21-1.01	[4.0]	[4]	Drinking water disinfectant added for treatment

**TABLE 5 – DETECTION OF CONSTITUENTS WITH A SECONDARY DRINKING WATER STANDARD**

Constituent (reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Constituent
Chloride (ppm)	7/6/2020	8.6	8.6	500	NA	Runoff/leaching from natural deposits; seawater influence
Odor (units)	7/6/2020	2.5	2.5	3	NA	Naturally occurring
Specific Conductance (µS/cm)	7/6/2020	560	560	1600	NA	Substances that form ions when in water; seawater influence
Sulfate (ppm)	7/6/2020	12	12	500	NA	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	7/6/2020	310	310	1000	NA	Runoff/leaching from natural deposits

<sup>1</sup> Compliance is based on a locational RAA (running annual average)

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. More information about contaminants, potential health effects, and reducing risks can be obtained by calling the USEPA's Safe Drinking Water Hotline 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. SID-Quail Canyon is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water is sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing

methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://epa.gov/safewater/lead> .