

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

Water System Name:	Diamond A Mutual Water Co
Water System Number:	4900562

The water system named above hereby certifies that its Consumer Confidence Report was distributed on **July 1, 2026** to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:

Name:	Will Glesnes	Title:	Secretary of the board
Signature:		Date:	July 1, 2026
Phone number:	+1 617 383-9525		

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used). **Members who do not have email or who have articulated a preference to not receive electronic communications receive notices via USPS**
- ☒ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☒ Posting the CCR at the following URL:
<https://www.diamondasonoma.com/water-co/wc-publications>
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☒ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL:
<https://www.diamondasonoma.com/water-co/wc-publications>
- ☒ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

All electronic communications from the Diamond A Mutual Water Company originate from the diamond.a.water@gmail.com email account. We send electronic notices both as a file attachment and as a URL link to where the notice can be viewed on our website.



Diamond A Mutual Water Co <diamond.a.water@gmail.com>

[DAMWCO Notice] 2025 Consumer Confidence Report (CCR)

Diamond A Mutual Water Co <diamond.a.water@gmail.com>
To: damwco-secretary@diamondasonoma.com

Wed, Jul 1, 2026 at 11:00 AM

Diamond "A" Mutual Water Company

A California Nonprofit Public Benefit Corporation



July 1, 2026

Dear Members,

Attached is our 2025 Consumer Confidence Report (CCR). State regulations require water systems to provide water system consumers with an annual CCR. The CCR includes: information about the water system, definitions, water sources, levels of detected contaminants, water quality compliance/violations, and some educational information. This CCR and other DAMWCO publications are also available on our website: <https://www.diamondasonoma.com/water-co/wc-publications>.

In summary, our water meets the applicable standards established under State and Federal regulations.

If you have any questions, please email damwco-president@diamondasonoma.com or send them to:

Diamond A Mutual Water Company
PO Box 150
El Verano, CA 95433

Sincerely,
Will Glesnes
Board Secretary
Diamond A Mutual Water Company

Attachment:
1. 2025 Consumer Confidence Report (CCR).pdf

 **2025 Consumer Confidence Report.pdf**
170K

Diamond “A” Mutual Water Company

A California Nonprofit Public Benefit Corporation



2025 Consumer Confidence Report

July 1, 2026

Water System Information

Water System Name: **Diamond A MWC #4900562**

Report Date: 06/03/26

Type of Water Source(s) in Use: Groundwater Well

Name and General Location of Source(s): Well 01, Well 02, Well 03 & Well 04. Well 01& Well 02 are located on Spring Dr. Well 03 is located on Alta Sonoma Dr., and Well 04 is located behind 4480 Grove St.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Quarterly & Annual Board Meetings.

For More Information, Contact: Joe Lieber at 707-337-6047

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025 and may include earlier monitoring data due to the State allowing us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Diamond A MWC Ph#: 707-337-2094 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系以获得中文的帮助 Diamond A MWC Ph#: 707-337-2094

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan Diamond A MWC Ph#: 707-337-2094 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Diamond A MWC Ph#: 707-337-2094 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsaab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Diamond A MWC Ph#: 707-337-2094 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Mitigation Measures You Can Take

Should you have concerns about any substances in the water, you can, out of an abundance of caution, elect to install an under-sink reverse osmosis treatment system. This would provide you with drinking and food preparation water that is free of *any substances* (essentially similar to distilled water). These units cost in the neighborhood of \$215 + installation. Here is a link to a well-rated model: <https://www.aquasana.com/under-sink-water-filters/smart-flow-reverse-osmosis/>. A whole house unit is about \$2000 + installation.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppm)	07/03/23	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	07/03/23	5	.072	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm) Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	18 mg/l 23 mg/l 25 mg/l 32 mg/l	18-32 mg/l	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm) Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	160 mg/l 160 mg/l 160 mg/l 110 mg/l	110-160 mg/l	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chromium Well 01	10/19/20	1.6 ug/l	1.6 ug/l	50 ug/l	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
ARSENIC Well 02 Well 04	10/10/23 06/10/25	2.4 ug/l 4.4 ug/l	2.4 – 4.4 ug/l	10 ug/l	.004 ug/l	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Gross Alpha Particle Activity (pCi/L) Well 04	01/15/2018	0.322 pCi/L	0.322 pCi/L	15 pCi/L	(0)	Erosion of natural deposits
FLUORIDE Well 01 Well 02	10/19/20 10/19/20	0.36 mg/l 0.36 mg/l	0.36 mg/l	2.0 mg/l	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Chromium (hexavalent) (ug/L) Well 01	02/10/25	0.29 ug/l	0.29 ug/l	10 ug/l	0.02 ug/l	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as

						discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
--	--	--	--	--	--	--

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Color Well 01	10/10/23	5 Units	5 Units	15 Units	N/A	Naturally occurring organic materials
Turbidity Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	.1 NTU .85 NTU .10 NTU .10 NTU	.10-.85 NTU	5 NTU	N/A	Soil runoff
Odor Threshold Well 01 Well 02 Well 03	10/10/23 10/10/23 10/10/23	1.0 1.4 *4.0	1-4 TON	3 Units	N/A	Naturally occurring organic materials
Specific Conductance Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	350 uS/cm 330 uS/cm 350 uS/cm 330 uS/cm	330 -350 uS/cm	1600 uS/cm	N/A	Substances that form ions when in water; seawater influence
Sulfate Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	8.4 mg/l 9.5 mg/l 6.9 mg/l 13 mg/l	7-13 mg/l	500 mg/l	N/A	Runoff/leaching from natural deposits; industrial wastes
Manganese Well 01 Well 02 Well 03 Well 04	10/19/20 10/10/23 10/19/20 06/06/22	88 ug/l 34 ug/l 35 ug/l 42 ug/l	34 - *88 ug/l	50 ug/l	N/A	Leaching from natural deposits
Zinc Well 01	10/10/23	84 ug/l	84ug/l	5000 ug/l	N/A	Runoff/ leaching from natural deposits

TDS Well 01 Well 02 Well 03 Well 04	10/10/23 10/10/23 10/10/23 06/10/25	220 mg/l 240 mg/l 250 mg/l 240 mg/l	220-250 mg/l	1000 mg/l	N/A	Runoff/leaching from natural deposits
Iron Well 01 Well 02	10/19/20 QTRLY	590 ug/l 495 ug/l Annual Avg	*590 ug/l 160 – * 890 ug/l	300 ug/l	N/A	Leaching from natural deposits
Chloride: Well 04 Well 03 Well 02 Well 01	06/10/25 10/10/23 10/10/23 10/10/23	5 mg/l 6.1 mg/l 6.9 mg/l 13 mg/l	5-13 mg/l	500 mg/l	N/A	Runoff/ leaching from natural deposits;

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
N/A					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Diamond A MWC is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0		0	(0)	Human and animal fecal waste
Enterococci	0		TT	N/A	Human and animal fecal waste
Coliphage	0		TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A

Special Notice for Uncorrected Significant Deficiencies: N/A

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				