

**Consumer Confidence Report
Certification Form**

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State
Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	LIBERTY SCHOOL
Water System Number:	4900714

The water system named above hereby certifies that its Consumer Confidence Report was distributed on JUNE 22, 2026, to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	CHRIS RAFANELLI
Name:	CHRIS RAFANELLI
Signature:	
Title:	SUPERINTENDENT
Phone Number:	707-795-4380
Date:	JUNE 22, 2026

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☒ Posting the CCR on the Internet at LIBERTYSD.ORG
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: **[INSERT INTERNET ADDRESS]**
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

Farsi, Persian

این گزارش حاوی اطلاعات مهمی در مورد آب آشامیدنی شماست.
آدرس در که 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL
آست تلفن شماره بگیریڈ تماس

French

Ce rapport contient des informations importantes concernant votre eau potable. Veuillez contacter [à 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL
pour de plus amples informations en français.

German

Dieser Bericht enthält wichtige Information über Ihr Trinkwasser. Bitte wenden Sie sich an 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL
unter 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL um Unterstützung in deutscher Sprache zu erhalten.

Hindi

इस रिपोर्ट में आपके पीने के जल से सम्बंधित महत्वपूर्ण जानकारी है। हिंदी में सहायता के लिए, 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL को अथवा पर संपर्क करें।

Hmong

Tsab ntawv no muaj cov ntsiab lus tseem ceeb hais txog koj cov dej haus. Thov hu rau 170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL ntawm yog koj xav tau kev pab hais lus Hmoob.

Japanese

この報告書には上水道に関する重要な情報が記されております。ご質問等ございましたら、170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL まで日本語でご連絡下さい。

Korean

이 보고서는 당신의 식수에 관한 중요한 정보를 포함하고 있습니다. 한국어로 된 도움을 원하시면 **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** 로 문의 하시기 바랍니다.

Mandarin (Simplified)

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** 以获得中文的帮助:

Mandarin (Traditional)

這份報告含有關於您的飲用水的重要訊息。請用以下地址和電話聯繫 **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** 以獲得中文的幫助:

Portuguese

Este relatório contém informação importante sobre sua água potável. Por favor entre em contato com **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** para auxílio em português.

Punjabi

ਐੱਸ ਰਿਪੋਟ ਵਿਚ ਤੁਵਾੜੇ ਪੀਣੇ ਦੇ ਵਾਰੇ ਮਹੱਤਵਪੂਰਨ ਸੂਚਨਾ ਹੈ। ਪੰਜਾਬੀ ਵਿਚ ਮਦਦ ਲਈ **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** ਤੇ ਸੰਪਰਕ ਕਰੋ।

Russian

Этот отчет содержит важную информацию о вашей питьевой воде. Пожалуйста, свяжитесь **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** для получения помощи на русском языке.

Spanish

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** para asistirlo en español.

Tagalog

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** para matulungan sa wikang Tagalog.

Thai

รายงานฉบับนี้มีข้อมูลที่สำคัญเกี่ยวกับน้ำประปาของท่าน
กรุณาติดต่อ **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** เพื่อการช่วยเหลือในภาษาไทย

Vietnamese

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ **170 LIBERTY SCHOOL ROAD, PETALUMA, CA, LIBERTY SCHOOL** để được trợ giúp bằng tiếng

2025 Consumer Confidence Report

Water System Information

Water System Name: Liberty School #4900714

Report Date: 06/03/26

Type of Water Source(s) in Use: Groundwater well

Name and General Location of Source(s): Well 01. The well is located at 170 Liberty School Rd.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Quarterly Board Meetings

For More Information, Contact: Chris Rafanelli at 707-795-4380

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025 and may include earlier monitoring data due to the State allowing us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Liberty School 707-795-4380 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Liberty School 707-795-4380

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Liberty School 707-795-4380 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Liberty School 707-795-4380 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsaab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Liberty School 707-795-4380 rau kev pab hauv lus Askiv.

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL

	violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the

ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal

					waste
--	--	--	--	--	-------

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppm)	08/21/2025	5	<0.005	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	08/21/2025	5	0.205	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	09/25/07	37 mg/l	37 mg/l	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	09/25/07	89 mg/l	89 mg/l	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic WELL TREATED	09/16/2025 12/02/2025	14 ug/l 4.5 ug/l	11-14 ug/l 3.5-5.9 ug/l	10 TT	4	Erosion of natural deposits; runoff from orchards; glass and

						electronics production wastes
Total Trihalomethanes TTHMs	08/03/2023	14 ug/l	14 ug/l	80 ug/l	N/A	By-product of drinking water disinfection
Gross Alpha	09/16/2025	1.96 pCi/l	1.96 pCi/l	15 pCi/l	(0)	Erosion of natural deposits

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Fluoride	06/05/24	.13 mg/l	.13 mg/l	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Iron	11/04/24	1400 ug/l	1400 ug/l	300 ug/l		Leaching from natural deposits; industrial wastes
Manganese	11/04/24	150 ug/l	150 ug/l	50 ug/l		Leaching from natural deposits

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Bromoform	08/03/23	5.8 ug/l	5.8 ug/l	N/A	N/A
Dibromoacetic Acid	08/03/23	2.80 ug/l	2.80 ug/l	N/A	N/A
Bromodichloromethane	08/03/23	1.80 ug/l	1.80 ug/l	N/A	N/A
Dibromochloromethane	08/03/23	5.80 ug/l	5.80 ug/l	N/A	N/A

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Liberty School is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Arsenic MCL	Raw water samples contain arsenic levels above the MCL.		There is a treatment system in place to reduce the arsenic in the water.	Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	1	2/7/25	0	(0)	Human and animal fecal waste
Enterococci	0		TT	N/A	Human and animal fecal waste
Coliphage	0		TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT**Special Notice of Fecal Indicator-Positive Groundwater Source Sample:**

02/07/2025 E. Coli was reported in Well 01. This was addressed and resolved by 02/12/2025. Treatment system was in place and in working order.

Special Notice for Uncorrected Significant Deficiencies: N/A**Table 9. Violation of Groundwater TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				