

2025 Consumer Confidence Report

Water System Information

Water System Name: CA4900897 Rodney Strong Vineyards

Report Date: 6/29/26

Type of Water Source(s) in Use: Groundwater wells

Name and General Location of Source(s): Well CA4900897-003 Pump House, Well CA4900897-004 Visitor Parking

Drinking Water Source Assessment Information: N/A

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A

For More Information, Contact: Larry Solomon 707-433-0918

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name] a [Enter Water System's Address or Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name] 以获得中文的帮助: [Enter Water System's Address][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address] o tumawag sa [Enter Water System's Phone Number] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại [Enter Water System's Address or Phone Number] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name] ntawm [Enter Water System's Address or Phone Number] rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/18/23	5	<.005	none	<.005- <.005	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	8/18/23	5	.7	none	<.005- 1	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/7/96	26	[Enter Range]	None	None	Salt present in the water and is generally naturally occurring
Well 003	7/24/200	33				
Well 004	0					
Hardness (ppm)	11/7/96	150	[Enter Range]	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
Well 003	7/24/200	140				
Well 004	0					

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chromium (hexavalent) (µg/L) Well #3 Well #4	11/1/24	<.020 .021		10	.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile
Nitrate (as no3) mg/l Well #3/Well#4	3/13/25 6/12/25 9/11/25 12/18/25	<.40/<.40 .49/<.40 <.40/<.40 <.40/<.40		45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrite (as N) mg/l Well #3 Well#4	5/2/25 5/2/25	<.40 <.40		1	1	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
<i>*Arsenic ug/l</i> <i>Well #3</i> <i>Well #4</i>	<i>3/13/25</i> <i>6/12/25</i>	<i>*66.5</i> <i>*16.25</i>	<i>42-92</i> <i>15-17</i>	<i>10</i>	<i>.004</i>	<i>Erosion of natural deposits; runoff from</i>

	<i>9/11/25 12/18/25</i>					<i>orchards; glass and electronics production wastes</i>
Aluminum Well #3 Well#4 Ug/l	5/12/22 5/2/25	<50		1000	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Antimony Well #3 Well #4 ug/l	5/12/22 5/2/25	<6 <6		6	20	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder erosion of natural deposits; discharge from metal factories
Asbestos (MFL) Well #3 Well#4	9/12/24	<.17 <.17		7	7	Internal corrosion of asbestos cement water mains; erosion of natural deposits
Barium Well #3 Well #4 Ug/l	5/12/22 5/2/25	220 100		1000	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium Well #3 Well #4 ug/l	5/12/22 5/2/25	<1 <1		4	1	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium Well #3 Well #4 Ug/l	5/12/22 5/2/25	<1 <1		5	.04	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from

						waste batteries and paints
Chromium Well #3 Well #4 ug/l	5/12/22 5/2/25	<1 <1		50	100	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride Well #3 Well #4 Mg/l	5/12/22 5/2/25	.15 <.10		2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum
Mercury Well #3 Well #4 Ug/l	5/12/22 5/2/25	<1 <1		2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nickel Well #3 Well #4 Ug/l	5/12/22 5/2/25	<10 <10		100	12	Erosion of natural deposits; discharge from metal factories.
Perchlorate Well #3 Well #4 Ug/l	5/2/25 5/2/25	<1.0 <1.0		6	6	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use,

						store, or dispose of perchlorate and its salts
Selenium Well #3 Well #4 ug/l	5/12/22 5/2/25	<5 <5		50	30	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium Well #3 Well #4 Ug/l	5/12/22 5/2/25	<1 <1		2	.1	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
1,1,1 Trichloroethane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		200	1000	Discharge from metal degreasing sites and other factories; manufacture of food wrappings
Gross Alpha Particle Activity Well#3 Well#4 pCi/L	 5/2/25 5/2/25	 .458 1.78		15	3	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
1,2,3 TCP Ug/l Well 4	2/23/18 8/22/18 10/16/18	<.005 <.005 <.005		.005		
1,2,3 TCP Ug/l Well 3	2/23/18 10/16/18	<.005 <.005		.005		
1,1,2,2 tetrachloroethane Well#3 Well#4	5/12/22 5/2/25	<.5		1	0.1	Discharge from industrial and agricultural chemical

						factories; solvent used in production of TCE, pesticides, varnish and lacquers
1,1,2-Trichloroethane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	0.3	Discharge from industrial chemical factories
1,1-Dichloroethane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	3	Extraction and degreasing solvent; used in the manufacture of pharmaceuticals, stone, clay, and glass products; fumigant
1,1 Dichloroethylene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		6	10	Discharge from industrial chemical factories
1,2,4- Trichlorobenzene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	5	Discharge from textile-finishing factories
1,2-Dichlorobenzene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		600	600	Discharge from industrial chemical factories
1,2-Dichloroethane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		.5	400	Discharge from industrial chemical factories
1,2-Dichloropropane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	0.5	Discharge from industrial chemical factories; primary component of some fumigants

1,3-Dichloropropene (total) Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		.5	200	Runoff/leaching from nematocide used on croplands
1,4-Dichlorobenzene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	6	Discharge from industrial chemical factories
Benzene Well #3 Well #4	5/12/22 5/22/25	<.5 <.5		1	0.15	Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills
Carbon Tetrachloride Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		.5	100	Discharge from chemical plants and other industrial activities
CIS-1,2- Dichloroethylene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		6	100	Discharge from industrial chemical factories; major biodegradation byproduct of TCE and
Dichloromethane Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	4	Discharge from pharmaceutical and chemical factories; insecticide
Ethyl Benzene Well #3 Well #4	5/12/22 5/22/25	<.5 <.5		300	300	Discharge from petroleum refineries; industrial chemical factories
Methyl-tert-butyl- ether (mtbe) Well #3 Well #4	5/12/22 5/2/25	<3 <3		13	13	Leaking underground storage tanks; discharges from petroleum and chemical factories

Monochlorobenzene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		70 70	70	Discharge from industrial and agricultural chemical factories and dry-cleaning facilities
Styrene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		100	0.5	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	0.06	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Toluene Well #3 Well #4	5/12/22 5/22/25	<.5 <.5		150	150	Discharge from petroleum and chemical factories; underground gas tank leaks
Trans-1,2-Dichloroethylene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		10	60	Discharge from industrial chemical factories; minor biodegradation byproduct of TCE and PCE groundwater contamination
Trichloroethylene Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		5	1.7	Discharge from metal degreasing sites and other factories
Trichlorofluoromethane Freon 11 Well #3 Well #4	5/12/22 5/2/25	<5 <5		150	1300	Discharge from industrial factories; degreasing solvent; propellant and refrigerant
Trichlorotrifluoroethane (freon 113)	5/12/22 5/2/25	<10 <10		1200	400	Discharge from metal degreasing

Well #3 Well #4						sites and other factories; dry cleaning solvent; refrigerant
Vinyl Chloride Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		.5	50	Leaching from PVC piping; discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination
Xylenes (total) Well #3 Well #4	5/12/22 5/2/25	<.5 <.5		1750	1.8	Discharge from petroleum and chemical factories; fuel solvent
1,2,3-Trichloropropane Well #4	5/2/25	<.005		.005	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
2,4,5-TP (silvex) Well #3 Well #4	5/2/25 5/2/25	ND ND		50	3	Residue of banned herbicide
2,4-D Well #3	5/2/25	ND		70	20	Runoff from herbicide used on row crops, range

Well #4	5/2/25	ND				land, lawns, and aquatic weeds
Atrazine Well #3 Well #4	5/2/25 5/2/25	ND ND		1	0.15	Runoff from herbicide used on row crops and along railroad and highway rights-of-way
Carbofuran Well #3 Well #4	5/2/25 5/2/25	ND ND		18	0.7	Leaching of soil fumigant used on rice and alfalfa, and grape vineyards
Dalapon Well #3 Well #4	5/2/25 5/2/25	ND ND		200	790	Runoff from herbicide used on rights-of-ways, and crops and landscape maintenance
Dinoseb Well #3 Well #4	5/2/25 5/2/25	ND ND		7	14	Runoff from herbicide used on soybeans, vegetables, and fruits
Diquat Well #3 Well #4	5/2/25 5/2/25	ND ND		20	6	Runoff from herbicide use for terrestrial and aquatic weeds
Endothall Well #3 Well #4	5/2/25 5/2/25	48 ND		100	94	Runoff from herbicide use for terrestrial and aquatic weeds; defoliant
Ethylene Dibromide Well #3 Well #4	5/24/19	0		.05	10	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due

Heptachlor Well #3 Well #4	3/28/19 5/24/19	0		.010	8	Residue of banned insecticide
Heptachlor Epoxide Well #3 Well #4	3/28/18 5/24/19	0		.2	6	Breakdown of heptachlor
Lindane Well #3 Well #4	3/28/18 5/24/19	0		.2	32	Runoff/leaching from insecticide used on cattle, lumber, and gardens
Methoxychlor Well #3 Well #4	3/28/19 5/24/19	0		30	0.09	Runoff/leaching from insecticide used on
Oxamyl Well #3 Well #4	5/2/25 5/2/25	ND ND		1	26	Runoff/leaching from insecticide used on field crops, fruits and ornamentals, especially apples, potatoes, and tomatoes
Pentachlorophenol Well #3 Well #4	5/2/25 5/2/25	ND ND		1	0.3	Discharge from wood preserving factories, cotton and other insecticidal/herbi cidal uses
Picloram Well #3 Well #4	5/2/25 5/2/25	ND ND		500	166	Herbicide runoff
Toxaphene Well #3 Well #4	3/28/18 5/24/19	ND ND		3	0.03	Runoff/leaching from insecticide used on cotton and cattle
Simazine Well #3 Well #4	5/2/25 5/2/25	ND ND		4	4	Herbicide runoff
Bentazon Well #3 Well #4	5/2/25 5/2/25	ND ND		200	0.018	Runoff/leaching from herbicide used on beans, peppers, corn,

						peanuts, rice, and ornamental grasses
--	--	--	--	--	--	---

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (secondary) Well#3 Well#4 Ug/l	5/9/2013	<50		200		Erosion of natural deposits; residual from some surface water treatment processes
Chloride Well#3 Well#4 Mg/l	5/13/2010	22 20		500		Runoff/leaching from natural deposits; seawater influence
Color Well#3 Well#4 Unit	5/13/2010	3 <3		15		Naturally-occurring organic materials
Copper Well#3 Ug/l	5/13/2010	<50		1000		Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Foaming agents(mbas) Well#3 Well#4 Mg/l	5/13/2010	<0.05		.50		Municipal and industrial waste discharges
<i>*Manganese Well#4 Ug/l</i>	<i>5/12/2011</i>	<i>130.0</i>		<i>50</i>		<i>Leaching from natural deposits</i>
Odor Well#3 Well#4 Units	5/13/2010	<1		3		Naturally-occurring organic materials
Silver Well#3 Well#4 Ug/l	5/9/2013	<10		100		Industrial discharges

Specific conductance Well#3 Well#4 Umho	5/13/2010	370		1600		Substances that form ions when in water; seawater influence
Sulfate Well#3 Well#4 Mg/l	5/13/2010	8.70 9.60		500		Runoff/leaching from natural deposits; industrial wastes
Total dissolved solids Well#3 Well#4 Mg/l	5/13/2010	230		1000		Runoff/leaching from natural deposits
Zinc Well#3 Ug/l	5/13/2010	<50		5000		Runoff/leaching from natural deposits; industrial wastes
Turbidity Well#3 Well#4 Ntu	5/13/2010 5/13/2010	3.1 .20		5		Soil runoff
Aluminum (secondary) Well#3 Well#4 Ug/l	5/9/2013	<50		200		Erosion of natural deposits; residual from some surface water treatment processes
Chloride Well#3 Well#4 Mg/l	5/13/2010	22 20		500		Runoff/leaching from natural deposits; seawater influence

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Dicamba Well #3 Well#4	5/2/25 5/2/25	ND ND		500	

[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter Language]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter Language]

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact [NAME OF UTILITY and CONTACT INFORMATION]. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

State Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
-----------	-------------	----------	------------------------------------	-------------------------

Violation of Arsenic MCL	<i>Levels are above 10 ug/l directly from well</i>	1/1/2024-12/31/2024	<i>We have implemented Arsenic removal systems throughout the winery in order to bring arsenic levels to safe drinking water standards.</i>	<i>While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.</i>

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) [Enter No.]	[Enter Dates]	0	(0)	Human and animal fecal waste
Enterococci	(In the year) [Enter No.]	[Enter Dates]	TT	N/A	Human and animal fecal waste
Coliphage	(In the year) [Enter No.]	[Enter Dates]	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: [Enter Special Notice of Fecal Indicator-Positive Groundwater Source Sample]

Special Notice for Uncorrected Significant Deficiencies: [Enter Special Notice for Uncorrected Significant Deficiencies]

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

Treatment Technique ^(a) (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month. 2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours. 3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.

Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	[Enter No.]
Highest single turbidity measurement during the year	[Enter No.]
Number of violations of any surface water treatment requirements	[Enter No.]

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]

Summary Information for Operating Under a Variance or Exemption

[Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

The water system shall include the following statements, as appropriate:

During the past year we were required to conduct [Insert Number of Level 1 Assessments] Level 1 assessment(s). [Insert Number of Level 1 Assessments] Level 1 assessment(s) were completed. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

During the past year [Insert Number of Level 2 Assessments] Level 2 assessments were required to be completed for our water system. [Insert Number of Level 2 Assessments] Level 2 assessments were completed. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

If the water system failed to complete all the required assessments or correct all identified sanitary defects, the water system is in violation of the treatment technique requirement and shall include the following statements, as appropriate:

During the past year we failed to conduct all of the required assessment(s).

During the past we failed to correct all identified defects that were found during the assessment.

[For Violation of the Total Coliform Bacteria TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

If a water system is required to comply with a Level 2 assessment requirement that is due to an *E. coli* MCL violation, include the information below [22 CCR section 64481(n)(2)].

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

If a water system failed to complete the required assessment or correct all identified sanitary defects, the water system is in violation of the treatment technique requirement and shall include the following statements, as appropriate:

We failed to conduct the required assessment.

We failed to correct all sanitary defects that were identified during the assessment.

If a water system detects *E. coli* and has violated the *E. coli* MCL, include one or more the following statements to describe any noncompliance, as applicable:

We had an *E. coli*-positive repeat sample following a total coliform positive routine sample.

We had a total coliform-positive repeat sample following an *E. coli*-positive routine sample.

We failed to take all required repeat samples following an *E. coli*-positive routine sample.

We failed to test for *E. coli* when any repeat sample tests positive for total coliform.

[If a water system detects *E. coli* and has not violated the *E. coli* MCL, the water system may include a statement that explains that although they have detected *E. coli*, they are not in violation of the *E. coli* MCL.]

APPENDIX B: eCCR Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	Rodney Strong Vineyards
Water System Number:	CA4900897

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/30/2026 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Larry Solomon	Title: Director of Facilities
Signature: 	Date: 6/30/26
Phone number: 707-433-0918	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

Posted CCR Locations:

- **Outside Bottling Breakroom**
 - **Barrel Building Breakroom**
 - **Administration Breakroom**
 - **Tasting Room**
-