

2018 Consumer Confidence Report

Water System Name: Sonoma County Central Landfill

Report Date: June 24th 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name Here] a [Enter Water System's Address or Phone Number Here] para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System's Name Here]以获得中文的帮助:[Enter Water System's Address Here][Enter Water System's Phone Number Here]

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address Here] o tumawag sa [Enter Water System's Phone Number Here] para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name Here] tại [Enter Water System's Address or Phone Number Here] để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name Here] ntawm [Enter Water System's Address or Phone Number Here] rau kev pab hauv lus Askiv.

Type of water source(s) in use: Well

Name & general location of source(s): Well 01

Drinking Water Source Assessment information: _____

Time and place of regularly scheduled board meetings for public participation: _____

For more information, contact: Bartley Pump PM LLC

Phone: (707)584-9191

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	11/20/2014	5	0	0	15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	11/20/2014	5	0.365	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural

								deposits; leaching from wood preservatives
--	--	--	--	--	--	--	--	--

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	3/18/2010	38		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	3/18/2010	82		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<u>Arsenic ug/L</u>	2/26/2019	4.0ug/l		<u>10</u>	<u>.004</u>	<u>Erosion of natural deposits; runoff from orchards; glass and electronics production wastes</u>
<u>Aluminum</u>	10/5/2018	<50ug/l		<u>1</u>	<u>0.6</u>	<u>Erosion of natural deposits; residue from some surface water treatment processes</u>
<u>Antimony</u>	10/5/2018	<6ppb		<u>6</u>	<u>20</u>	<u>Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder</u>
<u>Barium</u>	10/5/2018	<100ppb		<u>1</u>	<u>2</u>	<u>Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits</u>
<u>Beryllium</u>	10/5/2018	<1.0ppb		<u>4</u>	<u>1</u>	<u>Discharge from metal refineries, coal-burning factories, and electrical, aerospace, and defense industries</u>
<u>Cadmium</u>	10/5/2018	<1.0ppb		<u>5</u>	<u>0.04</u>	<u>Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and metal refineries; runoff from waste batteries and paints</u>
<u>Chromium</u>	10/5/2018	<1.0ppb		<u>50</u>	<u>(100)</u>	<u>Discharge from steel and pulp mills and chrome plating; erosion of natural deposits</u>
<u>Mercury (inorganic)</u>	10/5/2018	<1.0ppb		<u>2</u>	<u>1.2</u>	<u>Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland</u>
<u>Nickel</u>	10/5/2018	<10ppb		<u>100</u>	<u>12</u>	<u>Erosion of natural deposits; discharge from metal factories</u>
<u>Selenium</u>	10/5/2018	<5.0ppb		<u>50</u>	<u>30</u>	<u>Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)</u>
<u>Fluoride mg/L</u>	10/5/2018	<u>0.28</u>		<u>2.0</u>	<u>1</u>	<u>Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories</u>
<u>Gross Alpha pCi/L</u>	4/4/2017	3pci/l		<u>15</u>	<u>0</u>	<u>Erosion of natural deposits</u>
<u>Nitrate (as nitrate, NO3)</u>	2/26/2019	<0.4		<u>45</u>	<u>45</u>	<u>Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits</u>

<u>Perchlorate</u>	<u>7/16/2015</u>	<u><4</u>		<u>6</u>	<u>6</u>	<u>Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts</u>
<u>Chlorine</u>	<u>All months</u>	<u>0.6</u>	<u>Trace-1.8mg/l free</u>	<u>4.0</u>		<u>Drinking water disinfectant added for treatment</u>
<u>Benzene</u>	<u>3/8/13</u>	<u>.30</u>	<u>.50</u>	<u>.15</u>	<u>1</u>	<u>Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills</u>
<u>Carbon Tetrachloride ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>.5</u>	<u>100</u>	<u>Discharge from chemical plants and other industrial activities</u>
<u>1,2-Dichlorobenzene (o-DCB) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>600</u>	<u>600</u>	<u>Discharge from industrial chemical factories</u>
<u>1,4-Dichlorobenzene (p-DCB) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>6</u>	<u>Discharge from industrial chemical factories</u>
<u>1,1-Dichloroethane (1,1-DCA) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>3</u>	<u>Extraction and degreasing solvent; used in the manufacture of pharmaceuticals, stone, clay, and glass products; fumigant</u>
<u>1,2-Dichloroethane (1,2-DCA)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>.5</u>	<u>400</u>	<u>Discharge from industrial chemical factories</u>
<u>1,1-Dichloroethylene (1,1-DCE)ppb</u>	<u>3/8/13</u>	<u><.30</u>	<u>.50</u>	<u>6</u>	<u>10</u>	<u>Discharge from industrial chemical factories</u>
<u>cis-1,2-Dichloroethylene (c-1,2-DCE) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>6</u>	<u>100</u>	<u>Discharge from industrial chemical factories; major biodegradation byproduct of TCE and PCE groundwater contamination</u>
<u>trans-1,2-Dichloroethylene (t-1,2-DCE)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>10</u>	<u>60</u>	<u>Discharge from industrial chemical factories; major biodegradation byproduct of TCE and PCE groundwater contamination</u>
<u>Dichloromethane (Methylene Chloride)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>4</u>	<u>Discharge from pharmaceutical and chemical factories; insecticide</u>
<u>1,2-Dichloropropane ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>.5</u>	<u>Discharge from industrial chemical factories; primary component of some fumigants</u>
<u>Ethyl Benzene ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>300</u>	<u>300</u>	<u>Discharge from petroleum refineries; industrial chemical factories</u>
<u>Methyl tert-Butyl Ether (MTBE) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>3.00</u>	<u>5</u>	<u>13</u>	<u>Leaking underground storage tanks; discharges from petroleum and chemical factories</u>
<u>Monochlorobenzene (Chlorobenzene) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>70</u>	<u>200</u>	<u>Discharge from industrial and agricultural chemical factories and drycleaning facilities</u>
<u>Styrene ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>100</u>	<u>.50</u>	<u>Discharge from rubber and plastic factories; leaching from landfills</u>
<u>1,1,2,2-Tetrachloroethane ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>1</u>	<u>.10</u>	<u>Discharge from industrial and agricultural chemical factories; solvent used in production of TCE, pesticides, varnish and lacquers</u>
<u>Tetrachloroethylene (PCE) ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>.06</u>	<u>Discharge from factories, dry cleaners, and auto shops (metal degreaser)</u>
<u>Toluene ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>150</u>	<u>150</u>	<u>Discharge from petroleum and chemical factories; underground gas tank leaks</u>
<u>1,2,4-Trichlorobenzene ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>5</u>	<u>Discharge from textile-finishing factories</u>

<u>1,1,1-Trichloroethane (1,1,1-TCA)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>200</u>	<u>1000</u>	<u>Discharge from metal degreasing sites and other factories; manufacture of food wrappings</u>
<u>1,1,2-Trichloroethane (1,1,2-TCA)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>.3</u>	<u>Discharge from industrial chemical factories</u>
<u>Trichloroethylene (TCE)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>5</u>	<u>1.7</u>	<u>Discharge from metal degreasing sites and other factories</u>
<u>Trichlorofluoromethane (FREON 11)</u>	<u>3/8/13</u>	<u><.50</u>	<u>5.00</u>	<u>150</u>	<u>700</u>	<u>Discharge from metal degreasing sites and other factories; drycleaning solvent; refrigerant</u>
<u>Trichlorotrifluoroethane (FREON 113)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>10.00</u>	<u>1200</u>	<u>4</u>	<u>Discharge from metal degreasing sites and other factories; drycleaning solvent; refrigerant</u>
<u>Vinyl Chloride (VC)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>.5</u>	<u>50</u>	<u>Leaching from PVC piping; discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination</u>
<u>Total Xylenes (m,p, & o)ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>	<u>1750</u>	<u>1.8</u>	<u>Discharge from petroleum and chemical factories; fuel solvent</u>
<u>1,3-Dichloropropane ppb</u>	<u>3/8/13</u>	<u><.50</u>	<u>.50</u>		<u>.5</u>	<u>Runoff/leaching from nematocide used on croplands</u>
<u>Total Trihalomethanes (TTHMs) ppb</u>	<u>03/28/14</u>	<u>5.21</u>		<u>80</u>	<u>N/A</u>	<u>By-product of drinking water disinfection</u>
<u>Bromodichloromethane ppb</u>	<u>3/7/13</u>	<u><.50</u>	<u>1.0</u>			
<u>Bromoform ppb</u>	<u>3/7/13</u>	<u><.50</u>	<u>1.0</u>			
<u>Chloroform ppb(Trichloromethane)ppb</u>	<u>3/7/13</u>	<u><.50</u>	<u>1.0</u>			
<u>Dibromochloromethane ppb</u>	<u>3/7/13</u>	<u><.50</u>	<u>1.0</u>			
<u>Haloacetic Acids (five) (HAAS)</u>	<u>03/28/14</u>	<u>2.1</u>		<u>60</u>	<u>N/A</u>	<u>By-product of drinking water disinfection</u>
<u>Monochloroacetic Acid (MCAA)</u>	<u>3/7/13</u>	<u><2.0</u>	<u>2.0</u>			
<u>Dichloroacetic Acid (DCAA)</u>	<u>3/7/13</u>	<u><1.0</u>	<u>1.0</u>			
<u>Trichloroacetic Acid (TCAA)</u>	<u>3/7/13</u>	<u><1.0</u>	<u>1.0</u>			
<u>Monobromoacetic Acid (MBAA)</u>	<u>3/7/13</u>	<u><1.0</u>	<u>1.0</u>			
<u>Dibromoacetic Acid (DBAA)</u>	<u>3/7/13</u>	<u><1.0</u>	<u>1.0</u>			
Nitrate	4/04/2017	0.4	10			Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [ENTER WATER SYSTEM'S NAME HERE] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [OPTIONAL: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

For Water Systems Providing Groundwater as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)		0	(0)	Human and animal fecal waste
Enterococci	(In the year)		TT	N/A	Human and animal fecal waste
Coliphage	(In the year)		TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Groundwater TT

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE				
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES				
VIOLATION OF GROUNDWATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique ^(a) (Type of approved filtration technology used)	
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to ____ NTU in 95% of measurements in a month. 2 – Not exceed ____ NTU for more than eight consecutive hours. 3 – Not exceed ____ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	
Highest single turbidity measurement during the year	
Number of violations of any surface water treatment requirements	

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

Summary Information for Operating Under a Variance or Exemption

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct [**INSERT NUMBER OF LEVEL 1 ASSESSMENTS**] Level 1 assessment(s). [**INSERT NUMBER OF LEVEL 1 ASSESSMENTS**] Level 1 assessment(s) were completed. In addition, we were required to take [**INSERT NUMBER OF CORRECTIVE ACTIONS**] corrective actions and we completed [**INSERT NUMBER OF CORRECTIVE ACTIONS**] of these actions.

During the past year [**INSERT NUMBER OF LEVEL 2 ASSESSMENTS**] Level 2 assessments were required to be completed for our water system. [**INSERT NUMBER OF LEVEL 2 ASSESSMENTS**] Level 2 assessments were completed. In addition, we were required to take [**INSERT NUMBER OF CORRECTIVE ACTIONS**] corrective actions and we completed [**INSERT NUMBER OF CORRECTIVE ACTIONS**] of these actions.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take [**INSERT NUMBER OF CORRECTIVE ACTIONS**] corrective actions and we completed [**INSERT NUMBER OF CORRECTIVE ACTIONS**] of these actions.

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems