

APPENDIX F: Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	Sweetwater springs water district (monte rio)
Water System Number:	P.S 4910028

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5/15/2021 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	Name:	JACK BUSHGEN	
	Signature:		
	Title:	FIELD MANAGER	
	Phone Number:	(707) 869-4000	Date: 6/17/2021

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____

☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- ☒ Posting the CCR on the Internet at **www.sweetwatersprings.com**_____
- ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertising the availability of the CCR in news media (attach copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)

Instructions for Small Water Systems Appendix F
Revised February 2021

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following address: www._____
- ☐ *For investor-owned utilities:* Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

**Sweetwater Springs
Water District**
17081 Hwy. 116, Ste. B
P.O. Box 48
Guerneville, CA 95446
Tel (707) 869-4000
Fax (707) 869-4005
E-mail sws@monitor.net
Website: www.sweetwatersprings.com

Sweetwater Springs Water District 2020 Consumer Confidence Report Monte Rio

Board of Directors

Sukey Robb-Wilder, Pres.
Larry Spillane
Gaylord Schaap
Tim Lipinski
Rich Holmer

Monthly Board meetings are held
the first Thursday of every month.

Contact Person: Jack Bushgen, Field Manager

Dear Sweetwater Springs Customer:

Water quality is an important issue with us. Providing water that meets state and federal drinking water standards is our Number 1 priority. The District provides water quality information each year to customers in conformance with these state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020

The District's water is supplied by two groundwater wells (#4, #5) located in Monte Rio. A source water assessment was completed for both wells in April 2005. These sources are considered most vulnerable to high density septic systems not associated with any detected contaminants. You can obtain a summary of the assessment at our office at 17081 Hwy. 116, Ste. B, Guerneville.

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the state Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old. One school requested lead sampling.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (to be completed only if there was a detection of bacteria)	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria 2020	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year 2020) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste
<i>E. coli</i> (Federal revised Total Coliform Rule)	(In the year 2020) 0	0	(b)	0	Human and animal fecal waste
(a) Two or more positive monthly samples is a violation of the MCL. (b) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .					

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 th percentile level detected	No. Sites exceeding AL	AL	MCLG	No. schools requesting lead samples	Typical Source of Contaminant
Lead (ppb) Sample date: 2019	11	<5.0	0	15	0.2	1	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppb) Sample date: 2019	11	0.81	0	1.3	0.3	N/A	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2019	10	10	none	none	Generally found in ground and surface water
Hardness (ppm)	2019	150	150	none	none	Generally found in ground and surface water

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Gross Alpha (Radioactive) (pCi/L)	2013	0.57	0.57	15	N/A (0)	Erosion of natural deposits

Asbestos (MFL)	2018	ND	ND	7	7	Interior corrosion of asbestos mains; erosion of natural deposits
Barium (ppb)	2013	170	170	1000	N/A (2)	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2013	0.19	0.19	2	N/A (1)	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Arsenic (ppb)	2019	2.4	2.4	10	0.004	Erosion of natural deposits: Runoff from orchards, glass and electronics production wastes
Nitrate (as N)(ppm)	2020	Avg 0.4	0.4	10	N/A (45)/0	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
DISINFECTION BYPRODUCTS, DISINFECTANT RESIDUALS AND DISINFECTION BYPRODUCT AND PRECURSORS IN DISTRIBUTION SYSTEM						
Total Trihalomethanes (PPB)	2020	12	12	80	N/A (NA)	Byproduct of drinking water chlorination
Total Haloacetic Acids (PPB)	2020	2	2	60	N/A (NA)	Byproduct of drinking water chlorination
Chlorine (PPM)	Daily 2020	Avg 1.2	1.0 - 1.4	4	4	Drinking water disinfectant added to treatment
TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Color (units)	2019	15 before treatment	15 before treatment	15	N/A (N/A)	Naturally-occurring organic materials
Iron (ppb)	2020	ND after treatment	ND after treatment	300	N/A (N/A)	Leaching from natural deposits; industrial wastes
Manganese (ppb)	2020	ND after treatment	ND after treatment	50	N/A (N/A)	Leaching from natural deposits
Turbidity (units)	2019	4.3 before treatment	4.3 before treatment	5	N/A (N/A)	Soil runoff
Total Dissolved Solids (TDS) (ppm)	2019	190	190	1000	N/A (N/A)	Runoff/leaching from natural deposits
Specific Conductance (micromhos)	2019	350	350	1600	N/A (N/A)	Substances that form ions when in water; seawater influence
Chloride (ppm)	2019	16.0	16.0	500	N/A (N/A)	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2019	5.9	5.9	500	N/A (N/A)	Runoff/leaching from natural deposits' industrial wastes
TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS						
During the last 9 years there has not been any detection of unregulated contaminants.						

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

pCi/L: picocuries per liter (a measure of radiation)

MFL: million fibers per liter

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.