

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	LAZY B MOBILEHOME PARK
Water System Number:	CA5000048

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

- "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
 - Posted the CCR on the internet at http:// _____
 - Mailed the CCR to postal patrons within the service area (attach zip codes used)
 - Advertised the availability of the CCR in news media (attach a copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Other (attach a list of other methods used)

- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

- For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2024 Consumer Confidence Report

Water System Name: LAZY B MOBILEHOME PARK

Report Date: May 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): North East Well #1 and West #02

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209)838-7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	20	15 - 24	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	174	143 - 205	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022)	ND	ND - 2	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2022)	ND	ND - 0.10	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	(2022)	ND	ND - 0.1	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2024)	10	8.8 - 10.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	7.5	6.3 - 8.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2016)	2.31	1.96 - 2.48	15	(0)	Erosion of natural deposits.

Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	26	22 - 29	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2022)	474	463 - 485	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	13.6	12.6 - 14.6	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	290	280 - 300	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2022)	0.1	ND - 0.1	5	n/a	Soil runoff

Table 4 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	(2022)	10	6 - 13	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
Perfluorooctanoic Acid [PFOA] (ng/L)	(2024)	2.5	ND - 4.6	5.1	n/a
Perfluorooctanesulfonic Acid [PFOS] (ng/L)	(2024)	4.5	ND - 9.4	6.5	Perfluorooctanesulfonic acid exposures resulted in immune suppression and cancer in laboratory animals.
Perfluorobutane Sulfonic Acid [PFBS] (ng/L)	(2024)	2.7	ND - 5.2	500	n/a
Perfluorohexanoic Acid [PFHxA] (ng/L)	(2024)	6.3	ND - 13	n/a	n/a
Perfluorobutanoic acid [PFBA] (ng/L)	(2024)	2.1	ND - 4.3	n/a	n/a
Perfluoropentanoic acid [PFPeA] (ng/L)	(2024)	7.2	ND - 15	n/a	n/a
Perfluoroheptanoic Acid [PFHpA] (ng/L)	(2024)	0.5	ND - 2.2	n/a	n/a

Table 5 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	43	31 - 54	n/a	n/a
Magnesium (mg/L)	(2022)	17	16 - 17	n/a	n/a
pH (units)	(2022)	7.7	7.46 - 7.94	n/a	n/a
Alkalinity (mg/L)	(2022)	150	n/a	n/a	n/a
Aggressiveness Index	(2022)	11.9	11.5 - 12.2	n/a	n/a
Langelier Index	(2022)	0.1	-0.3 - 0.4	n/a	n/a

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Total (mg/L)	(2023)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Quality Service LAZY B Mobile Home Park* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Nitrate as N	The West #2 well has exceeded the nitrate MCL and the North East Well #1 has increasing nitrate levels.	November 2023 - current	The water system received Compliance Order No. DER-23R007 from Stanislaus County DER in order to comply with the nitrate MCL. The water system is working towards compliance through posting monthly public notices, performing quarterly nitrate sampling, and working towards consolidation with a municipal water system.	Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2024 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the NORTH EAST WELL #1 and the WEST #02 of the LAZY B MOBILEHOME PARK water system in June, 2002.

North East Well #1 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Injection wells/dry wells/ sumps
Septic systems - high density [$>1/\text{acre}$]

is considered to be most vulnerable to the following activities associated with contaminants detected in

the water supply:
wells - agricultural/irrigation and pesticide application.

West #02 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Injection wells/dry wells/ sumps
Septic systems - high density [$>1/\text{acre}$]

is considered to be most vulnerable to the following activities associated with contaminants detected in the

water supply:
wells - agricultural/irrigation and pesticide application.

Discussion of Vulnerability

North East Well #1: Dibromochloropropane (DBCP) has been detected in the water supply, below the State maximum contaminant level (MCL), during the monitoring history for this source. DBCP was not detected in an analysis performed July 30, 2001. Nitrates have been detected above half of the MCL. Additional monitoring for this contaminant and D.B.C.P. has been required, as per State standards. The following activities are associated with nitrates; injection/dry wells/sumps, septic systems - high density, and other animal operations.

Hexavalent chromium has been detected in the water. The State has not set a MCL or Action Level for this contaminant in drinking water supplies. The following activities are associated with hexavalent chromium; use or manufacture of wood preservative products, industrial applications, (e.g. automobile, appliance and other consumer product manufacturing), steel hardening, manufacturing of stainless steel and other alloys, chromium plating, pigment making, leather tanning, welding, and water treatment facilities that use oxidants (e.g. chlorine, ozone, permanganate).

West Well #02: Historically, Dibromochloropropane (DBCP) has been detected in the water, although it was below the State maximum contaminant level (MCL). DBCP was not detected in an analysis performed July 30, 2001. In addition, the source is considered most vulnerable to these activities for which no associated contaminant has been detected; injection/dry wells/sumps, septic systems - high density, and other animal operations.

Hexavalent chromium has been detected in the water. The State has not set a MCL or Action Level for this contaminant in drinking water supplies.

Acquiring Information

A copy of the assessment is available at:
Lazy B MOBILE HOME PARK OFFICE
7341 Eleanor Avenue
Oakdale, CA 95361

A copy of the complete assessment may be viewed at:
Stanislaus County, DER

3800 Cornucopia Way, Suite C
Modesto, CA 95358

You may request a summary of the assessment be sent to you by contacting:
Stanislaus County Department of Environmental Resources
Water Senior/Water Team Member
(209) 525-6700

Quality Service LAZY B MHP

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
Space #10	STK2455713-1					2024-10-22	Absent		
Space #10	STK2438633-1					2024-06-12	Absent		
Space #10	STK2432174-1					2024-02-14	Absent		
Space #18	STK2457339-1					2024-11-22	Absent		
Space #18	STK2450343-1					2024-07-16	Absent		
Space #18	STK2433709-1					2024-03-19	Absent		
Space #32	STK2453710-1					2024-09-13	Absent		
Space #32	STK2437291-1					2024-05-22	Absent		
Space #32	STK2430684-1					2024-01-15	Absent		
Space #38	STK2458112-1					2024-12-11	Absent		
Space #38	STK2452494-1					2024-08-22	Absent		
Space #38	STK2434958-1					2024-04-11	Absent		
Fecal coliform and E. coli			0	n/a				ND	-
Space #10	STK2455713-1					2024-10-22	Absent		
Space #10	STK2438633-1					2024-06-12	Absent		
Space #10	STK2432174-1					2024-02-14	Absent		
Space #18	STK2457339-1					2024-11-22	Absent		
Space #18	STK2450343-1					2024-07-16	Absent		
Space #18	STK2433709-1					2024-03-19	Absent		
Space #32	STK2453710-1					2024-09-13	Absent		
Space #32	STK2437291-1					2024-05-22	Absent		
Space #32	STK2430684-1					2024-01-15	Absent		
Space #38	STK2458112-1					2024-12-11	Absent		
Space #38	STK2452494-1					2024-08-22	Absent		
Space #38	STK2434958-1					2024-04-11	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
CuPb-Space #01	STK2450504-5	ug/L				2024-07-10	ND		
CuPb-Space #13	STK2450504-4	ug/L				2024-07-10	ND		
CuPb-Space #17	STK2450504-2	ug/L				2024-07-11	ND		
CuPb-Space #29	STK2450504-1	ug/L				2024-07-11	ND		
CuPb-Space #45	STK2450504-3	ug/L				2024-07-09	ND		
Copper		mg/L		1.3	.3			0	5
CuPb-Space #01	STK2450504-5	mg/L				2024-07-10	ND		
CuPb-Space #13	STK2450504-4	mg/L				2024-07-10	ND		
CuPb-Space #17	STK2450504-2	mg/L				2024-07-11	ND		
CuPb-Space #29	STK2450504-1	mg/L				2024-07-11	ND		
CuPb-Space #45	STK2450504-3	mg/L				2024-07-09	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			20	15 - 24
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	24		
WEST #02	STK2236127-1	mg/L				2022-05-05	15		
Hardness		mg/L		none	none			174	143 - 205
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	205		
WEST #02	STK2236127-1	mg/L				2022-05-05	143		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			ND	ND - 2
NORTH EAST WELL #1	STK2233328-1	ug/L				2022-03-10	ND		
WEST #02	STK2236127-1	ug/L				2022-05-05	2		
Barium		mg/L	2	1	2			ND	ND - 0.10
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	0.10		
WEST #02	STK2236127-1	mg/L				2022-05-05	ND		
Fluoride		mg/L		2	1			ND	ND - 0.1
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	0.1		
WEST #02	STK2236127-1	mg/L				2022-05-05	ND		
Nitrate as N		mg/L		10	10			9.4	6.0 - 12.8
North East Well #1	STK2455712-1	mg/L				2024-10-22	10.0		
North East Well #1	STK2450269-1	mg/L				2024-07-16	10.4		
NORTH EAST WELL #1	STK2339645-1	mg/L				2023-07-19	9.0		
West #02	STK2457338-1	mg/L				2024-11-22	8.8		
West #02	STK2452493-1	mg/L				2024-08-22	10.3		
West #02	STK2437356-1	mg/L				2024-05-22	10.3		
West #02	STK2432175-1	mg/L				2024-02-14	10.6		
WEST #02	STK2356123-1	mg/L				2023-11-20	10.3		
WEST #02	STK2355863-1	mg/L				2023-11-16	12.8		
WEST #02	STK2351382-1	mg/L				2023-08-21	6.8		
WEST #02	STK2336394-1	mg/L				2023-05-19	7.8		
WEST #02	STK2332177-1	mg/L				2023-02-17	6.0		
Nitrate + Nitrite as N		mg/L		10	10			7.5	6.3 - 8.7
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	8.7		
WEST #02	STK2236127-1	mg/L				2022-05-05	6.3		
Gross Alpha		pCi/L		15	(0)			2.31	1.96 - 2.48
NORTH EAST WELL #1	STK1655025-1	pCi/L				2016-12-08	2.48		
NORTH EAST WELL #1	STK1655025-1	pCi/L				2016-12-08	2.48		
WEST #02	STK1654977-1	pCi/L				2016-12-08	1.96		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			26	22 - 29
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	29		
WEST #02	STK2236127-1	mg/L				2022-05-05	22		
Specific Conductance		umhos/cm		1600	n/a			474	463 - 485
NORTH EAST WELL #1	STK2233328-1	umhos/cm				2022-03-10	485		
WEST #02	STK2236127-1	umhos/cm				2022-05-05	463		
Sulfate		mg/L		500	n/a			13.6	12.6 - 14.6
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	14.6		
WEST #02	STK2236127-1	mg/L				2022-05-05	12.6		
Total Dissolved Solids		mg/L		1000	n/a			290	280 - 300
NORTH EAST WELL #1	STK2233328-1	mg/L				2022-03-10	280		
WEST #02	STK2236127-1	mg/L				2022-05-05	300		
Turbidity		NTU		5	n/a			0.1	ND - 0.1
NORTH EAST WELL #1	STK2233328-1	NTU				2022-03-10	0.1		
WEST #02	STK2236127-1	NTU				2022-05-05	ND		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			10	6 - 13
NORTH EAST WELL #1	STK2233328-1	ug/L				2022-03-10	6		
WEST #02	STK2236127-1	ug/L				2022-05-05	13		
Perfluorooctanoic Acid [PFOA]		ng/L		NS	n/a			2.0	ND - 4.6
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		

NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	4.6		
WEST #02	STK2452492-3	ng/L				2024-08-22	3.8		
WEST #02	STK2437289-3	ng/L				2024-05-22	4.2		
WEST #02	STK2433708-3	ng/L				2024-03-19	3.3		
Perfluorooctanesulfonic Acid [PFOS]		ng/L		NS	n/a			3.7	ND - 9.2
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	8.1		
WEST #02	STK2452492-3	ng/L				2024-08-22	6.2		
WEST #02	STK2437289-3	ng/L				2024-05-22	9.2		
WEST #02	STK2433708-3	ng/L				2024-03-19	6.1		
Perfluorobutane Sulfonic Acid [PFBS]		ng/L		NS	n/a			2.2	ND - 5.2
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	5.2		
WEST #02	STK2452492-3	ng/L				2024-08-22	3.9		
WEST #02	STK2437289-3	ng/L				2024-05-22	4.8		
WEST #02	STK2433708-3	ng/L				2024-03-19	3.8		
Perfluorohexanoic Acid [PFHxA]		ng/L		NS	n/a			5.1	ND - 13
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	13		
WEST #02	STK2452492-3	ng/L				2024-08-22	9.2		
WEST #02	STK2437289-3	ng/L				2024-05-22	11		
WEST #02	STK2433708-3	ng/L				2024-03-19	7.9		
Perfluorobutanoic acid [PFBA]		ng/L		NS	n/a			2.1	ND - 4.3
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	2.9		
WEST #02	STK2458111-3	ng/L				2024-12-11	4.3		
WEST #02	STK2452492-3	ng/L				2024-08-22	3.1		
WEST #02	STK2437289-3	ng/L				2024-05-22	3.8		
WEST #02	STK2433708-3	ng/L				2024-03-19	2.3		
Perfluoropentanoic acid [PFPeA]		ng/L		NS	n/a			5.8	ND - 15
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	15		
WEST #02	STK2452492-3	ng/L				2024-08-22	10		
WEST #02	STK2437289-3	ng/L				2024-05-22	12		
WEST #02	STK2433708-3	ng/L				2024-03-19	9.3		
Perfluoroheptanoic Acid [PFHpA]		ng/L		NS	n/a			0.5	ND - 2.2
NORTH EAST WELL #1	STK2458111-1	ng/L				2024-12-11	ND		
NORTH EAST WELL #1	STK2452492-1	ng/L				2024-08-22	ND		
NORTH EAST WELL #1	STK2437289-1	ng/L				2024-05-22	ND		
NORTH EAST WELL #1	STK2433708-1	ng/L				2024-03-19	ND		
WEST #02	STK2458111-3	ng/L				2024-12-11	2.2		
WEST #02	STK2452492-3	ng/L				2024-08-22	ND		
WEST #02	STK2437289-3	ng/L				2024-05-22	1.9		
WEST #02	STK2433708-3	ng/L				2024-03-19	ND		

Quality Service LAZY B MHP

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CA5000048_LCR	STK2450504-5	2024-07-10	Metals, Total	CuPb-Space #01	LAZY B MOBILEHOME PARK
	STK2450504-4	2024-07-10	Metals, Total	CuPb-Space #13	LAZY B MOBILEHOME PARK
	STK2450504-2	2024-07-11	Metals, Total	CuPb-Space #17	LAZY B MOBILEHOME PARK
	STK2450504-1	2024-07-11	Metals, Total	CuPb-Space #29	LAZY B MOBILEHOME PARK
	STK2450504-3	2024-07-09	Metals, Total	CuPb-Space #45	LAZY B MOBILEHOME PARK
WELL 01-NEast	STK1655025-1	2016-12-08	Radio Chemistry	NORTH EAST WELL #1	Well #1 - Radio Monitoring
	STK2233328-1	2022-03-10	General Mineral	NORTH EAST WELL #1	Well #1 - Water Monitoring
	STK2233328-1	2022-03-10	Metals, Total	NORTH EAST WELL #1	Well #1 - Water Monitoring
	STK2233328-1	2022-03-10	Wet Chemistry	NORTH EAST WELL #1	Well #1 - Water Monitoring
	STK2334215-1	2023-04-06	Field Test	NORTH EAST WELL #1	LAZY B MOBILEHOME PARK
	STK2339645-1	2023-07-19	Wet Chemistry	NORTH EAST WELL #1	Well #1 - Water Monitoring
	STK2354621-1	2023-10-19	Field Test	NORTH EAST WELL #1	LAZY B MOBILEHOME PARK
	STK2433708-1	2024-03-19		NORTH EAST WELL #1	PFAS Monitoring
	STK2437289-1	2024-05-22		NORTH EAST WELL #1	PFAS Monitoring
	STK2450269-1	2024-07-16	Wet Chemistry	North East Well #1	Well #1 - Water Monitoring
	STK2452492-1	2024-08-22		NORTH EAST WELL #1	PFAS Monitoring
	STK2455712-1	2024-10-22	Wet Chemistry	North East Well #1	Well #1 - Water Monitoring
	STK2458111-1	2024-12-11		NORTH EAST WELL #1	PFAS Monitoring
Bacti-Rout-ss02	STK2432174-1	2024-02-14	Coliform	Space #10	Bacteriological Monitoring-2
	STK2438633-1	2024-06-12	Coliform	Space #10	Bacteriological Monitoring-2
	STK2455713-1	2024-10-22	Coliform	Space #10	Bacteriological Monitoring-2
Bacti-Rout-ss03	STK2433709-1	2024-03-19	Coliform	Space #18	Bacteriological Monitoring-3
	STK2450343-1	2024-07-16	Coliform	Space #18	Bacteriological Monitoring-3
	STK2457339-1	2024-11-22	Coliform	Space #18	Bacteriological Monitoring-3
Bacti-Rout-ss01	STK2430684-1	2024-01-15	Coliform	Space #32	Bacteriological Monitoring-1
	STK2437291-1	2024-05-22	Coliform	Space #32	Bacteriological Monitoring-1
	STK2453710-1	2024-09-13	Coliform	Space #32	Bacteriological Monitoring-1
Bacti-Rout-ss04	STK2434958-1	2024-04-11	Coliform	Space #38	Bacteriological Monitoring-4
	STK2452494-1	2024-08-22	Coliform	Space #38	Bacteriological Monitoring-4
	STK2458112-1	2024-12-11	Coliform	Space #38	Bacteriological Monitoring-4
WELL 02-West	STK1654977-1	2016-12-08	Radio Chemistry	WEST #02	Well #02 - Radio Monitoring
	STK2236127-1	2022-05-05	General Mineral	WEST #02	Well #02 - Water Monitoring
	STK2236127-1	2022-05-05	Metals, Total	WEST #02	Well #02 - Water Monitoring
	STK2236127-1	2022-05-05	Wet Chemistry	WEST #02	Well #02 - Water Monitoring
	STK2332177-1	2023-02-17	Wet Chemistry	WEST #02	Well #02 - Water Monitoring
	STK2334215-2	2023-04-06	Field Test	WEST #02	LAZY B MOBILEHOME PARK
	STK2336394-1	2023-05-19	Wet Chemistry	WEST #02	Well #02 - Water Monitoring
	STK2351382-1	2023-08-21	Wet Chemistry	WEST #02	Well #02 - Water Monitoring
	STK2355863-1	2023-11-16	Wet Chemistry	WEST #02	Well #02 - Water Monitoring
	STK2356123-1	2023-11-20	Wet Chemistry	WEST #02	LAZY B MOBILEHOME PARK
	STK2432175-1	2024-02-14	Wet Chemistry	West #02	Well #02 - Water Monitoring
	STK2433708-3	2024-03-19		WEST #02	PFAS Monitoring
	STK2437356-1	2024-05-22	Wet Chemistry	West #02	Well #02 - Water Monitoring
	STK2437289-3	2024-05-22		WEST #02	PFAS Monitoring
	STK2452493-1	2024-08-22	Wet Chemistry	West #02	Well #02 - Water Monitoring
	STK2452492-3	2024-08-22		WEST #02	PFAS Monitoring
	STK2457338-1	2024-11-22	Wet Chemistry	West #02	Well #02 - Water Monitoring
	STK2458111-3	2024-12-11		WEST #02	PFAS Monitoring