

## APPENDIX B: eCCR Certification Form (Suggested Format)

### Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	<b>Martin's Mobile Home Court – New West Well</b>
Water System Number:	<b>CA5000061</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 05/12/23 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: <u>DAVID COUNTS</u>	Title: <u>OWNER</u>
Signature: <u>[Handwritten Signature]</u>	Date: <u>05/12/23</u>
Phone number: <u>(925) 827-1176</u>	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used). **Hand Delivered**
- CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - Posting the CCR at the following URL: www.\_\_\_\_\_
  - Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - Advertising the availability of the CCR in news media (attach copy of press release)
  - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - Posted the CCR in public places (attach a list of locations)

- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- Other (attach a list of other methods used)
- For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: [www.\\_\\_\\_\\_\\_](http://www._____)
- For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

## 2022 Consumer Confidence Report

Water System Name:	<b>Martin's Mobile Home Court</b>	Report Date:	02/18/23
--------------------	-----------------------------------	--------------	----------

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua para beber.  
Favor de comunicarse Martin's Mobile Home Court a (209) 862-2495 para asistirlo en español.**

Type of water source(s) in use:	Groundwater Well		
Name & general location of source(s):	New West Well at 26648 River Rd. Newman, CA		
Drinking Water Source Assessment information:	Completed in June of 2002 - see last page		
Time and place of regularly scheduled board meetings for public participation:	None		
For more information, contact:	Doris Martin	Phone:	(209) 862-2495

### TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

#### Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

\*Any violation of an MCL, MRDL, AL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
E. Coli	0	0	(a)	0	

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (and reporting units)	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	08/17/20	5	< 5	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	08/17/20	5	0.2	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	06/27/22	890		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	06/27/22	1900		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate as Nitrogen (ppm)	2022	5	5 - 5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Mercury (ppb)	06/27/22	0.4		2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland
Selenium (ppb)	06/27/22	18		50	30	Discharge from petroleum, glass and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Fluoride (ppm)	06/27/22	0.5		2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Chromium (ppb)	06/27/22	12		50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Gross Alpha (pCi/l)	2022	30*	20* - 40*	15	0	Erosion of natural deposits
Uranium (pCi/l)	2022	40*	31* - 53*	20	0.4	Erosion of natural deposits

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	06/27/22	5100*		1000	N/A	Runoff/leaching from natural deposits
Specific Conductance (umho/cm)	06/27/22	6500*		1600	N/A	Substances that form ions when in water; seawater influence
Chloride (ppm)	06/27/22	1100*		500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	06/27/22	2000*		500	N/A	Runoff/leaching from natural deposits' industrial wastes
Color (unit)	06/27/22	5		15	N/A	Naturally-occurring organic materials
Turbidity (NTU)	06/27/22	0.3		5	N/A	Soil runoff

\*Any violation of an MCL, MRDL, AL, or TT is asterisked. Additional information regarding the violation is provided on the next page.

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Martin's Mobile Home Court is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

### **Summary Information for Violation of an MCL, MRDL, AL, TT, or Monitoring and Reporting Requirements**

Radionuclides (gross alpha and uranium) have been detected in the drinking water in 2022 above the maximum allowable limit (MCL). State regulations base compliance with the MCL on the average of four calendar quarters of samples, taken over one year. Additional monitoring has been required. Radionuclide contaminants such as gross alpha and uranium may occur naturally in the environment. Therefore, their presence may be related to natural occurrences in the environment. However, medical, veterinary offices and military installations, are potential sources for radionuclide contamination related to the activities of man. Some people who drink water containing gross alpha and uranium in excess of the MCL over many years may have an increased risk of getting cancer.

Specific conductance, total dissolved solids, chloride, and sulfate have been detected in the drinking water in 2022 above the allowable limits. The State has established the maximum allowable limits for specific conductance, total dissolved solids, chloride, and sulfate as secondary limits, not as primary limits. These secondary MCLs are set to protect you from unpleasant aesthetic affects such as color, taste, odor, and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. A violation of these MCLs do not pose a risk to public health.

In response, Martin's Mobile Home Court is currently working with the County to be granted a waiver so that the park can continue supplying drinking water.

### **Vulnerability Assessment Summary**

A source water assessment was conducted for the new west well of the Martin's Mobile Home Court water system in June of 2002. The source is considered most vulnerable to the following activities not associated with any detected contaminants: septic systems - high density.

Radionuclides have been detected in this water source but the levels of detection have not exceeded or met the maximum contaminant limit (MCL) in the monitoring history for this source. Radionuclide contaminants such as beta particles and photon emitters, gross alpha particle activity, radium 226 and Radium 228, occur naturally in the environment. Therefore their presence may be related to natural occurrences in the environment. However; medical, veterinary offices, and military installations are potential sources for radionuclide contamination related to the activities of man. For more information regarding the assessment summary, contact: Doris Martin at Martin's Mobile Home Court.

## Consumer Confidence Report Packet Guidelines:

Enclosed is your new Consumer Confidence Report (CCR) and a special certification form.

Check over your CCR. Any spelling or other changes need to be corrected before submission and distribution.

If you have received notice from your State/County regulator of any significant deficiencies, uncorrected deficiencies, tier III annual posting notices, or monitoring failures/violations during the past year, please forward them to us. We need to include them in the CCR. Do not submit or distribute the CCR until these additions are made.

If corrections to your CCR need to be made, call Far West Laboratories. We will make the necessary changes and re-send you a corrected copy.

When you are satisfied with the contents of your CCR, fill out the certification form, and send it, along with a copy of your CCR to your State/County regulator.

**It is highly advisable to first send the finished CCR, by itself to your State regulator, for them to preview, and identify any problems that they see – they are the most familiar with your water system, and can spot and deficiencies or corrections that were otherwise missed.**

Retain the original CCR for your records and for making additional copies as needed to distribute to your customers.

The deadline for distributing the CCR is July 1<sup>st</sup>.

If you have any questions, please contact us.

Thank you;

Far West Laboratories, Inc.

(209) 869-9260