

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	OASIS INVESTMENTS
Water System Number:	CA5000263

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2024 Consumer Confidence Report

Water System Name: OASIS INVESTMENTS Report Date: June 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: This info is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 1 source(s): NEW 2006

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service.

TERMS USED IN THIS REPORT	
Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).	Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.	Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.	ND: not detectable at testing limit
	mg/L: milligrams per liter or parts per million (ppm)
	ug/L: micrograms per liter or parts per billion (ppb)
	pCi/L: picocuries per liter (a measure of radiation)
	NTU: Nephelometric Turbidity Units
	umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2024)	31	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2024)	111	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2024)	5	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2024)	0.16	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate as N (mg/L)	(2024)	2.2	ND - 4.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2023)	1.06	n/a	15	(0)	Erosion of natural deposits.
Dibromochloropropane (DBCP) (ng/L)	(2023)	90	n/a	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit

Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2024)	24	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2024)	429	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2024)	29.4	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2024)	330	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2024)	0.1	n/a	5	n/a	Soil runoff

Table 4 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2024)	0.1	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2024)	41	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 5 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2024)	28	n/a	n/a	n/a
Magnesium (mg/L)	(2024)	10	n/a	n/a	n/a
pH (units)	(2024)	7.9	n/a	n/a	n/a
Alkalinity (mg/L)	(2024)	140	n/a	n/a	n/a
Aggressiveness Index	(2024)	11.9	n/a	n/a	n/a
Langelier Index	(2024)	0.05	n/a	n/a	n/a

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Total (mg/L)	(2018)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Quality Service OASIS APT* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2024 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment (DWSAP) has not been completed for the NEW 2006 WELL of the OASIS INVESTMENTS water system.

NEW 2006 - does not have a completed DWSAP on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Quality Service OASIS APT

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Total Coliform Bacteria			0	5%	n/a			ND -
HB in Breezeway @ Empire	STK2456840-1					2024-11-13	Absent	
HB in Breezeway @ Empire	STK2439694-1					2024-07-03	Absent	
HB in Breezeway @ Empire	STK2433337-1					2024-03-08	Absent	
N. Side HB Apartments 25-28	STK2457601-1					2024-12-03	Absent	
N. Side HB Apartments 25-28	STK2451721-1					2024-08-09	Absent	
N. Side HB Apartments 25-28	STK2434735-1					2024-04-05	Absent	
S. Side HB Apartments 1-14	STK2453708-1					2024-09-13	Absent	
S. Side HB Apartments 1-14	STK2436399-1					2024-05-08	Absent	
S. Side HB Apartments 1-14	STK2430556-1					2024-01-11	Absent	
S. Side HB Apartments 15-24	STK2455129-1					2024-10-10	Absent	
S. Side HB Apartments 15-24	STK2438629-1					2024-06-12	Absent	
S. Side HB Apartments 15-24	STK2432345-1					2024-02-15	Absent	
Fecal coliform and E. coli			0	n/a				ND -
HB in Breezeway @ Empire	STK2456840-1					2024-11-13	Absent	
HB in Breezeway @ Empire	STK2439694-1					2024-07-03	Absent	
HB in Breezeway @ Empire	STK2433337-1					2024-03-08	Absent	
N. Side HB Apartments 25-28	STK2457601-1					2024-12-03	Absent	
N. Side HB Apartments 25-28	STK2451721-1					2024-08-09	Absent	
N. Side HB Apartments 25-28	STK2434735-1					2024-04-05	Absent	
S. Side HB Apartments 1-14	STK2453708-1					2024-09-13	Absent	
S. Side HB Apartments 1-14	STK2436399-1					2024-05-08	Absent	
S. Side HB Apartments 1-14	STK2430556-1					2024-01-11	Absent	
S. Side HB Apartments 15-24	STK2455129-1					2024-10-10	Absent	
S. Side HB Apartments 15-24	STK2438629-1					2024-06-12	Absent	
S. Side HB Apartments 15-24	STK2432345-1					2024-02-15	Absent	

SAMPLING RESULTS FOR SODIUM AND HARDNESS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Sodium		mg/L		none	none			31 31 - 31
NEW 2006	STK2453709-1	mg/L				2024-09-13	31	
Hardness		mg/L		none	none			111 111 - 111
NEW 2006	STK2453709-1	mg/L				2024-09-13	111	

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Arsenic		ug/L		10	0.004			5 5 - 5
NEW 2006	STK2453709-1	ug/L				2024-09-13	5	
Barium		mg/L	2	1	2			0.16 0.16 - 0.16
NEW 2006	STK2453709-1	mg/L				2024-09-13	0.16	
Nitrate as N		mg/L		10	10			2.2 ND - 4.4
NEW 2006	STK2455130-1	mg/L				2024-10-10	4.4	
NEW 2006	STK2453709-1	mg/L				2024-09-13	ND	
Gross Alpha		pCi/L		15	(0)			1.06 1.06 - 1.06
NEW 2006	STK2357013-1	pCi/L				2023-12-13	1.06	
Dibromochloropropane (DBCP)		ng/L		200	1.7			90 90 - 90
NEW 2006	STK2353702-1	ng/L				2023-10-05	90	

SECONDARY DRINKING WATER STANDARDS (SDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Chloride		mg/L		500	n/a			24 24 - 24

Quality Service OASIS APT

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
HB BREEZEWAY	STK2433337-1	2024-03-08	Coliform	HB in Breezeway @ Empire	Monthly Bacteriological-3
	STK2439694-1	2024-07-03	Coliform	HB in Breezeway @ Empire	Monthly Bacteriological-3
	STK2456840-1	2024-11-13	Coliform	HB in Breezeway @ Empire	Monthly Bacteriological-3
N.HB APTS 25-28	STK2434735-1	2024-04-05	Coliform	N. Side HB Apartments 25-28	Monthly Bacteriological-4
	STK2451721-1	2024-08-09	Coliform	N. Side HB Apartments 25-28	Monthly Bacteriological-4
	STK2457601-1	2024-12-03	Coliform	N. Side HB Apartments 25-28	Monthly Bacteriological-4
WELLNEW-2006	STK1854691-4	2018-10-08	Field Test	NEW 2006	OASIS INVESTMENTS
	STK2353702-1	2023-10-05	EPA 504.1	NEW 2006	SOC Monitoring Well 2
	STK2357013-1	2023-12-13	Radio Chemistry	NEW 2006	Radio Monitoring Well 2
	STK2453709-1	2024-09-13	Metals, Total	NEW 2006	Water Quality Monitoring Well 2
	STK2453709-1	2024-09-13	Wet Chemistry	NEW 2006	Water Quality Monitoring Well 2
	STK2453709-1	2024-09-13	General Mineral	NEW 2006	Water Quality Monitoring Well 2
	STK2455130-1	2024-10-10	Wet Chemistry	NEW 2006	Water Quality Monitoring Well 2
S.HB APTS.1-14	STK2430556-1	2024-01-11	Coliform	S. Side HB Apartments 1-14	Monthly Bacteriological-1
	STK2436399-1	2024-05-08	Coliform	S. Side HB Apartments 1-14	Monthly Bacteriological-1
	STK2453708-1	2024-09-13	Coliform	S. Side HB Apartments 1-14	Monthly Bacteriological-1
S.HB APTS.15-24	STK2432345-1	2024-02-15	Coliform	S. Side HB Apartments 15-24	Monthly Bacteriological-2
	STK2438629-1	2024-06-12	Coliform	S. Side HB Apartments 15-24	Monthly Bacteriological-2
	STK2455129-1	2024-10-10	Coliform	S. Side HB Apartments 15-24	Monthly Bacteriological-2