


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>BRONCO WINERY</b>
Water System Number:	<b>5000286</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on MAY 12, 2021 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<b>PAUL D. HUCKABA</b>	
	Signature:		
	Title:	<b>MANAGER OF ENVIRONMENTAL AFFAIRS</b>	
	Phone Number:	<b>(209) 272-3201</b>	Date: <b>MAY 12, 2021</b>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
\_\_\_\_\_

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at http:// \_\_\_\_\_
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// \_\_\_\_\_

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# **CCR POSTING LOCATIONS**

## **BRONCO WINE COMPANY (CERES) - 5000286**

Timeclock Bulletin Board in Winery Building

Downstairs Bulletin Board in Winery Building

HR Postings Bulletin Board

Compliance Office Trailer near sink

Maintenance Shop Break Room Bulletin Board

Classic Wines of California Offices Break Room

IT Break Room Bulletin Board

Purchasing Break Room Bulletin Board

House – Bulletin Board in Break room (Kitchen)

Warehouse Office Break Room Bulletin Board

Bivio Warehouse Break Room Bulletin Board

Note: The Potable Water system does not supply the “Grower Relations” building, so no notice is necessary in that building.

# 2020 Consumer Confidence Report

Water System Name: BRONCO WINERY

Report Date: \_\_\_\_\_

April 2021

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

## Type of water source(s) in use:

**Your water comes from 1 source(s):** Well 2

**and from 2 treated location(s):** Treatment GAC and Treatment RO

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209)272-3201 and ask for Paul Huckaba.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2018)	5	0.48	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2018)	81	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2018)	170	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Arsenic (ug/L)	(2020)	11	9 - 12	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2018)	0.16	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate as N (mg/L)	(2020)	4	3.3 - 5.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2018)	3.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2020)	6.52	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2020)	7.37	n/a	20	0.43	Erosion of natural deposits
Dibromochloropropane (DBCP) (ppt)	(2020)	13	ND - 22	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2020)	0.005	n/a	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Arsenic (ug/L)	(2020)	ND	ND - 2.0	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2018)	0.16	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate as N (mg/L)	(2020)	ND	ND - 0.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2018)	3.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate (ug/L)	(2019)	ND	n/a	6	1	Perchlorate is an inorganic chemical in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.
Dibromochloropropane (DBCP) (ppt)	(2020)	ND	ND - 43	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit

<b>Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Chloride (mg/L)	(2018)	120	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2018)	1	n/a	15	n/a	Naturally-occurring organic materials
Manganese (ug/L)	(2018)	40	n/a	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2018)	711	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2018)	17	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2018)	440	n/a	1000	n/a	Runoff/leaching from natural deposits

<b>Table 6 - DETECTION OF UNREGULATED CONTAMINANTS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>
Manganese (ug/L)	(2018)	40	n/a	n/a	n/a

<b>Table 7 - ADDITIONAL DETECTIONS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>
Calcium (mg/L)	(2018)	46	n/a	n/a	n/a
Magnesium (mg/L)	(2018)	13	n/a	n/a	n/a
pH (units)	(2018)	8.02	n/a	n/a	n/a
Alkalinity (mg/L)	(2018)	150	n/a	n/a	n/a

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Bronco Winery* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic	Untreated sample		Reverse Osmosis treatment used to decrease the Arsenic concentration below the legal level.	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
1,2,3-Trichloropropane (1,2,3-TCP)	Untreated sample		Granular Activated Carbon treatment used to decrease the 1,2,3-Trichloropropane (1,2,3-TCP) concentration below the legal level.	Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

**About your Arsenic:** The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## 2020 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

A Drinking Water Source Assessment has not been completed for the WELL 2 of the BRONCO WINERY water system

### Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

### Acquiring Information

For more info you may visit [https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/DWSAP.html](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html) or contact the health department in the county to which the water system belongs as indicated on this following link: [https://www.waterboards.ca.gov/drinking\\_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf](https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf)

# Bronco Winery

## Analytical Results - 2020

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.48	5
Analytical Lab Sink	STK2057792-9	mg/L				2018-07-19	0.41		
House Kitchen Sink	STK2057792-1	mg/L				2018-07-11	ND		
Maint. Break Room Sink	STK2057792-3	mg/L				2018-07-13	0.25		
Warehouse Sink*	STK2057792-5	mg/L				2018-07-15	0.19		
Winery Blending Station Sink	STK2057792-7	mg/L				2018-07-17	0.55		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			81	81 - 81
Well 2	STK2057792-11	mg/L				2018-10-02	81		
<b>Hardness</b>		mg/L		none	none			170	170 - 170
Well 2	STK2057792-11	mg/L				2018-10-02	170		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			11	9 - 12
Well 2	STK2057792-52	ug/L				2020-10-06	9		
Well 2	STK2057792-34	ug/L				2020-07-08	11		
Well 2	STK2057792-25	ug/L				2020-04-07	12		
Well 2	STK2057792-16	ug/L				2020-01-08	12		
<b>Barium</b>		mg/L	2	1	2			0.16	0.16 - 0.16
Well #2 - Well Head	STK2057792-11	mg/L				2018-10-02	0.16		
<b>Nitrate as N</b>		mg/L		10	10			4.0	3.3 - 5.3
Well 2	STK2057792-53	mg/L				2020-10-06	5.3		
Well 2	STK2057792-35	mg/L				2020-07-08	3.7		
Well 2	STK2057792-26	mg/L				2020-04-07	3.3		
Well 2	STK2057792-18	mg/L				2020-01-08	3.7		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			3.5	3.5 - 3.5
Well #2 - Well Head	STK2057792-11	mg/L				2018-10-02	3.5		
<b>Gross Alpha</b>		pCi/L		15	(0)			6.52	6.52 - 6.52
Well 2	STK2057792-17	pCi/L				2020-01-08	6.52		
<b>Uranium</b>		pCi/L		20	0.43			7.37	7.37 - 7.37
Well 2	STK2057792-17	pCi/L				2020-01-08	7.37		
<b>Dibromochloropropane (DBCP)</b>		ppt		200	1.7			13	ND - 22
Well 2	STK2057792-53	ppt				2020-10-06	22		
Well 2	STK2057792-35	ppt				2020-07-08	ND		
Well 2	STK2057792-26	ppt				2020-04-07	11		
Well 2	STK2057792-18	ppt				2020-01-08	17		
<b>1,2,3-Trichloropropane (1,2,3-TCP)</b>		ug/L		0.005	0.0007			0.005	0.0054 - 0.0054
Well 2	STK2057792-27	ug/L				2020-04-08	0.0054		

### TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			ND	ND - 2.0
Treatment RO	STK2057792-57	ug/L				2020-12-08	2.0		
Treatment RO	STK2057792-55	ug/L				2020-11-03	ND		
Treatment RO	STK2057792-51	ug/L				2020-10-06	ND		
Treatment RO	STK2057792-49	ug/L				2020-09-02	2.0		

Treatment RO	STK2057792-37	ug/L				2020-08-05	ND		
Treatment RO	STK2057792-33	ug/L				2020-07-08	ND		
Treatment RO	STK2057792-31	ug/L				2020-06-02	ND		
Treatment RO	STK2057792-29	ug/L				2020-05-05	ND		
Treatment RO	STK2057792-24	ug/L				2020-04-07	ND		
Treatment RO	STK2057792-15	ug/L				2020-01-08	ND		
<b>Barium</b>		mg/L	2	1	2			0.16	0.16 - 0.16
Well #2 - Well Head	STK2057792-11	mg/L				2018-10-02	0.16		
<b>Nitrate as N</b>		mg/L		10	10			ND	ND - 0.65
Treatment RO	STK2057792-57	mg/L				2020-12-08	0.47		
Treatment RO	STK2057792-55	mg/L				2020-11-03	0.63		
Treatment RO	STK2057792-51	mg/L				2020-10-06	0.52		
Treatment RO	STK2057792-49	mg/L				2020-09-02	0.50		
Treatment RO	STK2057792-37	mg/L				2020-08-05	0.60		
Treatment RO	STK2057792-33	mg/L				2020-07-08	0.65		
Treatment RO	STK2057792-31	mg/L				2020-06-02	ND		
Treatment RO	STK2057792-29	mg/L				2020-05-05	0.49		
Treatment RO	STK2057792-24	mg/L				2020-04-07	0.45		
Treatment RO	STK2057792-22	mg/L				2020-03-10	0.44		
Treatment RO	STK2057792-20	mg/L				2020-02-11	ND		
Treatment RO	STK2057792-15	mg/L				2020-01-08	ND		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			3.5	3.5 - 3.5
Well #2 - Well Head	STK2057792-11	mg/L				2018-10-02	3.5		
<b>Perchlorate</b>		ug/L		6	1			ND	ND - ND
Treatment GAC	STK2057792-13	ug/L				2019-07-09	ND		
<b>Dibromochloropropane (DBCP)</b>		ppt		200	1.7			ND	ND - 43
Treatment GAC	STK2057792-56	ppt				2020-12-08	ND		
Treatment GAC	STK2057792-54	ppt				2020-11-03	ND		
Treatment GAC	STK2057792-50	ppt				2020-10-06	13		
Treatment GAC	STK2057792-48	ppt				2020-09-02	ND		
Treatment GAC	STK2057792-36	ppt				2020-08-05	43		
Treatment GAC	STK2057792-32	ppt				2020-07-08	ND		
Treatment GAC	STK2057792-30	ppt				2020-06-02	ND		
Treatment GAC	STK2057792-28	ppt				2020-05-05	ND		
Treatment GAC	STK2057792-23	ppt				2020-04-07	ND		
Treatment GAC	STK2057792-21	ppt				2020-03-10	ND		
Treatment GAC	STK2057792-14	ppt				2020-01-08	ND		

**SECONDARY DRINKING WATER STANDARDS (SDWS)**

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>	mg/L		500	n/a			120	120 - 120
Well 2	STK2057792-11	mg/L			2018-10-02	120		
<b>Color</b>	Units		15	n/a			1.0	1.0 - 1.0
Well 2	STK2057792-11	Units			2018-10-02	1.0		
<b>Manganese</b>	ug/L		50	n/a			40	40 - 40
Well 2	STK2057792-11	ug/L			2018-10-02	40		
<b>Specific Conductance</b>	umhos/cm		1600	n/a			711	711 - 711
Well 2	STK2057792-11	umhos/cm			2018-10-02	711		
<b>Sulfate</b>	mg/L		500	n/a			17	17 - 17
Well 2	STK2057792-11	mg/L			2018-10-02	17		
<b>Total Dissolved Solids</b>	mg/L		1000	n/a			440	440 - 440
Well 2	STK2057792-11	mg/L			2018-10-02	440		

**UNREGULATED CONTAMINANTS**

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Manganese</b>	ug/L		NS	n/a			40	40 - 40
Well 2	STK2057792-11	ug/L			2018-10-02	40		

**ADDITIONAL DETECTIONS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			46	46 - 46
Well 2	STK2057792-11	mg/L				2018-10-02	46		
<b>Magnesium</b>		mg/L			n/a			13	13 - 13
Well 2	STK2057792-11	mg/L				2018-10-02	13		
<b>pH</b>		units			n/a			8.02	8.02 - 8.02
Well 2	STK2057792-11	units				2018-10-02	8.02		
<b>Alkalinity</b>		mg/L			n/a			150	150 - 150
Well 2	STK2057792-11	mg/L				2018-10-02	150		