

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

Water for the Yuba Apartment Homes water system originates from one groundwater source known as new Well #1.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is technologically and economically feasible.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the Federal Environmental Protection Agency (USEPA).

pCi/L: picocuries per liter (a measure of radiation)

ppm: parts per million or milligrams per liter

TDS: Total Dissolved Solids

Testing for bacteriological Contaminants in the distribution system is required by State regulations. This testing is done regularly to verify that the water system is free from coliform bacteria. The minimum number of tests required per month is one. In our distribution system we test the water once per month for coliform bacteria. The highest number of samples found to contain coliform bacteria during any one month was zero.

At present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials, components associated with service lines and home plumbing. **Yuba Apartment Homes** is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize exposure by flushing your tap for 30 seconds to 2 minutes before using for drinking or cooking. If you are concerned about lead you may wish to have your water tested. More info on lead in drinking water can be found at <http://www.epa.gov/safewater/lead>. The table below summarizes the most recent sampling for lead and copper.

The following table gives a list of all detected chemicals in our water during the most recent sampling. Please note that not all sampling is required annually so in some cases our results are more than one year old. These values are expressed in ppm unless otherwise stated.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

Contaminants that may be present in source water include:

- In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

While your drinking water meets the current standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The California Department of Health Services continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and other circulatory problems.

A source water assessment has been completed for the well serving the Yuba Apartments in August 2002. The source is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems, storm and agricultural drainage from adjacent properties

VIOLATION INFORMATION: YUBA APARTMENT HOMES IS REQUIRED TO COLLECT FIVE LEAD AND COPPER SAMPLES EVERY THREE YEARS AND FAILED TO COLLECT LEAD AND COPPER SAMPLES IN 2024.