


Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	ABBEY OF NEW CLAIRVAUX
Water System Number:	5200559

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 04-28-2021 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	CARLOS GALVIS	
	Signature:		
	Title:	GENERAL MANAGER	
	Phone Number:	(530) 839-2161	Date: 04-28-2021

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

POSTED ON BILLBOARD, EMAILED TO WATER USERS AT THE MONASTERY

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2020 Consumer Confidence Report

Water System Name: ABBEY OF NEW CLAIRVAUX

Report Date: April 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): East Well

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are not held.

For more information about this report, or any questions relating to your drinking water, please call (530)839-2161 and ask for Carlos Galvis.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG Typical Sources of Contaminant
Copper (mg/L)	(2018)	5	0.14	0	1.3	.3 Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2018)	10	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2018)	86.8	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2018)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Hexavalent Chromium (ug/L)	(2014)	2.8	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2020)	0.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2018)	4	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2018)	226	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2018)	2.5	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2018)	160	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2018)	0.7	n/a	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2018)	0.1	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (mg/L)	(2018)	0.015	n/a	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2018)	15	n/a	n/a	n/a
Magnesium (mg/L)	(2018)	12	n/a	n/a	n/a
pH (units)	(2018)	7.3	n/a	n/a	n/a
Alkalinity (mg/L)	(2018)	100	n/a	n/a	n/a
Aggressiveness Index	(2018)	10.9	n/a	n/a	n/a
Langelier Index	(2018)	-0.9	n/a	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-

4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Abbey of New Clairvaux* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2020 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment was conducted for the EAST WELL of the ABBEY OF NEW CLAIRVAUX water system in March, 2002.

East Well - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Pesticide/fertilizer/petroleum storage & transfer areas
- Sewer collection systems
- Wells - Agricultural/ Irrigation

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

The two wells are considered to be most vulnerable to contamination from pesticide/fertilizer/petroleum storage & transfer areas, sewer collection systems, and agricultural/irrigation wells in the general vicinity of the wells.

Acquiring Information

A copy of the complete assessment may be viewed at:
Tehama County Environmental Health Dept.
633 Washington Street, Room 36
Red Bluff, CA 96080

You may request a summary of the assessment be sent to you by contacting:
Tia Branton
tbranton@co.tehama.ca.us
(530)527-8020

Abbey of New Clairvaux

Analytical Results By FGL - 2020

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.14	5
Guest Kitchen	CH 1874021-2	mg/L				2018-06-10	ND		
Kitchen Cloister	CH 1874021-3	mg/L				2018-06-10	ND		
Private Room	CH 1874021-5	mg/L				2018-06-10	0.13		
Processed Wash Room	CH 1874021-4	mg/L				2018-06-10	0.15		
Winery Building	CH 1874021-1	mg/L				2018-06-10	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			10	10 - 10
East Well	CH 1871153-1	mg/L				2018-03-06	10		
Hardness		mg/L		none	none			86.8	86.8 - 86.8
East Well	CH 1871153-1	mg/L				2018-03-06	86.8		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
East Well	CH 1871151-1	ug/L				2018-03-06	2		
Hexavalent Chromium		ug/L			0.02			2.8	2.8 - 2.8
East Well	CH 1478962-1	ug/L				2014-12-08	2.8		
Nitrate as N		mg/L		10	10			0.5	0.5 - 0.5
East Well	CH 2071181-1	mg/L				2020-03-02	0.5		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			4	4 - 4
East Well	CH 1871153-1	mg/L				2018-03-06	4		
Specific Conductance		umhos/cm		1600	n/a			226	226 - 226
East Well	CH 1871153-1	umhos/cm				2018-03-06	226		
Sulfate		mg/L		500	n/a			2.5	2.5 - 2.5
East Well	CH 1871153-1	mg/L				2018-03-06	2.5		
Total Dissolved Solids		mg/L		1000	n/a			160	160 - 160
East Well	CH 1871153-1	mg/L				2018-03-06	160		
Turbidity		NTU		5	n/a			0.7	0.7 - 0.7
East Well	CH 1871149-1	NTU				2018-03-06	0.7		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.1	0.1 - 0.1
East Well	CH 1871153-1	mg/L				2018-03-06	0.1		
Vanadium		mg/L		NS	n/a			0.015	0.015 - 0.015
East Well	CH 1871151-1	mg/L				2018-03-06	0.015		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			15	15 - 15
East Well	CH 1871153-1	mg/L				2018-03-06	15		

Magnesium		mg/L			n/a			12	12 - 12
East Well	CH 1871153-1	mg/L				2018-03-06	12		
pH		units			n/a			7.3	7.3 - 7.3
East Well	CH 1871153-1	units				2018-03-06	7.3		
Alkalinity		mg/L			n/a			100	100 - 100
East Well	CH 1871153-1	mg/L				2018-03-06	100		
Aggressiveness Index					n/a			10.9	10.9 - 10.9
East Well	CH 1871153-1					2018-03-06	10.9		
Langelier Index					n/a			-0.9	-0.9 - -0.9
East Well	CH 1871153-1					2018-03-06	-0.9		

Abbey of New Clairvaux

CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CLSTR	CH 2071179-1	2020-03-02	Coliform	Cloister	Bacteriological Monitoring-3
	CH 2073479-1	2020-06-01	Coliform	Cloister	Bacteriological Monitoring-3
	CH 2077022-1	2020-09-01	Coliform	Cloister	Bacteriological Monitoring-3
	CH 2078710-1	2020-12-01	Coliform	Cloister	Bacteriological Monitoring-3
EWELL	CH 1478962-1	2014-12-08	Wet Chemistry	East Well	ABBEY OF NEW CLAIRVAUX
	CH 1871153-1	2018-03-06	General Mineral	East Well	Drinking Water Monitoring
	CH 1871151-1	2018-03-06	Metals, Total	East Well	Arsenic Monitoring
	CH 1871149-1	2018-03-06	Wet Chemistry	East Well	General Physical Monitoring
	CH 2071181-1	2020-03-02	Wet Chemistry	East Well	Drinking Water Monitoring
Guest Kitchen	CH 1874021-2	2018-06-10	Metals, Total	Guest Kitchen	Lead & Copper Monitoring
Kitchen Cloiste	CH 1874021-3	2018-06-10	Metals, Total	Kitchen Cloister	Lead & Copper Monitoring
Private Room	CH 1874021-5	2018-06-10	Metals, Total	Private Room	Lead & Copper Monitoring
Processed Wash	CH 1874021-4	2018-06-10	Metals, Total	Processed Wash Room	Lead & Copper Monitoring
SHOP SINK	CH 2070105-1	2020-01-06	Coliform	Shop Sink	Bacteriological Monitoring-1
	CH 2071624-1	2020-04-02	Coliform	Shop Sink	Bacteriological Monitoring-1
	CH 2074987-1	2020-07-01	Coliform	Shop Sink	Bacteriological Monitoring-1
	CH 2078010-1	2020-10-05	Coliform	Shop Sink	Bacteriological Monitoring-1
ST. LUKE DR	CH 2070755-1	2020-02-03	Coliform	St. Luke Dining Room	Bacteriological Monitoring-2
	CH 2072667-1	2020-05-04	Coliform	St. Luke Dining Room	Bacteriological Monitoring-2
	CH 2075858-1	2020-08-03	Coliform	St. Luke Dining Room	Bacteriological Monitoring-2
	CH 2078883-1	2020-11-02	Coliform	St. Luke Dining Room	Bacteriological Monitoring-2
Winery Building	CH 1874021-1	2018-06-10	Metals, Total	Winery Building	Lead & Copper Monitoring