

# Disinfection Process Data

Disinfectant residual type (check one):     Free Chlorine     Combined Chlorine     Other

**Incidents of chlorine residuals less than 0.2 ppm at discharge from Chlorine Contact Tank:**

Date of Incident	NONE		
Duration			
Date Dept. Notified			

Total number of incidents where residual is < 0.2 ppm: 0  
**Meet Standard** (i.e. is not less than 0.2 ppm for more than four hours (Y/N)? YES)

Number of distribution system residual samples collected:	
Number of distribution system samples for HPC only:	
Total number of residual and/or HPC samples collected:	
Number of samples with no detectable residual and HPC is not measured:	
Number of samples with no residual and HPC > 500 CFU/mL:	
Number of samples for HPC only and HPC > 500 CFU/mL:	
Total number of samples with no residual and/or HPC > 500 CFU/mL:	

**Compute V:**

Where  $V = [1 - (\text{Total No. of samples with no residual and/or HPC} > 500) / (\text{Total No. of residual and/or HPC samples collected})] \times 100$

V = \_\_\_\_\_  
**Meets Standard** (i.e.  $V \geq 95\%$ ) (Y/N)? \_\_\_\_\_

## SUMMARY OF WATER QUALITY COMPLAINTS

**General Complaints:**

Type of Complaint	Number	Corrective Actions Taken
Taste/Odor		<del>NONE</del>
Color		
Turbidity		
Suspended Solids		
Other (Describe)		

**Reports of Gastrointestinal Illness (attach additional sheets if necessary):**

Person Reporting	Date	Corrective Actions Taken
		<del>NONE</del>

Attach an explanation of any failure of the performance standards or operating criteria and corrective action taken or planned.

**Signature:**

Linton E. Scott

**Date:**

10/10 APRIL 2024