

2024 Consumer Confidence Report

Water System Name: River Retreat Mutual Water Company

Report Date: March 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Regularly-scheduled water board or city/county council meetings are not currently held

Your water comes from 2 source(s): Well 02 and WELL 02 - RAW

Opportunities for public participation in decisions that affect drinking water quality: RRMWC provides 1 to 2 shareholder meeting per year held in January and again in the summer. Shareholders are mailed an invitation/agenda and sometimes texted as well.

For more information about this report, or any questions relating to your drinking water, please call 559-561-3158 ext 559561 and ask for Alysia Schmidt or email rrmwcbo@gmail.com or visit our website at rrmwc.weebly.com/.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2024)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2024)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2024)	267	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2024)	300	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2024)	0.6	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2024)	4.76	n/a	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2024)	650	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
MBAS (ug/L)	(2024)	166	n/a	500	n/a	Municipal and industrial waste discharges.
Manganese (ug/L)	(2024)	10	n/a	50	n/a	Leaching from natural deposits
Odor Threshold at 60 °C (TON)	(2024)	224	32 - 512	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2024)	2190	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2024)	4	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2024)	1560	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2024)	0.1	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2024)	0.02	n/a	5	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2024)	1.45	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2024)	10	n/a	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 6 - ADDITIONAL DETECTIONS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant	
Calcium (mg/L)	(2024)	112	n/a	n/a	n/a	
Magnesium (mg/L)	(2024)	5	n/a	n/a	n/a	
pH (units)	(2024)	6.3	n/a	n/a	n/a	
Alkalinity (mg/L)	(2024)	90	n/a	n/a	n/a	
Aggressiveness Index	(2024)	10.7	n/a	n/a	n/a	
Langelier Index	(2024)	-1.2	n/a	n/a	n/a	

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2024)	26	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine, Total (mg/L)	(2021)	0.95	.29 - 2.17	4.0	4.0	No	Drinking water disinfectant added for treatment.
Chlorine, Free (mg/L)	(2024)	1.49	0.41 - 4.40	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2024)	4	n/a	60	n/a	No	By-product of drinking water disinfection

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *River Retreat Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.
Chloride				n/a

Odor Threshold at 60 °C				Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Specific Conductance				The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCLs were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.
Total Dissolved Solids				The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.
Chlorine				Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water contains chlorine well in excess of the MRDL could experience stomach discomfort.

2024 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment has not been completed for the WELL 02 of the RIVER RETREAT MUTUAL water system.

Well 02 - does not have a completed assessment on file.

WELL 02 - RAW - does not have a completed assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

River Retreat Mutual Water Co.

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
40972 Oakridge	VI 2446107-4					2024-07-31	<1.0		
40972 Oakridge	VI 2445184-4					2024-06-27	<1.0		
41070 Oakridge	VI 2446107-3					2024-07-31	<1.0		
41070 Oakridge	VI 2445184-3					2024-06-27	<1.0		
41113C Oakridge	VI 2449627-1					2024-12-05	Absent		
41113C Oakridge	VI 2449127-1					2024-11-13	Absent		
41113C Oakridge	VI 2448148-1					2024-10-03	Absent		
41113C Oakridge	VI 2447480-1					2024-09-11	Absent		
41113C Oakridge	VI 2446685-1					2024-08-19	Absent		
41113C Oakridge	VI 2446107-2					2024-07-31	<1.0		
41113C Oakridge	VI 2445938-1					2024-07-24	Absent		
41113C Oakridge	VI 2445184-2					2024-06-27	<1.0		
41113C Oakridge	VI 2444320-1					2024-06-03	Present		
41113C Oakridge	VI 2443479-1					2024-05-01	Absent		
41113C Oakridge	VI 2442864-1					2024-04-10	Absent		
41113C Oakridge	VI 2442331-1					2024-03-25	Absent		
41113C Oakridge	VI 2440914-1					2024-02-05	Absent		
41113C Oakridge	VI 2440081-1					2024-01-03	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
40972 Oakridge	VI 2446107-4					2024-07-31	<1.0		
40972 Oakridge	VI 2445184-4					2024-06-27	<1.0		
41070 Oakridge	VI 2446107-3					2024-07-31	<1.0		
41070 Oakridge	VI 2445184-3					2024-06-27	<1.0		
41113C Oakridge	VI 2449627-1					2024-12-05	Absent		
41113C Oakridge	VI 2449127-1					2024-11-13	Absent		
41113C Oakridge	VI 2448148-1					2024-10-03	Absent		
41113C Oakridge	VI 2447480-1					2024-09-11	Absent		
41113C Oakridge	VI 2446685-1					2024-08-19	Absent		
41113C Oakridge	VI 2446107-2					2024-07-31	<1.0		
41113C Oakridge	VI 2445938-1					2024-07-24	Absent		
41113C Oakridge	VI 2445184-2					2024-06-27	<1.0		
41113C Oakridge	VI 2444320-1					2024-06-03	Absent		
41113C Oakridge	VI 2443479-1					2024-05-01	Absent		
41113C Oakridge	VI 2442864-1					2024-04-10	Absent		
41113C Oakridge	VI 2442331-1					2024-03-25	Absent		
41113C Oakridge	VI 2440914-1					2024-02-05	Absent		
41113C Oakridge	VI 2440081-1					2024-01-03	Absent		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			267	267 - 267
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	267		
Hardness		mg/L		none	none			300	300 - 300
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	300		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.6	0.6 - 0.6
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	0.6		
Gross Alpha		pCi/L		15	(0)			4.76	4.76 - 4.76
WELL 02 - RAW	VI 2447481-1	pCi/L				2024-09-11	4.76		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			650	650 - 650
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	650		
MBAS		ug/L		500	n/a			166	166 - 166
WELL 02 - RAW	VI 2447481-1	ug/L				2024-09-11	166		
Manganese		ug/L		50	n/a			10	10 - 10
WELL 02 - RAW	VI 2447481-1	ug/L				2024-09-11	10		
Odor Threshold at 60 °C		TON		3	n/a			224	32 - 512
WELL 02 - RAW	VI 2449128-1	TON				2024-11-13	256		
WELL 02 - RAW	VI 2447481-1	TON				2024-09-11	256		
WELL 02 - RAW	VI 2446688-1	TON				2024-08-19	32		
WELL 02 - RAW	VI 2443478-1	TON				2024-05-01	512		
WELL 02 - RAW	VI 2440913-1	TON				2024-02-05	64		
Specific Conductance		umhos/cm		1600	n/a			2190	2190 - 2190
WELL 02 - RAW	VI 2447481-1	umhos/cm				2024-09-11	2190		
Sulfate		mg/L		500	n/a			4.0	4.0 - 4.0
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	4.0		
Total Dissolved Solids		mg/L		1000	n/a			1560	1560 - 1560
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	1560		
Turbidity		NTU		5	n/a			0.10	0.10 - 0.10
WELL 02 - RAW	VI 2447481-1	NTU				2024-09-11	0.10		
Zinc		mg/L		5	n/a			0.02	0.02 - 0.02
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	0.02		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			1.45	1.45 - 1.45
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	1.45		
Manganese		ug/L		NS	n/a			10	10 - 10
WELL 02 - RAW	VI 2447481-1	ug/L				2024-09-11	10		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			112	112 - 112
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	112		
Magnesium		mg/L			n/a			5	5 - 5
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	5		
pH		units			n/a			6.3	6.3 - 6.3
WELL 02 - RAW	VI 2447481-1	units				2024-09-11	6.3		
Alkalinity		mg/L			n/a			90	90 - 90
WELL 02 - RAW	VI 2447481-1	mg/L				2024-09-11	90		
Aggressiveness Index					n/a			10.7	10.7 - 10.7
WELL 02 - RAW	VI 2447481-1					2024-09-11	10.7		
Langelier Index					n/a			-1.2	-1.2 - -1.2
WELL 02 - RAW	VI 2447481-1					2024-09-11	-1.2		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			26	26 - 26
ST2S1 - 40972 OAK RIDGE DR	VI 2447479-1	ug/L				2024-09-11	26		
Average ST2S1 - 40972 OAK RIDGE DR								26	
Chlorine		mg/L		4.0	4.0			0.95	.29 - 2.17
41148 Oakridge	VI 2142864-1	mg/L				2021-04-19	2.17		
41148 Oakridge	VI 2141899-1	mg/L				2021-03-11	.29		

River Retreat Mutual Water Co.

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
40972 OAKRDG	VI 2445184-4	2024-06-27	Field Test	40972 Oakridge	Water Monitoring
	VI 2445184-4	2024-06-27	Coliform	40972 Oakridge	Water Monitoring
	VI 2446107-4	2024-07-31	Field Test	40972 Oakridge	Water Monitoring
	VI 2446107-4	2024-07-31	Coliform	40972 Oakridge	Water Monitoring
41070 Oakridge	VI 2445184-3	2024-06-27	Field Test	41070 Oakridge	Water Monitoring
	VI 2445184-3	2024-06-27	Coliform	41070 Oakridge	Water Monitoring
41070 OAKRDG	VI 2446107-3	2024-07-31	Coliform	41070 Oakridge	Water Monitoring
	VI 2446107-3	2024-07-31	Field Test	41070 Oakridge	Water Monitoring
41113C OAKRIDGE	VI 2440081-1	2024-01-03	Coliform	41113C Oakridge	Coliform Monitoring
	VI 2440081-1	2024-01-03	Field Test	41113C Oakridge	Coliform Monitoring
	VI 2440914-1	2024-02-05	Coliform	41113C Oakridge	Water Monitoring
	VI 2440914-1	2024-02-05	Field Test	41113C Oakridge	Water Monitoring
	VI 2442331-1	2024-03-25	Coliform	41113C Oakridge	Water Monitoring
	VI 2442331-1	2024-03-25	Field Test	41113C Oakridge	Water Monitoring
	VI 2442864-1	2024-04-10	Coliform	41113C Oakridge	Water Monitoring
	VI 2442864-1	2024-04-10	Field Test	41113C Oakridge	Water Monitoring
	VI 2443479-1	2024-05-01	Coliform	41113C Oakridge	Water Monitoring
	VI 2443479-1	2024-05-01	Field Test	41113C Oakridge	Water Monitoring
	VI 2444320-1	2024-06-03	Coliform	41113C Oakridge	Water Monitoring
	VI 2444320-1	2024-06-03	Field Test	41113C Oakridge	Water Monitoring
	VI 2445184-2	2024-06-27	Field Test	41113C Oakridge	Water Monitoring
	VI 2445184-2	2024-06-27	Coliform	41113C Oakridge	Water Monitoring
	VI 2445938-1	2024-07-24	Coliform	41113C Oakridge	Water Monitoring
	VI 2445938-1	2024-07-24	Field Test	41113C Oakridge	Water Monitoring
	VI 2446107-2	2024-07-31	Field Test	41113C Oakridge	Water Monitoring
	VI 2446107-2	2024-07-31	Coliform	41113C Oakridge	Water Monitoring
	VI 2446685-1	2024-08-19	Coliform	41113C Oakridge	Water Monitoring
	VI 2446685-1	2024-08-19	Field Test	41113C Oakridge	Water Monitoring
	VI 2447480-1	2024-09-11	Field Test	41113C Oakridge	Water Monitoring
	VI 2447480-1	2024-09-11	Coliform	41113C Oakridge	Water Monitoring
	VI 2448148-1	2024-10-03	Coliform	41113C Oakridge	Water Monitoring
	VI 2448148-1	2024-10-03	Field Test	41113C Oakridge	Water Monitoring
	VI 2449127-1	2024-11-13	Field Test	41113C Oakridge	Water Monitoring
	VI 2449127-1	2024-11-13	Coliform	41113C Oakridge	Water Monitoring
	VI 2449627-1	2024-12-05	Field Test	41113C Oakridge	Water Monitoring
	VI 2449627-1	2024-12-05	Coliform	41113C Oakridge	Water Monitoring
41148 OAKRIDGE	VI 2140129-1	2021-01-07	Field Test	41148 Oakridge	Water Monitoring
	VI 2141061-1	2021-02-11	Field Test	41148 Oakridge	Water Monitoring
	VI 2141899-1	2021-03-11	Field Test	41148 Oakridge	Water Monitoring
	VI 2142864-1	2021-04-19	Field Test	41148 Oakridge	Water Monitoring
ST2S1-DBP	VI 2447479-1	2024-09-11	EPA 551.1	ST2S1 - 40972 OAK RIDGE DR	RIVER RETREAT MUTUAL
	VI 2447479-1	2024-09-11	EPA 552.2	ST2S1 - 40972 OAK RIDGE DR	RIVER RETREAT MUTUAL
WELL 02	VI 2440913-1	2024-02-05	Wet Chemistry	WELL 02 - RAW	Well 02-Odor Monitoring
	VI 2443478-1	2024-05-01	Wet Chemistry	WELL 02 - RAW	Well 02-Odor Monitoring
	VI 2446688-1	2024-08-19	Wet Chemistry	WELL 02 - RAW	Well 02-Odor Monitoring
	VI 2447481-1	2024-09-11	Wet Chemistry	WELL 02 - RAW	Well 2 - Water Quality
	VI 2447481-1	2024-09-11	Radio Chemistry	WELL 02 - RAW	Well 2 - Water Quality
	VI 2447481-1	2024-09-11	General Mineral	WELL 02 - RAW	Well 2 - Water Quality
	VI 2449128-1	2024-11-13	Wet Chemistry	WELL 02 - RAW	Well 02-Odor Monitoring