

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	SO KAWEAH MUTUAL WATER CO
Water System Number:	CA5400754

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	KyleMcIntyre	
	Signature:	<i>Kyle McIntyre</i>	
	Title:	Water Distribution/Treatment Operator	
	Phone Number:	(559) 280-3055	Date: 03/30/2026

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

- "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

- For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2025 Consumer Confidence Report

Water System Name: SO KAWEAH MUTUAL WATER CO

Report Date: March 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): WELL 02

Opportunities for public participation in decisions that affect drinking water quality: Regularly scheduled water board meetings are held at posted locations, dates and times.

For more information about this report, or any questions relating to your drinking water, please call 5592803055 and ask for Kyle McIntyre or email slanginfood@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2023)	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2023)	5	0.03	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022 - 2025)	30	23 - 37	none	none	Salt present in the water and is generally naturally occurring

Hardness (mg/L)	(2022 - 2025)	304	291 - 326	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
-----------------	---------------	-----	-----------	------	------	--

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (mg/L)	(2025)	0.13	ND - 0.26	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (ug/L)	(2023 - 2025)	9	4 - 17	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2025)	ND	ND - 0.10	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ug/L)	(2022 - 2025)	10	ND - 17	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Copper (mg/L)	(2025)	ND	n/a	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (mg/L)	(2022 - 2025)	0.2	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2025)	3.4	2.7 - 4.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022 - 2025)	3.4	2.7 - 4.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2022 - 2025)	2.78	2.01 - 3.22	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2019)	4.67	n/a	20	0.43	Erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022 - 2025)	58	28 - 76	500	n/a	Runoff/leaching from natural deposits; seawater influence
Copper (mg/L)	(2025)	ND	n/a	1.0	1.0	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Iron (ug/L)	(2025)	445	ND - 890	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2025)	6.4	ND - 12.8	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2022 - 2025)	757	640 - 833	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022 - 2025)	30	27.9 - 34.1	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022 - 2025)	480	460 - 510	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2025)	1.05	0.10 - 2.0	5	n/a	Soil runoff
Zinc (mg/L)	(2025)	0.21	0.03 - 0.39	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2022 - 2025)	ND	ND - 0.17	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2022)	23	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
Manganese (ug/L)	(2025)	6.4	ND - 12.8	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022 - 2025)	94	87 - 106	n/a	n/a
Magnesium (mg/L)	(2022 - 2025)	17	15 - 18	n/a	n/a
pH (units)	(2022 - 2025)	6.73	6.6 - 6.89	n/a	n/a
Alkalinity (mg/L)	(2022 - 2025)	267	260 - 280	n/a	n/a
Aggressiveness Index	(2022 - 2025)	11.6	11.5 - 11.7	n/a	n/a
Langelier Index	(2022 - 2025)	-0.3	-0.4 - -0.2	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2023)	10	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine, Free (mg/L)	(2024 - 2025)	0.78	0.31 - 2.20	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *South Kaweah MWC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2025 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 of the SO KAWEAH MUTUAL WATER CO water system in December, 2002.

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Known Contaminant Plumes
 Septic systems - high density [>1/acre]

Discussion of Vulnerability

The activities to which the South Kaweah Mutual Water Company is most vulnerable include a known contamination plume, petroleum and chemical storage, and septic systems and agricultural activity and drainage. This system has detected arsenic at a level (10, 12 and 6 ppb respectively) that exceeds the recently revised federal MCL of 10 ppb. The source of the arsenic is not known, but is likely to be naturally occurring.

It is important that septic systems be kept in good repair and pumped regularly. It is also necessary to keep the well site clean and free of weeds and debris to prevent contamination. The cement surface seal needs to be checked for cracks and immediately repaired or sealed.

Acquiring Information

A copy of the complete assessment may be viewed at:

Environmental Health Services

5957 S Mooney Blvd

Visalia, CA 93277

You may request a summary of the assessment be sent to you by contacting:

Miguel Herrera

REHS II

Environmental Health Services Division

559-624-7413

mherrera@tularehhsa.org

Lead		ug/L	0	15	0.2			0	5
40796 Grouse	VI 2346375-4	ug/L				2023-09-19	ND		
40933 Oakridge	VI 2346375-1	ug/L				2023-09-19	ND		
40934 Cherokee Oaks	VI 2346375-5	ug/L				2023-09-19	ND		
40944 Grouse	VI 2346375-3	ug/L				2023-09-19	ND		
40985 Quail	VI 2346375-2	ug/L				2023-09-19	ND		
Copper		mg/L		1.3	.3			0.03	5
40796 Grouse	VI 2346375-4	mg/L				2023-09-19	ND		
40933 Oakridge	VI 2346375-1	mg/L				2023-09-19	0.06		
40934 Cherokee Oaks	VI 2346375-5	mg/L				2023-09-19	ND		
40944 Grouse	VI 2346375-3	mg/L				2023-09-19	ND		
40985 Quail	VI 2346375-2	mg/L				2023-09-19	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			30	23 - 37
Well 02	VI 2543235-1	mg/L				2025-05-07	23		
WELL 02	VI 2243427-1	mg/L				2022-05-12	31		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	37		
Hardness		mg/L		none	none			304	291 - 326
Well 02	VI 2543235-1	mg/L				2025-05-07	291		
WELL 02	VI 2243427-1	mg/L				2022-05-12	295		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	326		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Aluminum		mg/L		1	0.6			0.13	ND - 0.26
Well 02	VI 2543235-1	mg/L				2025-05-07	ND		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	0.26		
Arsenic		ug/L		10	0.004			9	4 - 17
Well 02	VI 2548242-1	ug/L				2025-11-20	14		
Well 02	VI 2545824-1	ug/L				2025-08-14	9		
Well 02	VI 2543235-1	ug/L				2025-05-07	12		
Well 02	VI 2540919-1	ug/L				2025-02-05	17		
WELL 02	VI 2347468-1	ug/L				2023-11-06	9		
WELL 02	VI 2345071-1	ug/L				2023-08-02	10		
WELL 02	VI 2342884-1	ug/L				2023-05-10	8		
WELL 02	VI 2340926-1	ug/L				2023-02-13	10		
WELL 03 - FIRE SUPRESSION ONLY	VI 2548242-2	ug/L				2025-11-20	4		
WELL 03 - FIRE SUPRESSION ONLY	VI 2545824-2	ug/L				2025-08-14	8		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	ug/L				2025-05-07	6		
WELL 03 - FIRE SUPRESSION ONLY	VI 2540919-2	ug/L				2025-02-05	4		
Barium		mg/L	2	1	2			ND	ND - 0.10
Well 02	VI 2543235-1	mg/L				2025-05-07	ND		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	0.10		
Chromium		ug/L	100	50.0	n/a			10	ND - 17
Well 02	VI 2543235-1	ug/L				2025-05-07	ND		
WELL 02	VI 2243427-1	ug/L				2022-05-12	17		
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	ug/L				2025-05-07	13		
Copper		mg/L		1.3	.3			ND	ND - ND
WELL 03 - FIRE SUPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	ND		

Fluoride		mg/L		2	1			0.2	0.2 - 0.2
Well 02	VI 2543235-1	mg/L				2025-05-07		0.2	
WELL 02	VI 2243427-1	mg/L				2022-05-12		0.2	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		0.2	
Nitrate as N		mg/L		10	10			3.4	2.7 - 4.0
Well 02	VI 2548593-1	mg/L				2025-12-03		2.7	
Well 02	VI 2543235-1	mg/L				2025-05-07		3.4	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		4.0	
Nitrate + Nitrite as N		mg/L		10	10			3.4	2.7 - 4.0
Well 02	VI 2543235-1	mg/L				2025-05-07		3.4	
WELL 02	VI 2243427-1	mg/L				2022-05-12		2.7	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		4.0	
Gross Alpha		pCi/L		15	(0)			2.78	2.01 - 3.22
Well 02	VI 2543235-1	pCi/L				2025-05-07		3.22	
WELL 02	VI 2243427-1	pCi/L				2022-05-12		2.01	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	pCi/L				2025-05-07		3.12	
Uranium		pCi/L		20	0.43			4.67	4.67 - 4.67
WELL 02	VI 1942125-1	pCi/L				2019-05-08		4.67	

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			58	28 - 76
Well 02	VI 2543235-1	mg/L				2025-05-07		28	
WELL 02	VI 2243427-1	mg/L				2022-05-12		76	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		70	
Copper		mg/L		1.0	1.0			ND	ND - ND
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		ND	
Iron		ug/L		300	n/a			445	ND - 890
Well 02	VI 2543235-1	ug/L				2025-05-07		ND	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	ug/L				2025-05-07		890	
Manganese		ug/L		50	n/a			6.4	ND - 12.8
Well 02	VI 2543235-1	ug/L				2025-05-07		ND	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	ug/L				2025-05-07		12.8	
Specific Conductance		umhos/cm		1600	n/a			757	640 - 833
Well 02	VI 2543235-1	umhos/cm				2025-05-07		640	
WELL 02	VI 2243427-1	umhos/cm				2022-05-12		833	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	umhos/cm				2025-05-07		799	
Sulfate		mg/L		500	n/a			30.0	27.9 - 34.1
Well 02	VI 2543235-1	mg/L				2025-05-07		34.1	
WELL 02	VI 2243427-1	mg/L				2022-05-12		27.9	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		28.0	
Total Dissolved Solids		mg/L		1000	n/a			480	460 - 510
Well 02	VI 2543235-1	mg/L				2025-05-07		460	
WELL 02	VI 2243427-1	mg/L				2022-05-12		470	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07		510	
Turbidity		NTU		5	n/a			1.05	0.10 - 2.0
Well 02	VI 2543235-1	NTU				2025-05-07		0.10	
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	NTU				2025-05-07		2.0	
Zinc		mg/L		5	n/a			0.21	0.03 - 0.39
Well 02	VI 2543235-1	mg/L				2025-05-07		0.03	

WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	0.39		
---------------------------------	--------------	------	--	--	--	------------	------	--	--

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			ND	ND - 0.17
Well 02	VI 2543235-1	mg/L				2025-05-07	ND		
WELL 02	VI 2243427-1	mg/L				2022-05-12	0.1		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	0.17		
Vanadium		ug/L		NS	n/a			23	23 - 23
WELL 02	VI 2243427-1	ug/L				2022-05-12	23		
Manganese		ug/L		NS	n/a			6.4	ND - 12.8
Well 02	VI 2543235-1	ug/L				2025-05-07	ND		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	ug/L				2025-05-07	12.8		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			94	87 - 106
Well 02	VI 2543235-1	mg/L				2025-05-07	87		
WELL 02	VI 2243427-1	mg/L				2022-05-12	90		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	106		
Magnesium		mg/L			n/a			17	15 - 18
Well 02	VI 2543235-1	mg/L				2025-05-07	18		
WELL 02	VI 2243427-1	mg/L				2022-05-12	17		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	15		
pH		units			n/a			6.73	6.6 - 6.89
Well 02	VI 2543235-1	units				2025-05-07	6.7		
WELL 02	VI 2243427-1	units				2022-05-12	6.89		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	units				2025-05-07	6.6		
Alkalinity		mg/L			n/a			267	260 - 280
Well 02	VI 2543235-1	mg/L				2025-05-07	260		
WELL 02	VI 2243427-1	mg/L				2022-05-12	260		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2	mg/L				2025-05-07	280		
Aggressiveness Index					n/a			11.6	11.5 - 11.7
Well 02	VI 2543235-1					2025-05-07	11.5		
WELL 02	VI 2243427-1					2022-05-12	11.7		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2					2025-05-07	11.5		
Langelier Index					n/a			-0.3	-0.4 - -0.2
Well 02	VI 2543235-1					2025-05-07	-0.4		
WELL 02	VI 2243427-1					2022-05-12	-0.2		
WELL 03 - FIRE SUPPRESSION ONLY	VI 2543235-2					2025-05-07	-0.4		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			10	10 - 10
ST2S1 - 40709 TERMINUS CT	VI 2346512-1	ug/L				2023-09-27	10		
Average ST2S1 - 40709 TERMINUS CT								10	
Chlorine		mg/L		4.0	4.0			0.78	0.31 - 2.20
125,000 Gal Tank	VI 2541683-5	mg/L				2025-03-06	0.34		
Average 125,000 Gal Tank								0.54	
125,000 gal Tank	VI 2541024-2	mg/L				2025-02-11	0.46		

South Kaweah MWC CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
125,000 Gal Tan	VI 2540081-2	2025-01-06	Field Test	125,000 Gal Tank	Chlorine Monitoring
125,000 gal Tan	VI 2541024-2	2025-02-11	Field Test	125,000 gal Tank	Chlorine Monitoring
125,000 Gal Tan	VI 2541683-5	2025-03-06	Field Test	125,000 Gal Tank	Drinking Water Monitoring
125,000 gal. Ta	VI 2449622-2	2024-12-05	Field Test	125,000 gal. Tank	Chlorine Monitoring
150,000 Gal Tan	VI 2540081-1	2025-01-06	Field Test	150,000 Gal Tank	Chlorine Monitoring
150,000 gal Tan	VI 2541024-1	2025-02-11	Field Test	150,000 gal Tank	Chlorine Monitoring
150,000 Gal Tan	VI 2541683-4	2025-03-06	Field Test	150,000 Gal Tank	Drinking Water Monitoring
40488 Cherokee	VI 2540081-6	2025-01-06	Field Test	40488 Cherokee Oaks	Chlorine Monitoring
	VI 2541683-6	2025-03-06	Field Test	40488 Cherokee Oaks	Drinking Water Monitoring
	VI 2541024-6	2025-02-11	Field Test	40488 Cherokee Oaks Dr	Chlorine Monitoring
40675 Crystal	VI 2540080-1	2025-01-06	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2540080-1	2025-01-06	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2541692-1	2025-03-06	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2541692-1	2025-03-06	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2543237-1	2025-05-07	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2543237-1	2025-05-07	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2544932-1	2025-07-10	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2544932-1	2025-07-10	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2546304-1	2025-09-03	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2546304-1	2025-09-03	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2548241-1	2025-11-20	Coliform	40675 Crystal	Bacteriological Monitoring-Odd
	VI 2548241-1	2025-11-20	Field Test	40675 Crystal	Bacteriological Monitoring-Odd
40709 Terminus	VI 2541022-1	2025-02-11	Field Test	40709 Terminus	Bacti Monitoring - Even
	VI 2541022-1	2025-02-11	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2542381-1	2025-04-03	Field Test	40709 Terminus	Bacti Monitoring - Even
	VI 2542381-1	2025-04-03	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2544289-1	2025-06-19	Field Test	40709 Terminus	Bacti Monitoring - Even
	VI 2544289-1	2025-06-19	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2545816-1	2025-08-14	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2545816-1	2025-08-14	Field Test	40709 Terminus	Bacti Monitoring - Even
	VI 2547114-1	2025-10-02	Field Test	40709 Terminus	Bacti Monitoring - Even
	VI 2547114-1	2025-10-02	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2548595-1	2025-12-03	Coliform	40709 Terminus	Bacti Monitoring - Even
	VI 2548595-1	2025-12-03	Field Test	40709 Terminus	Bacti Monitoring - Even
DST_LCR	VI 2346375-4	2023-09-19	Metals, Total	40796 Grouse	SOUTH KAWEAH MUTUAL WATER COMPANY
	VI 2346375-1	2023-09-19	Metals, Total	40933 Oakridge	SOUTH KAWEAH MUTUAL WATER COMPANY
	VI 2346375-5	2023-09-19	Metals, Total	40934 Cherokee Oaks	SOUTH KAWEAH MUTUAL WATER COMPANY
	VI 2346375-3	2023-09-19	Metals, Total	40944 Grouse	SOUTH KAWEAH MUTUAL WATER COMPANY
40944 Grouse	VI 2540079-1	2025-01-06	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2540079-1	2025-01-06	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2541021-1	2025-02-11	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2541021-1	2025-02-11	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2541693-1	2025-03-06	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2541693-1	2025-03-06	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2542382-1	2025-04-03	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2542382-1	2025-04-03	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2543236-1	2025-05-07	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2543236-1	2025-05-07	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2544288-1	2025-06-19	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2544288-1	2025-06-19	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2544933-1	2025-07-10	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2544933-1	2025-07-10	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2545817-1	2025-08-14	Coliform	40944 Grouse	Coliform Monitoring

	VI 2545817-1	2025-08-14	Field Test	40944 Grouse	Coliform Monitoring
	VI 2546303-1	2025-09-03	Coliform	40944 Grouse	Coliform Monitoring
	VI 2546303-1	2025-09-03	Field Test	40944 Grouse	Coliform Monitoring
	VI 2547113-1	2025-10-02	Coliform	40944 Grouse	Coliform Monitoring
	VI 2547113-1	2025-10-02	Field Test	40944 Grouse	Coliform Monitoring
	VI 2548243-1	2025-11-20	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2548243-1	2025-11-20	Field Test	40944 Grouse	Drinking Water Monitoring
	VI 2548592-1	2025-12-03	Coliform	40944 Grouse	Drinking Water Monitoring
	VI 2548592-1	2025-12-03	Field Test	40944 Grouse	Drinking Water Monitoring
40962 Meadow Dr	VI 2541024-4	2025-02-11	Field Test	40962 Meadow Dr	Chlorine Monitoring
	VI 2541683-1	2025-03-06	Field Test	40962 Meadow Dr	Drinking Water Monitoring
	VI 2540081-4	2025-01-06	Field Test	40962 Meadow Dr.	Chlorine Monitoring
40962 Measow Dr	VI 2449622-5	2024-12-05	Field Test	40962 Measow Dr.	Chlorine Monitoring
40974 Cherdkee	VI 2540081-5	2025-01-06	Field Test	40974 Cherokee Oak	Chlorine Monitoring
40974 Cherokee	VI 2541683-2	2025-03-06	Field Test	40974 Cherokee Oaks	Drinking Water Monitoring
	VI 2541024-5	2025-02-11	Field Test	40974 Cherokee Oaks Dr	Chlorine Monitoring
DST_LCR	VI 2346375-2	2023-09-19	Metals, Total	40985 Quail	SOUTH KAWEAH MUTUAL WATER COMPANY
41056 Grouse Dr	VI 2541683-3	2025-03-06	Field Test	41056 Grouse Dr	Drinking Water Monitoring
	VI 2540081-3	2025-01-06	Field Test	41056 Grouse Dr.	Chlorine Monitoring
	VI 2541024-3	2025-02-11	Field Test	41056 Grouse Dr.	Chlorine Monitoring
DBPR	VI 2346512-1	2023-09-27	EPA 551.1	ST2S1 - 40709 TERMINUS CT	Disinfection Byproducts
STW-2	VI 1942125-1	2019-05-08	Metals, Total	WELL 02	Well 02 - Water Quality
	VI 2243427-1	2022-05-12	Metals, Total	WELL 02	Water Quality Monitoring
	VI 2243427-1	2022-05-12	Radio Chemistry	WELL 02	Water Quality Monitoring
	VI 2243427-1	2022-05-12	General Mineral	WELL 02	Water Quality Monitoring
	VI 2340926-1	2023-02-13	Metals, Total	WELL 02	Water Quality Monitoring
	VI 2342884-1	2023-05-10	Metals, Total	WELL 02	Water Quality Monitoring
	VI 2345071-1	2023-08-02	Metals, Total	WELL 02	Water Quality Monitoring
	VI 2347468-1	2023-11-06	Metals, Total	WELL 02	Water Quality Monitoring
	VI 2540919-1	2025-02-05	Metals, Total	Well 02	Water Quality Monitoring
	VI 2543235-1	2025-05-07	General Mineral	Well 02	Water Quality Monitoring
	VI 2543235-1	2025-05-07	Metals, Total	Well 02	Water Quality Monitoring
	VI 2543235-1	2025-05-07	Radio Chemistry	Well 02	Water Quality Monitoring
	VI 2543235-1	2025-05-07	Wet Chemistry	Well 02	Water Quality Monitoring
	VI 2545824-1	2025-08-14	Metals, Total	Well 02	Water Quality Monitoring
	VI 2548242-1	2025-11-20	Metals, Total	Well 02	Water Quality Monitoring
	VI 2548593-1	2025-12-03	Wet Chemistry	WELL 02	Well 02- Nitrate Monitoring
STW-3	VI 2540919-2	2025-02-05	Metals, Total	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2543235-2	2025-05-07	Radio Chemistry	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2543235-2	2025-05-07	General Mineral	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2543235-2	2025-05-07	Metals, Total	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2543235-2	2025-05-07	Wet Chemistry	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2545824-2	2025-08-14	Metals, Total	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring
	VI 2548242-2	2025-11-20	Metals, Total	WELL 03 - FIRE SUPRESSION ONLY	Water Quality Monitoring