

2025 Consumer Confidence Report

Water System Name: SULTANA CSD

Report Date: June 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 5 source(s): WELL 01 - RAW, WELL 02 - SOUTH STBY, Well 03 - Main, WELL 03 - MAIN RAW and WELL 04 - RAW

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board meetings are held at Sultana-Monson School District 10643 Ave. 416 Sultana, Ca. 93666 every first Thursday of each month.

For more information about this report, or any questions relating to your drinking water, please call (559) 458 - 6144 and ask for Jose Padilla.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	Range	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2024)	5	0	0	ND -	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	5	0	0	ND - 0.01	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021 - 2025)	35	27 - 38	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021 - 2025)	162	64.7 - 206	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2025)	ND	ND - 3	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2021 - 2025)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2024 - 2025)	4.3	1.5 - 5.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021 - 2025)	5.1	2.4 - 9.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2023 - 2025)	ND	ND - 2.36	15	(0)	Erosion of natural deposits.
Dibromochloropropane (DBCP) (ng/L)	(2023 - 2025)	22	ND - 60	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021 - 2025)	29	16 - 41	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2021 - 2025)	2	ND - 6	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2023)	30	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2021 - 2025)	483	340 - 545	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021 - 2025)	20.5	5.0 - 31.2	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021 - 2025)	308	230 - 380	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021 - 2025)	0.48	ND - 1.3	5	n/a	Soil runoff
Zinc (mg/L)	(2025)	0.01	n/a	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	(2021 - 2023)	48	27 - 74	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021 - 2025)	44	21 - 55	n/a	n/a
Magnesium (mg/L)	(2021 - 2025)	13	3 - 18	n/a	n/a
pH (units)	(2021 - 2025)	7.18	6.4 - 7.8	n/a	n/a
Alkalinity (mg/L)	(2021 - 2025)	163	130 - 190	n/a	n/a
Aggressiveness Index	(2021 - 2025)	11.5	10.7 - 11.9	n/a	n/a
Langelier Index	(2021 - 2025)	-0.4	-1.1 - 0.1	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2024 - 2025)	1	ND - 1	80	n/a	No	By-product of drinking water disinfection
Chlorine, Total (mg/L)	(2021)	0.45	.13 - 0.69	4.0	4.0	No	Drinking water disinfectant added for treatment.
Chlorine, Free (mg/L)	(2024 - 2025)	1.59	0.10 - 2.20	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2024)	4	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Sultana Community Serv. Dist* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 03 MAIN of the SULTANA C S D water system in October, 2002.

WELL 02 - SOUTH STBY - does not have a completed assessment on file. This well is only used for backup and was used briefly last year to provide water.

Well 03 - Main - is considered most vulnerable to the following activities associated with contaminants detected in the water supply:
Automobile - Gas stations
Underground storage tanks - Confirmed leaking tanks
Fertilizer/Pesticide/Herbicide Application

is considered most vulnerable to the following activities not associated with any detected contaminants:
Chemical/petroleum processing/storage
Historic gas stations
Known Contaminant Plumes

WELL 03 - MAIN RAW - is considered most vulnerable to the following activities associated with contaminants detected in the water supply:
Automobile - Gas stations
Underground storage tanks - Confirmed leaking tanks
Fertilizer/Pesticide/Herbicide Application

is considered most vulnerable to the following activities not associated with any detected contaminants:
Chemical/petroleum processing/storage
Historic gas stations
Known Contaminant Plumes

Discussion of Vulnerability

The activities to which Well 03 - Back up of the Sultana CSD water system is most vulnerable include historic leaking underground petroleum tanks, known contamination plumes, agricultural activity and drainage and sewer lines. The system is in an area with contamination plumes for Nitrates and DBCP (Di Bromo Chloro Propane).

Well sites are within the pesticide management zone for Diuron and there are zones for Prometon and Simazine west of Road 104 and North of Avenue 416. The area has contamination of DBCP (Di Bromo Chloro Propane) a fumigant which had been used for nematodes in orchards and vineyards but was banned in 1977. This system has at times had the presence of DBCP below the MCL of 0.2 ppb in some sample results.

Well 03 was the main source of water used for consumption while Well 04 is now the primary well. Well 03 will now be the Back-up and also used to provide water in 2025. It is important to keep the well site clean and free of weeds and debris to prevent contamination. The cement surface seal needs to be checked for cracks and immediately repaired or sealed.

Acquiring Information

A copy of the complete assessment may be viewed at:

Environmental Health Services

5957 S Mooney Blvd

Visalia, CA 93277

Sultana Community Serv. Dist

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
10427 Ave 416	VI 2548658-1					2025-12-04	Absent		
10427 Ave 416	VI 2547973-1					2025-11-11	Absent		
10427 Ave 416	VI 2547270-1					2025-10-09	Absent		
10427 Ave 416	VI 2546436-1					2025-09-09	Absent		
10427 Ave 416	VI 2545703-1					2025-08-11	Absent		
10427 Ave 416	VI 2545169-1					2025-07-21	Absent		
10427 Ave 416	VI 2543999-1					2025-06-09	Absent		
10427 Ave 416	VI 2543489-1					2025-05-19	Absent		
10427 Ave 416	VI 2542462-1					2025-04-07	Absent		
10427 Ave 416	VI 2541635-1					2025-03-05	Absent		
10427 Ave 416	VI 2540956-1					2025-02-06	Absent		
10427 Ave 416	VI 2540419-1					2025-01-20	Absent		
10427 W. El Monte Way	VI 2548210-1					2025-11-19	<1.0		
10494 W. El Monte Way	VI 2548210-2					2025-11-19	<1.0		
10643 W. El Monte Way	VI 2548210-3					2025-11-19	<1.0		
Fecal coliform and E. coli			0	n/a				ND	-
10427 Ave 416	VI 2548658-1					2025-12-04	Absent		
10427 Ave 416	VI 2547973-1					2025-11-11	Absent		
10427 Ave 416	VI 2547270-1					2025-10-09	Absent		
10427 Ave 416	VI 2546436-1					2025-09-09	Absent		
10427 Ave 416	VI 2545703-1					2025-08-11	Absent		
10427 Ave 416	VI 2545169-1					2025-07-21	Absent		
10427 Ave 416	VI 2543999-1					2025-06-09	Absent		
10427 Ave 416	VI 2543489-1					2025-05-19	Absent		
10427 Ave 416	VI 2542462-1					2025-04-07	Absent		
10427 Ave 416	VI 2541635-1					2025-03-05	Absent		
10427 Ave 416	VI 2540956-1					2025-02-06	Absent		
10427 Ave 416	VI 2540419-1					2025-01-20	Absent		
10427 W. El Monte Way	VI 2548210-1					2025-11-19	<1.0		
10494 W. El Monte Way	VI 2548210-2					2025-11-19	<1.0		
10643 W. El Monte Way	VI 2548210-3					2025-11-19	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
10591 Lewis Dr.	VI 2444839-2	ug/L				2024-06-19	ND		
10678 Simson Dr.	VI 2444839-5	ug/L				2024-06-19	ND		
38660 Monson Dr.	VI 2444839-4	ug/L				2024-06-19	ND		
38698 Mason Dr.	VI 2444839-3	ug/L				2024-06-19	ND		
38795 Campbell Dr.	VI 2444839-1	ug/L				2024-06-19	ND		
Copper		mg/L		1.3	.3			0	5
10591 Lewis Dr.	VI 2444839-2	mg/L				2024-06-19	ND		
10678 Simson Dr.	VI 2444839-5	mg/L				2024-06-19	ND		
38660 Monson Dr.	VI 2444839-4	mg/L				2024-06-19	ND		
38698 Mason Dr.	VI 2444839-3	mg/L				2024-06-19	ND		
38795 Campbell Dr.	VI 2444839-1	mg/L				2024-06-19	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			35	27 - 38
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	38		

WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	27		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	36		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	38		
Hardness		mg/L		none	none			161.5	64.7 - 206
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	165		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	206		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	173		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	199		
WELL 04 - RAW	VI 2546824-1	mg/L				2025-09-24	64.7		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			ND	ND - 3
WELL 01 - RAW	VI 2341349-1	ug/L				2023-03-06	3		
WELL 02 - SOUTH STBY	VI 2141248-1	ug/L				2021-02-18	ND		
Well 03 - Main	VI 2541636-1	ug/L				2025-03-05	2		
WELL 03 - MAIN RAW	VI 2241498-1	ug/L				2022-03-07	2		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	0.1		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	0.1		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	0.1		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	0.1		
Nitrate as N		mg/L		10	10			4.3	1.5 - 5.8
WELL 01 - RAW	VI 2440994-1	mg/L				2024-02-07	3.0		
WELL 02 - SOUTH STBY	VI 2441076-1	mg/L				2024-02-12	4.5		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	4.9		
WELL 03 - MAIN RAW	VI 2545704-1	mg/L				2025-08-11	5.4		
WELL 03 - MAIN RAW	VI 2543490-1	mg/L				2025-05-19	5.0		
WELL 03 - MAIN RAW	VI 2540950-1	mg/L				2025-02-06	5.8		
WELL 04 - RAW	VI 2547974-1	mg/L				2025-11-11	1.5		
Nitrate + Nitrite as N		mg/L		10	10			5.1	2.4 - 9.8
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	3.1		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	9.8		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	4.9		
WELL 03 - MAIN RAW	VI 2548665-1	mg/L				2025-12-05	2.4		
Gross Alpha		pCi/L		15	(0)			ND	ND - 2.36
WELL 01 - RAW	VI 2449047-1	pCi/L				2024-11-11	1.52		
WELL 01 - RAW	VI 2446852-1	pCi/L				2024-08-22	ND		
WELL 01 - RAW	VI 2443584-1	pCi/L				2024-05-06	ND		
WELL 01 - RAW	VI 2440994-1	pCi/L				2024-02-07	ND		
WELL 02 - SOUTH STBY	VI 2341038-1	pCi/L				2023-02-17	ND		
WELL 03 - MAIN RAW	VI 2340936-1	pCi/L				2023-02-13	1.20		
WELL 04 - RAW	VI 2548659-1	pCi/L				2025-12-04	ND		
WELL 04 - RAW	VI 2546823-1	pCi/L				2025-09-24	2.36		
Dibromochloropropane (DBCP)		ng/L		200	1.7			22.22	ND - 60
WELL 02 - SOUTH STBY	VI 2341039-1	ng/L				2023-02-17	ND		
Well 03 - Main	VI 2541636-1	ng/L				2025-03-05	40		
WELL 03 - MAIN RAW	VI 2548665-1	ng/L				2025-12-05	ND		
WELL 03 - MAIN RAW	VI 2545704-1	ng/L				2025-08-11	40		
WELL 03 - MAIN RAW	VI 2543490-1	ng/L				2025-05-19	60		
WELL 03 - MAIN RAW	VI 2540950-1	ng/L				2025-02-06	60		
WELL 04 - RAW	VI 2548659-1	ng/L				2025-12-04	ND		
WELL 04 - RAW	VI 2547974-1	ng/L				2025-11-11	ND		
WELL 04 - RAW	VI 2546823-1	ng/L				2025-09-24	ND		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			29	16 - 41

WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	22		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	16		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	41		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	35		
Color		Units		15	n/a			2	ND - 6
WELL 02 - SOUTH STBY	VI 2141248-1	Units				2021-02-18	6		
Well 03 - Main	VI 2541636-1	Units				2025-03-05	ND		
WELL 03 - MAIN RAW	VI 2241498-1	Units				2022-03-07	ND		
Iron		ug/L		300	n/a			30	30 - 30
WELL 01 - RAW	VI 2342314-1	ug/L				2023-04-18	30		
Specific Conductance		umhos/cm		1600	n/a			483	340 - 545
WELL 01 - RAW	VI 2342314-1	umhos/cm				2023-04-18	340		
WELL 02 - SOUTH STBY	VI 2141248-1	umhos/cm				2021-02-18	545		
Well 03 - Main	VI 2541636-1	umhos/cm				2025-03-05	516		
WELL 03 - MAIN RAW	VI 2241498-1	umhos/cm				2022-03-07	530		
Sulfate		mg/L		500	n/a			20.5	5.0 - 31.2
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	5.0		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	31.2		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	21.9		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	24.0		
Total Dissolved Solids		mg/L		1000	n/a			308	230 - 380
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	230		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	380		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	290		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	330		
Turbidity		NTU		5	n/a			0.48	ND - 1.3
WELL 01 - RAW	VI 2341349-1	NTU				2023-03-06	1.3		
WELL 02 - SOUTH STBY	VI 2141248-1	NTU				2021-02-18	0.3		
Well 03 - Main	VI 2541636-1	NTU				2025-03-05	0.30		
WELL 03 - MAIN RAW	VI 2241498-1	NTU				2022-03-07	ND		
Zinc		mg/L		5	n/a			0.01	0.01 - 0.01
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	0.01		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			48	27 - 74
WELL 01 - RAW	VI 2341349-1	ug/L				2023-03-06	74		
WELL 02 - SOUTH STBY	VI 2141248-1	ug/L				2021-02-18	27		
WELL 03 - MAIN RAW	VI 2241498-1	ug/L				2022-03-07	42		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			44	21 - 55
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	43		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	53		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	48		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	55		
WELL 04 - RAW	VI 2546824-1	mg/L				2025-09-24	21		
Magnesium		mg/L			n/a			13	3 - 18
WELL 01 - RAW	VI 2342314-1	mg/L				2023-04-18	14		
WELL 02 - SOUTH STBY	VI 2141248-1	mg/L				2021-02-18	18		
Well 03 - Main	VI 2541636-1	mg/L				2025-03-05	13		
WELL 03 - MAIN RAW	VI 2241498-1	mg/L				2022-03-07	15		
WELL 04 - RAW	VI 2546824-1	mg/L				2025-09-24	3		
pH		units			n/a			7.18	6.4 - 7.8
WELL 01 - RAW	VI 2342314-1	units				2023-04-18	7.8		
WELL 02 - SOUTH STBY	VI 2141248-1	units				2021-02-18	7.2		
Well 03 - Main	VI 2541636-1	units				2025-03-05	6.4		

Sultana Community Serv. Dist

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
10427AVE416	VI 2049982-1	2020-12-21	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2049982-1	2020-12-21	Sampling	10427 Ave 416	Routine Bacteriological
	VI 2140421-1	2021-01-19	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2141247-1	2021-02-18	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2141970-1	2021-03-15	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2142830-1	2021-04-15	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2540419-1	2025-01-20	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2540419-1	2025-01-20	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2540956-1	2025-02-06	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2540956-1	2025-02-06	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2541635-1	2025-03-05	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2541635-1	2025-03-05	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2542462-1	2025-04-07	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2542462-1	2025-04-07	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2543489-1	2025-05-19	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2543489-1	2025-05-19	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2543999-1	2025-06-09	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2543999-1	2025-06-09	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2545169-1	2025-07-21	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2545169-1	2025-07-21	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2545703-1	2025-08-11	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2545703-1	2025-08-11	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2546436-1	2025-09-09	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2546436-1	2025-09-09	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2547270-1	2025-10-09	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2547270-1	2025-10-09	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2547973-1	2025-11-11	Field Test	10427 Ave 416	Routine Bacteriological
	VI 2547973-1	2025-11-11	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2548658-1	2025-12-04	Coliform	10427 Ave 416	Routine Bacteriological
	VI 2548658-1	2025-12-04	Field Test	10427 Ave 416	Routine Bacteriological
10427 W. El Mon	VI 2548210-1	2025-11-19	Field Test	10427 W. El Monte Way	Sultana C.S.D. Special Sampling
	VI 2548210-1	2025-11-19	Coliform	10427 W. El Monte Way	Sultana C.S.D. Special Sampling
10444 Hobson	VI 1742920-1	2017-06-26	Sub Contracted	10444 Hobson	Drinking Water Monitoring
10494 W. El Mon	VI 2548210-2	2025-11-19	Field Test	10494 W. El Monte Way	Sultana C.S.D. Special Sampling
	VI 2548210-2	2025-11-19	Coliform	10494 W. El Monte Way	Sultana C.S.D. Special Sampling
CA5403212_LCR	VI 2444839-2	2024-06-19	Metals, Total	10591 Lewis Dr.	MONSON WATER SYSTEM
10643 W. El Mon	VI 2548210-3	2025-11-19	Coliform	10643 W. El Monte Way	Sultana C.S.D. Special Sampling
	VI 2548210-3	2025-11-19	Field Test	10643 W. El Monte Way	Sultana C.S.D. Special Sampling
CA5403212_LCR	VI 2444839-5	2024-06-19	Metals, Total	10678 Simson Dr.	MONSON WATER SYSTEM
	VI 2444839-4	2024-06-19	Metals, Total	38660 Monson Dr.	MONSON WATER SYSTEM
	VI 2444839-3	2024-06-19	Metals, Total	38698 Mason Dr.	MONSON WATER SYSTEM
	VI 2444839-1	2024-06-19	Metals, Total	38795 Campbell Dr.	MONSON WATER SYSTEM
10678 Simpson R	VI 1842736-10	2018-06-08	Metals, Total	M-10678 Simpson Rd.	Monson Residents
38660 Monson Dr	VI 1842736-8	2018-06-08	Metals, Total	M-38660 Monson Dr.	Monson Residents
38686 Monson Dr	VI 1842736-7	2018-06-08	Metals, Total	M-38686 Monson Dr.	Monson Residents
MONSON HYD 3	VI 2140420-1	2021-01-19	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2141249-1	2021-02-18	Field Test	Monson Hyd #3	Monson - Routine Monitoring
MONSON HYD3	VI 2141971-1	2021-03-15	Field Test	Monson Hyd #3	Monson - Routine Monitoring
MONSON HYD 3	VI 2142829-1	2021-04-15	Field Test	Monson Hyd #3	Monson - Routine Monitoring
MONSON HYD3	VI 2440148-1	2024-01-04	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2440995-1	2024-02-07	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2441774-1	2024-03-07	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2443012-1	2024-04-16	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2443585-1	2024-05-06	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2443932-1	2024-05-20	Field Test	Monson Hyd #3	Resamples
	VI 2444784-1	2024-06-17	Field Test	Monson Hyd #3	Monson - Routine Monitoring

	VI 2445910-1	2024-07-24	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2446853-1	2024-08-22	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2447764-1	2024-09-23	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2448389-1	2024-10-14	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2449048-1	2024-11-11	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 2449686-1	2024-12-10	Field Test	Monson Hyd #3	Monson - Routine Monitoring
MONSON HYD5	VI 2443932-2	2024-05-20	Field Test	Monson Hyd #5	Resamples
MONSON TNK	VI 2443932-3	2024-05-20	Field Test	Monson Tank	Resamples
ST2S1	VI 2445577-1	2024-07-11	EPA 552.2	ST2S1 - 10678 SIMPSON DR	Monson Water-Stage 2 DBP
	VI 2445577-1	2024-07-11	EPA 551.1	ST2S1 - 10678 SIMPSON DR	Monson Water-Stage 2 DBP
DBPR-STG2-SS1	VI 2545705-1	2025-08-11	EPA 551.1	ST2S1-10427 Ave 416 (Post Ofc)	Stage 2 DBP Monitoring
DBPR-STG2-SS2	VI 2546822-1	2025-09-24	EPA 551.1	ST2S2 - 10678 SIMPSON DR	Stage 2 DBP Monitoring
Well	VI 1742919-1	2017-06-26	Sub Contracted	WELL 01 - RAW	Drinking Water Monitoring
WELL01	VI 2247587-1	2022-09-26		WELL 01 - RAW	Monson Water-Well 01 VOC Monitoring
CA5400824_007_0	VI 2341349-1	2023-03-06	Wet Chemistry	WELL 01 - RAW	SULTANA COMMUNITY SERVICES DISTRICT
	VI 2341349-1	2023-03-06	Metals, Total	WELL 01 - RAW	SULTANA COMMUNITY SERVICES DISTRICT
WELL01	VI 2342314-1	2023-04-18	General Mineral	WELL 01 - RAW	Well 01- WQ Resample
	VI 2346136-1	2023-09-11		WELL 01 - RAW	MONSON WATER SYSTEM
	VI 2440994-1	2024-02-07	Wet Chemistry	WELL 01 - RAW	Monson Water-Well 01 WQ 2
	VI 2440994-1	2024-02-07	Radio Chemistry	WELL 01 - RAW	Monson Water-Well 01 WQ 2
	VI 2443584-1	2024-05-06	Radio Chemistry	WELL 01 - RAW	Monson Water-Well 01 WQ 2
	VI 2446852-1	2024-08-22	Radio Chemistry	WELL 01 - RAW	Monson Water-Well 01 WQ 2
	VI 2449047-1	2024-11-11	Radio Chemistry	WELL 01 - RAW	Monson Water-Well 01 WQ 2
WELL 02 - SOUTH	VI 2141248-1	2021-02-18	Wet Chemistry	WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
	VI 2141248-1	2021-02-18	Metals, Total	WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
	VI 2141248-1	2021-02-18	General Mineral	WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
	VI 2241286-1	2022-02-28		WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
	VI 2341039-1	2023-02-17		WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
	VI 2341038-1	2023-02-17	Radio Chemistry	WELL 02 - SOUTH STBY	Sultana CSD-Well 02 Radio Monitoring
	VI 2441076-1	2024-02-12	Wet Chemistry	WELL 02 - SOUTH STBY	Sultana CSD-Well 02 General Mineral Monitoring
WELL 03 - MAIN	VI 2241989-1	2022-03-21		Well 03 - Main	Sultana CSD Well 03-Water Quality Monitoring
	VI 2541636-1	2025-03-05	Metals, Total	Well 03 - Main	Sultana CSD Well 03-Water Quality Monitoring
	VI 2541636-1	2025-03-05	General Mineral	Well 03 - Main	Sultana CSD Well 03-Water Quality Monitoring
	VI 2541636-1	2025-03-05	EPA 504.1	Well 03 - Main	Sultana CSD Well 03-Water Quality Monitoring
	VI 2541636-1	2025-03-05	Wet Chemistry	Well 03 - Main	Sultana CSD Well 03-Water Quality Monitoring
	VI 2049993-1	2020-12-21	Radio Chemistry	WELL 03 - MAIN RAW	Sultana CSD Well 03-Radio Monitoring
	VI 2241498-1	2022-03-07	General Mineral	WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
	VI 2241498-1	2022-03-07	Wet Chemistry	WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
	VI 2241498-1	2022-03-07	Metals, Total	WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
	VI 2241498-1	2022-03-07		WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
	VI 2340936-1	2023-02-13	Radio Chemistry	WELL 03 - MAIN RAW	Sultana CSD Well 03-Radio Monitoring
	VI 2540950-1	2025-02-06	Wet Chemistry	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring
	VI 2540950-1	2025-02-06	EPA 504.1	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring
	VI 2543490-1	2025-05-19	Wet Chemistry	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring
	VI 2543490-1	2025-05-19	EPA 504.1	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring
	VI 2545704-1	2025-08-11	EPA 504.1	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring
	VI 2545704-1	2025-08-11	Wet Chemistry	WELL 03 - MAIN RAW	Well 03-Quarterly Monitoring

	VI 2548665-1	2025-12-05	Wet Chemistry	WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
	VI 2548665-1	2025-12-05	EPA 504.1	WELL 03 - MAIN RAW	Sultana CSD Well 03-Water Quality Monitoring
WELL04RAW	VI 2546824-1	2025-09-24	Metals, Total	WELL 04 - RAW	Sultana CSD-Well 04-WQ
	VI 2546823-1	2025-09-24	Radio Chemistry	WELL 04 - RAW	Sultana CSD-Well 04-Quarterly
	VI 2546823-1	2025-09-24	EPA 504.1	WELL 04 - RAW	Sultana CSD-Well 04-Quarterly
	VI 2547974-1	2025-11-11	EPA 504.1	WELL 04 - RAW	Well 04-Quarterly Monitoring
	VI 2547974-1	2025-11-11	Wet Chemistry	WELL 04 - RAW	Well 04-Quarterly Monitoring
	VI 2548659-1	2025-12-04	Radio Chemistry	WELL 04 - RAW	Sultana CSD-Well 04-Quarterly
	VI 2548659-1	2025-12-04	EPA 504.1	WELL 04 - RAW	Sultana CSD-Well 04-Quarterly