

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

| | |
|----------------------|------------------------------------|
| Water System Name: | SIERRA KING HOMEOWNERS ASSN (SKHA) |
| Water System Number: | CA5400940 |

The water system named above hereby certifies that its Consumer Confidence Report was distributed on July 1, 2022 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

| | | | |
|---------------|---------------|------------------------|--------------------|
| Certified By: | Name: | Malinee Crapsey | |
| | Signature: | <i>Malinee Crapsey</i> | |
| | Title: | SKHA Board President | |
| | Phone Number: | (559) 769-5110 | Date: July 1, 2022 |

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
Email to every member with confirmed email, including to family members of elders who have requested notifications to caregiving family members. Emailed to managers of short-term rentals. Delivered to household without email. Posted on SKHA public bulletin board in the neighborhood. In July newsletter mailed with quarterly billing, a reminder of the CCR completion and how to get a copy if they need another one.
- ☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods: Not applicable, as all members regularly pay water bills.
- ☐ Posted the CCR on the internet at http://
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http://
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2021 Consumer Confidence Report

Water System Name: SIERRA KING HOMEOWNERS ASSN

Report Date: June 2022

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, Well 01 - RAW and WELL 02 - RAW are Groundwater. This Assessment was done using the Default Groundwater System Method. Well 01 - RAW and Well 02 - RAW alternate to provide water to residences.

Your water comes from 2 source(s): WELL 01 - RAW and WELL 02 - RAW

Opportunities for public participation in decisions that affect drinking water quality: Members are invited to monthly board meetings. An annual members meeting is held yearly (almost no attendees). Members have been given contact information for all board members. Since COVID, there have been no annual meetings or in-person board meetings, so members have been invited in writing to contact any board member with questions. When there are questions or issues, a newsletter/update is included in the quarterly billing mailed to all members, with contact information.

For more information about this report, or any questions relating to your drinking water, please call (559) 769-5110 and ask for Malinee Crapsey or email mcrapsey3@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

| Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER | | | | | | | |
|--|--------------------|-----------------------|---------------------------------------|-------------------------------|-----------|------------|---|
| Lead and Copper (complete if lead or copper detected in last sample set) | Sample Date | No. of Samples | 90th percentile level detected | No. Sites Exceeding AL | AL | PHG | Typical Sources of Contaminant |
| Copper (mg/L) | (2019) | 5 | 0.11 | 0 | 1.3 | .3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

| Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | |
|---|--------------------|-------------------------------|----------------------------|------------|-------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
| Sodium (mg/L) | (2019 - 2020) | 24 | 20 - 27 | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (mg/L) | (2019 - 2020) | 130 | 125 - 134 | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|---|--------------------|-------------------------------|----------------------------|-------------------|---------------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
| Arsenic (ug/L) | (2019 - 2020) | 6 | 5 - 6 | 10 | 0.004 | Erosion of natural deposits; runoff from orchards, glass and electronics production wastes |

| | | | | | | |
|-------------------------------|---------------|------|-------------|----|------|---|
| Fluoride (mg/L) | (2019 - 2020) | 0.6 | 0.5 - 0.7 | 2 | 1 | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Nitrate + Nitrite as N (mg/L) | (2019 - 2020) | 0.9 | 0.5 - 1.3 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Gross Alpha (pCi/L) | (2020) | 3.06 | 2.35 - 3.76 | 15 | (0) | Erosion of natural deposits. |
| Uranium (pCi/L) | (2017 - 2019) | 7 | 2.80 - 17.1 | 20 | 0.43 | Erosion of natural deposits |

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
|--|---------------|------------------------|---------------------|------|------------|---|
| Chloride (mg/L) | (2019 - 2020) | 11 | 9 - 13 | 500 | n/a | Runoff/leaching from natural deposits; seawater influence |
| Odor Threshold at 60 °C (TON) | (2020) | 4 | ND - 8 | 3 | n/a | Naturally-occurring organic materials. |
| Specific Conductance (umhos/cm) | (2019 - 2020) | 371 | 360 - 381 | 1600 | n/a | Substances that form ions when in water; seawater influence |
| Sulfate (mg/L) | (2019 - 2020) | 28.9 | 26.0 - 31.7 | 500 | n/a | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (mg/L) | (2019 - 2020) | 235 | 220 - 250 | 1000 | n/a | Runoff/leaching from natural deposits |
| Turbidity (NTU) | (2019 - 2020) | 0.2 | 0.1 - 0.2 | 5 | n/a | Soil runoff |
| Zinc (mg/L) | (2019 - 2020) | 0.54 | 0.07 - 1.01 | 5 | n/a | Runoff/leaching from natural deposits |

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Typical Sources of Contaminant |
|--|---------------|------------------------|---------------------|--------------------|---|
| Boron (mg/L) | (2019 - 2020) | 0.1 | ND - 0.2 | 1 | Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats. |

Table 6 - ADDITIONAL DETECTIONS

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Typical Sources of Contaminant |
|--|---------------|------------------------|---------------------|--------------------|--------------------------------|
| Calcium (mg/L) | (2019 - 2020) | 38 | 37 - 39 | n/a | n/a |
| Magnesium (mg/L) | (2019 - 2020) | 9 | 8 - 9 | n/a | n/a |
| pH (units) | (2019 - 2020) | 6.9 | 6.7 - 7.0 | n/a | n/a |
| Alkalinity (mg/L) | (2019 - 2020) | 135 | 130 - 140 | n/a | n/a |
| Aggressiveness Index | (2019 - 2020) | 11 | 10.8 - 11.1 | n/a | n/a |
| Langelier Index | (2019 - 2020) | -0.9 | -1.0 - -0.7 | n/a | n/a |

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Violation | Typical Sources of Contaminant |
|--|-------------|------------------------|---------------------|------------|------------|-----------|--|
| Chlorine (mg/L) | (2021) | 0.51 | .22 - .77 | 4.0 | 4.0 | No | Drinking water disinfectant added for treatment. |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Sierra King Homeowners Assoc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT | | | | |
|--|--|--|--|---|
| Violation | Explanation | Duration | Actions Taken To Correct the Violation | Health Effects Language |
| Odor Threshold at 60 °C | FGL staff said that occasionally gases can collect and cause a temporary odor. This occurred once in 2020. | FGL staff noted odor on one occasion, at one site, in 2020. Regulations require that it remain in the CCR for 9 years. | No action taken | Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health. |

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2021 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 - RAW of the SIERRA KING HOMEOWNERS ASSN. water system in August, 2002. A source water assessment was completed for the WELL 02 - RAW of the SIERRA KING HOMEOWNERS ASSN. water system in February, 2017.

WELL 01 - RAW - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [$<1/\text{acre}$]

WELL 02 - RAW - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [$<1/\text{acre}$]

Discussion of Vulnerability

The activity to which the Sierra King Homeowners Association water system is most vulnerable is septic systems. It is important that septic systems be kept in good repair and pumped regularly. It is also necessary to keep the well site clean and free of weeds and debris to prevent contamination. The cement surface seal needs to be checked for cracks and immediately repaired or sealed. Assessment summaries are not available for some sources.

Acquiring Information

The system is no longer overseen by Tulare County. It is now under the purview of the California State Water Resources Control Board, Division of Drinking Water, under Domestic Water Supply Permit No. 03-24-15P-024 as a D1 distribution system.

Per Kevin Bangsund of Tulare County Environmental Health Services Division, 559-624-7405, the county no longer has any documents pertaining to this system; they were turned over to the state several years ago.

A copy of the complete assessment may be viewed through:

State Water Resources Control Board

Division of Drinking Water

265 W. Bullard Ave., Suite 101

Fresno, CA 93704

Or contact Lewis Sutfin, VP & DO for SKHA

lsutfin@yahoo.com