

2018 Consumer Confidence Report

Water System Name: EAST OROSI CSD

Report Date: April 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Well 02 - WEST

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at 41842 Ione Rd Orosi, CA. on the last Thursday of each month at 6:30P.M.

For more information about this report, or any questions relating to your drinking water, please call (559) 393-1125 and ask for Lucy Rodriguez or email eastoroscids@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health, along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

umhos/cra: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	10 (2018)	0.07	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2013)	17	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2013)	176	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table.3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2013)	0.2	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (mg/L)	(2018)	11.7	11.3 - 12.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2013)	9.1	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2018)	ND	ND - 0.008	0.005	0.0007	

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2013)	16	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2013)	456	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2013)	16	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2013)	310	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (mg/L)	(2013)	0.04	n/a	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2015)	4.6	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2018)	0.27	0.05 - 0.79	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *East Oroshi Community Services* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Nitrate as N: Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.

Systems with nitrate (as nitrogen) above 5 ppm (50% of the MCL), but below 10 ppm (the MCL): Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

About our 1,2,3-Trichloropropane (1,2,3-TCP): Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 - WEST of the EAST OROSI C.S.D. water system in October, 2002.

Well 02 - WEST - is considered most vulnerable to the following activities not associated with any detected contaminants:
Known Contaminant Plumes

Discussion of Vulnerability

The activities to which the East Oroshi CSD water system is most vulnerable include known agricultural activity and drainage and septic systems. This system is over half the MCL of 45 ppm for nitrates with 33.7 ppm for Well 01 and 43.4 for Well 02. Nitrates can be associated with septic systems, agricultural use of fertilizers and concentrated animal facilities. Both wells are also within the pesticide management zones for Bromacil and Diuron.

It is important that septic systems be kept in good repair and pumped regularly. It is also necessary to keep the well site clean and free of weeds and debris to prevent contamination. The cement surface seal needs to be checked for cracks and immediately repaired or sealed.

Acquiring Information

A copy of the complete assessment may be viewed at:

Environmental Health Services
5957 S Mooney Blvd
Visalia, CA 93277

You may request a summary of the assessment be sent to you by contacting:

Environmental Health Specialist
559-733-6441
559-733-6932 (fax)

East Orosi Community Services

Analytical Results By FGL - 2018

LEAD AND COPPER RULE								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile
Copper		mg/L		1.3	.3			0.07
13907 Idaho Ave.	VI 1844580-2	mg/L				2018-08-29	ND	10
13911 Ave. 418	VI 1844580-1	mg/L				2018-08-29	0.09	
13921 Idaho Ave.	VI 1844580-5	mg/L				2018-08-29	ND	
13944 Ave. 416	VI 1845062-1	mg/L				2018-09-21	ND	
13946 Idaho Ave.	VI 1845062-3	mg/L				2018-09-21	ND	
13953 Ave. 418	VI 1845062-2	mg/L				2018-09-21	ND	
13968 Ave. 416	VI 1845062-4	mg/L				2018-09-21	0.07	
41712 Fruitvale Ave #A	VI 1844580-4	mg/L				2018-08-29	ND	
41712 Fruitvale Ave.	VI 1844580-3	mg/L				2018-08-29	ND	
41724 Fruitvale Ave.	VI 1845749-1	mg/L				2018-10-24	ND	

SAMPLING RESULTS FOR SODIUM AND HARDNESS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)
Sodium		mg/L		none	none			17
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	17	17 - 17
Hardness		mg/L		none	none			176
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	176	176 - 176

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)
Fluoride		mg/L		2	1			0.2
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	0.2	0.2 - 0.2
Nitrate as N		mg/L		10	10			11.7
Well 02 - WEST	VI 1843610-2	mg/L				2018-07-20	12.3	11.3 - 12.3
Well 02 - WEST	VI 1841799-2	mg/L				2018-04-18	11.4	
Well 02 - WEST	VI 1840205-2	mg/L				2018-01-15	11.3	
Nitrate + Nitrite as N		mg/L		10	10			9.1
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	9.1	9.1 - 9.1
1,2,3-Trichloropropane (1,2,3-TCP)		ug/L		0.005	0.0007			ND
Well 02 - WEST	VI 1844993-2	ug/L				2018-09-19	ND	ND - 0.008
Well 02 - WEST	VI 1841366-1	ug/L				2018-03-21	0.008	

SECONDARY DRINKING WATER STANDARDS (SDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)
Chloride		mg/L		500	n/a			16
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	16	16 - 16
Specific Conductance		umhos/cm		1600	n/a			456
Well 02 - WEST	VI 1343525-3	umhos/cm				2013-09-25	456	456 - 456
Sulfate		mg/L		500	n/a			16
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	16	16 - 16
Total Dissolved Solids		mg/L		1000	n/a			310
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	310	310 - 310

UNREGULATED CONTAMINANTS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)
Vanadium		mg/L		NS	n/a			0.040
Well 02 - WEST	VI 1343525-3	mg/L				2013-09-25	0.040	0.040 - 0.040

[illegible]

East Orosi Community Services

CCR Login Linkage - 2018

FGL Code	Lab ID	Date Sampled	Method	Description	Property
13875 Idaho	VI 1843769-6	2018-07-30	Coliform	13875 Idaho Ave.	EAST OROSI CSD
13907 Idaho Ave	VI 1844580-2	2018-08-29	Metals, Total	13907 Idaho Ave.	Lead & Copper
13911 Ave. 418	VI 1844580-1	2018-08-29	Metals, Total	13911 Ave. 418	Lead & Copper
13920 AVE 41	VI 1843112-1	2018-06-22	Coliform	13920 Ave. 416	Monthly Coliform Monitoring
	VI 1843112-1	2018-06-22	Field Test	13920 Ave. 416	Monthly Coliform Monitoring
Bacti-Rout-ss01	VI 1543683-2	2015-09-16	EPA 551.1	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840205-1	2018-01-15	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840205-1	2018-01-15	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840515-1	2018-02-05	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840515-1	2018-02-05	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
CuPb-ss01	VI 1841029-1	2018-03-09	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1841029-1	2018-03-09	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
Bacti-Rout-ss01	VI 1841799-1	2018-04-18	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1841799-1	2018-04-18	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843610-1	2018-07-20	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843610-1	2018-07-20	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843769-3	2018-07-30	Coliform	13920 Ave. 418	Monthly Bacteriological Monitoring
	VI 1844129-1	2018-08-13	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844129-1	2018-08-13	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844989-1	2018-09-19	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844989-1	2018-09-19	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1845523-1	2018-10-11	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1845523-1	2018-10-11	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
13921 Idaho Ave	VI 1844580-5	2018-08-29	Metals, Total	13921 Idaho Ave.	Lead & Copper
13944 Ave 416	VI 1845062-1	2018-09-21	Metals, Total	13944 Ave. 416	Drinking Water Monitoring
13946 Idaho Ave	VI 1845062-3	2018-09-21	Metals, Total	13946 Idaho Ave.	Drinking Water Monitoring
13953 Ave 418	VI 1845062-2	2018-09-21	Metals, Total	13953 Ave. 418	Drinking Water Monitoring
Bacti-Rout-ss03	VI 1845062-4	2018-09-21	Metals, Total	13968 Ave. 416	Drinking Water Monitoring
41712 Fruitvale	VI 1844580-4	2018-08-29	Metals, Total	41712 Fruitvale Ave #A	Lead & Copper
	VI 1844580-3	2018-08-29	Metals, Total	41712 Fruitvale Ave.	Lead & Copper
41724 Fruitvale	VI 1843769-4	2018-07-30	Coliform	41724 Fruitvale Ave.	EAST OROSI CSD
41724 Fruit Val	VI 1845749-1	2018-10-24	Metals, Total	41724 Fruitvale Ave.	Drinking Water Monitoring
41778 Rd 139	VI 1843769-5	2018-07-30	Coliform	41778 Road 139	EAST OROSI CSD
41786 Rd 139	VI 1843769-2	2018-07-30	Coliform	41786 Road 139	Monthly Bacteriological Monitoring
STW-2	VI 1343525-3	2013-09-25	Metals, Total	Well 02 - WEST	Monthly Coliform Monitoring
	VI 1343525-3	2013-09-25	General Mineral	Well 02 - WEST	Monthly Coliform Monitoring
WELL02	VI 1840205-2	2018-01-15	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1841366-1	2018-03-21	SRL 524M-TCP	Well 02 - WEST	EAST OROSI CSD
	VI 1841799-2	2018-04-18	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1843610-2	2018-07-20	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1844993-2	2018-09-19	SRL 524M-TCP	Well 02 - WEST	EAST OROSI CSD

East Orosi Community Services

CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
13875 Idaho	VI 1843769-6	2018-07-30	Coliform	13875 Idaho Ave.	EAST OROSI CSD
13907 Idaho Ave	VI 1844580-2	2018-08-29	Metals, Total	13907 Idaho Ave.	Lead & Copper
13911 Ave. 418	VI 1844580-1	2018-08-29	Metals, Total	13911 Ave. 418	Lead & Copper
13920 AVE 41	VI 1843112-1	2018-06-22	Coliform	13920 Ave. 416	Monthly Coliform Monitoring
	VI 1843112-1	2018-06-22	Field Test	13920 Ave. 416	Monthly Coliform Monitoring
Bacti-Rout-ss01	VI 1543683-2	2015-09-16	EPA 551.1	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840205-1	2018-01-15	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840205-1	2018-01-15	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840515-1	2018-02-05	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1840515-1	2018-02-05	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
CuPb-ss01	VI 1841029-1	2018-03-09	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1841029-1	2018-03-09	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
Bacti-Rout-ss01	VI 1841799-1	2018-04-18	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1841799-1	2018-04-18	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843610-1	2018-07-20	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843610-1	2018-07-20	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1843769-3	2018-07-30	Coliform	13920 Ave. 418	Monthly Bacteriological Monitoring
	VI 1844129-1	2018-08-13	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844129-1	2018-08-13	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844989-1	2018-09-19	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1844989-1	2018-09-19	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1845523-1	2018-10-11	Field Test	13920 Ave. 418	Monthly Coliform Monitoring
	VI 1845523-1	2018-10-11	Coliform	13920 Ave. 418	Monthly Coliform Monitoring
13921 Idaho Ave	VI 1844580-5	2018-08-29	Metals, Total	13921 Idaho Ave.	Lead & Copper
13944 Ave 416	VI 1845062-1	2018-09-21	Metals, Total	13944 Ave. 416	Drinking Water Monitoring
13946 Idaho Ave	VI 1845062-3	2018-09-21	Metals, Total	13946 Idaho Ave.	Drinking Water Monitoring
13953 Ave 418	VI 1845062-2	2018-09-21	Metals, Total	13953 Ave. 418	Drinking Water Monitoring
Bacti-Rout-ss03	VI 1845062-4	2018-09-21	Metals, Total	13968 Ave. 416	Drinking Water Monitoring
41712 Fruitvale	VI 1844580-4	2018-08-29	Metals, Total	41712 Fruitvale Ave #A	Lead & Copper
	VI 1844580-3	2018-08-29	Metals, Total	41712 Fruitvale Ave.	Lead & Copper
41724 Fruitvale	VI 1843769-4	2018-07-30	Coliform	41724 Fruitvale Ave.	EAST OROSI CSD
41724 Fruit Val	VI 1845749-1	2018-10-24	Metals, Total	41724 Fruitvale Ave.	Drinking Water Monitoring
41778 Rd 139	VI 1843769-5	2018-07-30	Coliform	41778 Road 139	EAST OROSI CSD
41786 Rd 139	VI 1843769-2	2018-07-30	Coliform	41786 Road 139	Monthly Bacteriological Monitoring
STW-2	VI 1343525-3	2013-09-25	Metals, Total	Well 02 - WEST	Monthly Coliform Monitoring
	VI 1343525-3	2013-09-25	General Mineral	Well 02 - WEST	Monthly Coliform Monitoring
WELL02	VI 1840205-2	2018-01-15	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1841366-1	2018-03-21	SRL 524M-TCP	Well 02 - WEST	EAST OROSI CSD
	VI 1841799-2	2018-04-18	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1843610-2	2018-07-20	Wet Chemistry	Well 02 - WEST	Quarterly Nitrate Monitoring
	VI 1844993-2	2018-09-19	SRL 524M-TCP	Well 02 - WEST	EAST OROSI CSD

Location of CCR Posting :

East Orosi Community Service District - 40482 lone Rd. Orosi, CA. 93647

Orosi Market 13968 AVE. 416 Orosi, CA. 936478