


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at [http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>DEER MEADOW MUTUAL</b>
Water System Number:	<b>CA5401026</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Scott Sherwood	
	Signature:		
	Title:	President	
	Phone Number:	( 559 ) 303-2900	Date: 05-05-2026

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
Email to members


---
  
- "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
  - Posted the CCR on the internet at http:// \_\_\_\_\_
  - Mailed the CCR to postal patrons within the service area (attach zip codes used)
  - Advertised the availability of the CCR in news media (attach a copy of press release)
  - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
  - Posted the CCR in public places (attach a list of locations)
  - Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
  - Delivery to community organizations (attach a list of organizations)
  - Other (attach a list of other methods used)
  
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// \_\_\_\_\_
  
- For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2025 Consumer Confidence Report

Water System Name: DEER MEADOW MUTUAL

Report Date: April 2026

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 2 source(s):** Well 01 and WELL 01 - RAW

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call 5599015156 and ask for Catherine Karplus or email [cakarplus@gmail.com](mailto:cakarplus@gmail.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

<b>Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>							
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>No. of Samples</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Lead (ug/L)	(2023)	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2023)	5	0.11	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2025)	36	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2025)	256	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (mg/L)	(2025)	0.11	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	(2025)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

**Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2025)	95	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2025)	7	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2025)	700	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2025)	142	90 - 241	50	n/a	Leaching from natural deposits
Odor Threshold at 60 °C (TON)	(2025)	16	n/a	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2025)	734	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2025)	21.6	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2025)	430	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2025)	4.7	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2025)	0.03	n/a	5	n/a	Runoff/leaching from natural deposits

**Table 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2025)	0.16	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2025)	142	90 - 241	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

**Table 7 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2025)	91	n/a	n/a	n/a
Magnesium (mg/L)	(2025)	7	n/a	n/a	n/a
pH (units)	(2025)	7.7	n/a	n/a	n/a
Alkalinity (mg/L)	(2025)	220	n/a	n/a	n/a
Aggressiveness Index	(2025)	12.4	n/a	n/a	n/a
Langelier Index	(2025)	0.5	n/a	n/a	n/a

**Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2025)	10	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine, Free (mg/L)	(2024 - 2025)	2.20	0.31 - 2.20	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2025)	23	n/a	60	n/a	No	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Deer Meadow MWC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

# Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.
Odor Threshold at 60 °C				Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

## 2025 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

A source water assessment was conducted for the WELL 01 of the DEER MEADOW MUTUAL water system in July, 2002.

Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - high density [>1/acre]

WELL 01 - RAW - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - high density [>1/acre]

### Discussion of Vulnerability

The activity to which the Deer Meadow Mutual Water Company is most vulnerable is septic systems. It is important that septic systems be kept in good repair and pumped regularly. It is also necessary to keep the well site clean and free of weeds and debris to prevent contamination. The cement surface seal needs to be checked for cracks

and immediately repaired or sealed.

**Acquiring Information**

A copy of the complete assessment may be viewed at:

Environmental Health Services

5957 S Mooney Blvd

Visalia, CA 93277

You may request a summary of the assessment be sent to you by contacting:

Susan Shaw

Environmental Health Specialist

559-733-6441

559-733-6932 (fax)

sshaw@tularehhsa.org

# Deer Meadow MWC

## Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			ND	-
40992 Meadow Drive H/B	VI 2546345-3					2025-09-04	<1.0		
40992 Meadow Drive H/B	VI 2546300-3					2025-09-03	<1.0		
40992 Meadow Drive H/B	VI 2545850-3					2025-08-18	<1.0		
40999 Cherokee Oaks	VI 2548932-1					2025-12-15	Absent		
40999 Cherokee Oaks	VI 2548246-1					2025-11-20	Absent		
40999 Cherokee Oaks	VI 2547115-1					2025-10-02	Absent		
40999 Cherokee Oaks	VI 2546480-1					2025-09-10	Absent		
40999 Cherokee Oaks	VI 2546345-2					2025-09-04	<1.0		
40999 Cherokee Oaks	VI 2546300-2					2025-09-03	<1.0		
40999 Cherokee Oaks	VI 2545850-2					2025-08-18	<1.0		
40999 Cherokee Oaks	VI 2545819-1					2025-08-14	Absent		
40999 Cherokee Oaks	VI 2544934-1					2025-07-10	Absent		
40999 Cherokee Oaks	VI 2543805-1					2025-06-02	Absent		
40999 Cherokee Oaks	VI 2543239-1					2025-05-07	Absent		
40999 Cherokee Oaks	VI 2542463-1					2025-04-07	Absent		
40999 Cherokee Oaks	VI 2541690-1					2025-03-06	Absent		
40999 Cherokee Oaks	VI 2541023-1					2025-02-11	Absent		
40999 Cherokee Oaks	VI 2540036-1					2025-01-02	Absent		
41039 Meadow Dr.	VI 2543241-1					2025-05-07	<1.0		
41046 Meadow Dr.	VI 2543241-2					2025-05-07	<1.0		
41053 Meadow Dr.	VI 2546345-4					2025-09-04	<1.0		
41053 Meadow Dr.	VI 2546300-4					2025-09-03	<1.0		
41053 Meadow Dr.	VI 2545850-4					2025-08-18	<1.0		
41053 Meadow Dr.	VI 2543241-3					2025-05-07	<1.0		
Well	VI 2546345-1					2025-09-04	<1.0		
<b>Fecal coliform and E. coli</b>			0		n/a			ND	-
40992 Meadow Drive H/B	VI 2546345-3					2025-09-04	<1.0		
40992 Meadow Drive H/B	VI 2546300-3					2025-09-03	<1.0		
40992 Meadow Drive H/B	VI 2545850-3					2025-08-18	<1.0		
40999 Cherokee Oaks	VI 2548932-1					2025-12-15	Absent		
40999 Cherokee Oaks	VI 2548246-1					2025-11-20	Absent		
40999 Cherokee Oaks	VI 2547115-1					2025-10-02	Absent		
40999 Cherokee Oaks	VI 2546480-1					2025-09-10	Absent		
40999 Cherokee Oaks	VI 2546345-2					2025-09-04	<1.0		
40999 Cherokee Oaks	VI 2546300-2					2025-09-03	<1.0		
40999 Cherokee Oaks	VI 2545850-2					2025-08-18	<1.0		
40999 Cherokee Oaks	VI 2545819-1					2025-08-14	Absent		
40999 Cherokee Oaks	VI 2544934-1					2025-07-10	Absent		
40999 Cherokee Oaks	VI 2543805-1					2025-06-02	Absent		
40999 Cherokee Oaks	VI 2543239-1					2025-05-07	Absent		
40999 Cherokee Oaks	VI 2542463-1					2025-04-07	Absent		
40999 Cherokee Oaks	VI 2541690-1					2025-03-06	Absent		
40999 Cherokee Oaks	VI 2541023-1					2025-02-11	Absent		
40999 Cherokee Oaks	VI 2540036-1					2025-01-02	Absent		
41039 Meadow Dr.	VI 2543241-1					2025-05-07	<1.0		
41046 Meadow Dr.	VI 2543241-2					2025-05-07	<1.0		
41053 Meadow Dr.	VI 2546345-4					2025-09-04	<1.0		
41053 Meadow Dr.	VI 2546300-4					2025-09-03	<1.0		
41053 Meadow Dr.	VI 2545850-4					2025-08-18	<1.0		
41053 Meadow Dr.	VI 2543241-3					2025-05-07	<1.0		
Well	VI 2546345-1					2025-09-04	<1.0		

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Lead</b>		ug/L	0	15	0.2			0	5
40999 Cherokee Oaks	VI 2345278-5	ug/L				2023-08-09	ND		
41025 Meadow Dr.	VI 2345278-4	ug/L				2023-08-09	ND		
41039 Meadow Dr.	VI 2345278-3	ug/L				2023-08-09	ND		
41053 Meadow Dr.	VI 2345278-2	ug/L				2023-08-09	ND		
41075 Meadow Dr.	VI 2345278-1	ug/L				2023-08-09	ND		
<b>Copper</b>		mg/L		1.3	.3			0.105	5
40999 Cherokee Oaks	VI 2345278-5	mg/L				2023-08-09	0.10		
41025 Meadow Dr.	VI 2345278-4	mg/L				2023-08-09	0.11		
41039 Meadow Dr.	VI 2345278-3	mg/L				2023-08-09	ND		
41053 Meadow Dr.	VI 2345278-2	mg/L				2023-08-09	ND		
41075 Meadow Dr.	VI 2345278-1	mg/L				2023-08-09	0.08		

**SAMPLING RESULTS FOR SODIUM AND HARDNESS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			36	36 - 36
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	36		
<b>Hardness</b>		mg/L		none	none			256	256 - 256
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	256		

**PRIMARY DRINKING WATER STANDARDS (PDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Barium</b>		mg/L	2	1	2			0.11	0.11 - 0.11
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	0.11		
<b>Fluoride</b>		mg/L		2	1			0.1	0.1 - 0.1
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	0.1		

**SECONDARY DRINKING WATER STANDARDS (SDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			95	95 - 95
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	95		
<b>Color</b>		Units		15	n/a			7	7 - 7
WELL 01 - RAW	VI 2541691-1	Units				2025-03-06	7		
<b>Iron</b>		ug/L		300	n/a			700	700 - 700
WELL 01 - RAW	VI 2541691-1	ug/L				2025-03-06	700		
<b>Manganese</b>		ug/L		50	n/a			142	90 - 241
Well 01	VI 2548245-1	ug/L				2025-11-20	110		
Well 01	VI 2545823-1	ug/L				2025-08-14	90		
Well 01	VI 2543238-1	ug/L				2025-05-07	100		
Well 01	VI 2541025-1	ug/L				2025-02-11	170		
WELL 01 - RAW	VI 2541691-1	ug/L				2025-03-06	241		
<b>Odor Threshold at 60 °C</b>		TON		3	n/a			16	16 - 16
WELL 01 - RAW	VI 2541691-1	TON				2025-03-06	16		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			734	734 - 734
WELL 01 - RAW	VI 2541691-1	umhos/cm				2025-03-06	734		
<b>Sulfate</b>		mg/L		500	n/a			21.6	21.6 - 21.6
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	21.6		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			430	430 - 430
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	430		
<b>Turbidity</b>		NTU		5	n/a			4.7	4.7 - 4.7
WELL 01 - RAW	VI 2541691-1	NTU				2025-03-06	4.7		
<b>Zinc</b>		mg/L		5	n/a			0.03	0.03 - 0.03
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	0.03		

**UNREGULATED CONTAMINANTS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>		mg/L		NS	n/a			0.16	0.16 - 0.16
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	0.16		
<b>Manganese</b>		ug/L		NS	n/a			142	90 - 241
Well 01	VI 2548245-1	ug/L				2025-11-20	110		
Well 01	VI 2545823-1	ug/L				2025-08-14	90		
Well 01	VI 2543238-1	ug/L				2025-05-07	100		
Well 01	VI 2541025-1	ug/L				2025-02-11	170		
WELL 01 - RAW	VI 2541691-1	ug/L				2025-03-06	241		

<b>ADDITIONAL DETECTIONS</b>									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			91	91 - 91
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	91		
<b>Magnesium</b>		mg/L			n/a			7	7 - 7
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	7		
<b>pH</b>		units			n/a			7.7	7.7 - 7.7
WELL 01 - RAW	VI 2541691-1	units				2025-03-06	7.7		
<b>Alkalinity</b>		mg/L			n/a			220	220 - 220
WELL 01 - RAW	VI 2541691-1	mg/L				2025-03-06	220		
<b>Aggressiveness Index</b>					n/a			12.4	12.4 - 12.4
WELL 01 - RAW	VI 2541691-1					2025-03-06	12.4		
<b>Langelier Index</b>					n/a			0.5	0.5 - 0.5
WELL 01 - RAW	VI 2541691-1					2025-03-06	0.5		

<b>DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE</b>									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Trihalomethanes (TTHMs)</b>		ug/L		80	n/a			10	10 - 10
ST2S1 - 40999 MEADOW DR (LOT 1)	VI 2543240-1	ug/L				2025-05-07	10		
Average ST2S1 - 40999 MEADOW DR (LOT 1)								10	
<b>Chlorine</b>		mg/L		4.0	4.0			2.20	0.31 - 2.20
40992 Meadow Drive H/B	VI 2546345-3	mg/L				2025-09-04	0.31		
40992 Meadow Drive H/B	VI 2546300-3	mg/L				2025-09-03	0.35		
40992 Meadow Drive H/B	VI 2545850-3	mg/L				2025-08-18	0.48		
Average 40992 Meadow Drive H/B								0.38	
40999 Cherokee Oaks	VI 2548932-1	mg/L				2025-12-15	2.20		
40999 Cherokee Oaks	VI 2548246-1	mg/L				2025-11-20	2.20		
40999 Cherokee Oaks	VI 2547115-1	mg/L				2025-10-02	0.96		
40999 Cherokee Oaks	VI 2546480-1	mg/L				2025-09-10	0.53		
40999 Cherokee Oaks	VI 2546345-2	mg/L				2025-09-04	1.20		
40999 Cherokee Oaks	VI 2546300-2	mg/L				2025-09-03	1.35		
40999 Cherokee Oaks	VI 2545850-2	mg/L				2025-08-18	2.20		
40999 Cherokee Oaks	VI 2545819-1	mg/L				2025-08-14	1.96		
40999 Cherokee Oaks	VI 2544934-1	mg/L				2025-07-10	0.95		
40999 Cherokee Oaks	VI 2543805-1	mg/L				2025-06-02	1.35		
40999 Cherokee Oaks	VI 2543239-1	mg/L				2025-05-07	2.20		
40999 Cherokee Oaks	VI 2542463-1	mg/L				2025-04-07	1.34		
40999 Cherokee Oaks	VI 2541690-1	mg/L				2025-03-06	2.20		
40999 Cherokee Oaks	VI 2541023-1	mg/L				2025-02-11	2.18		
40999 Cherokee Oaks	VI 2540036-1	mg/L				2025-01-02	2.20		
Average 40999 Cherokee Oaks								1.67	
40999 Meadow Drive H/B	VI 2446693-2	mg/L				2024-08-19	1.84		
Average 40999 Meadow Drive H/B								1.84	
41039 Meadow Dr.	VI 2543241-1	mg/L				2025-05-07	2.20		
Average 41039 Meadow Dr.								2.2	
41046 Meadow Dr.	VI 2543241-2	mg/L				2025-05-07	2.20		



## Deer Meadow MWC CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
40992 MEADOW	VI 2545850-3	2025-08-18	Coliform	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
	VI 2545850-3	2025-08-18	Field Test	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
	VI 2546300-3	2025-09-03	Coliform	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
	VI 2546300-3	2025-09-03	Field Test	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
	VI 2546345-3	2025-09-04	Coliform	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
	VI 2546345-3	2025-09-04	Field Test	40992 Meadow Drive H/B	Deer Meadow - Special Sampling
DST_LCR	VI 2345278-5	2023-08-09	Metals, Total	40999 Cherokee Oaks	Lead & Copper Monitoring
40999 CHEROKEE	VI 2540036-1	2025-01-02	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2540036-1	2025-01-02	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2541023-1	2025-02-11	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2541023-1	2025-02-11	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2541690-1	2025-03-06	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2541690-1	2025-03-06	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2542463-1	2025-04-07	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2542463-1	2025-04-07	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2543239-1	2025-05-07	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2543239-1	2025-05-07	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2543805-1	2025-06-02	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2543805-1	2025-06-02	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2544934-1	2025-07-10	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2544934-1	2025-07-10	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2545819-1	2025-08-14	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2545819-1	2025-08-14	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2545850-2	2025-08-18	Coliform	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2545850-2	2025-08-18	Field Test	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2546300-2	2025-09-03	Field Test	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2546300-2	2025-09-03	Coliform	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2546345-2	2025-09-04	Coliform	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2546345-2	2025-09-04	Field Test	40999 Cherokee Oaks	Deer Meadow - Special Sampling
	VI 2546480-1	2025-09-10	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2546480-1	2025-09-10	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2547115-1	2025-10-02	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2547115-1	2025-10-02	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2548246-1	2025-11-20	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2548246-1	2025-11-20	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2548932-1	2025-12-15	Coliform	40999 Cherokee Oaks	Routine Water Monitoring
	VI 2548932-1	2025-12-15	Field Test	40999 Cherokee Oaks	Routine Water Monitoring
40999 MEADOW DR	VI 2446693-2	2024-08-19	Field Test	40999 Meadow Drive H/B	Drinking Water Monitoring
DST_LCR	VI 2345278-4	2023-08-09	Metals, Total	41025 Meadow Dr.	Lead & Copper Monitoring
	VI 2345278-3	2023-08-09	Metals, Total	41039 Meadow Dr.	Lead & Copper Monitoring
41039 Meadow Dr	VI 2543241-1	2025-05-07	Field Test	41039 Meadow Dr.	Dear Meadow - Bacteriological Analysis
	VI 2543241-1	2025-05-07	Coliform	41039 Meadow Dr.	Dear Meadow - Bacteriological Analysis
41046 Meadow Dr	VI 2543241-2	2025-05-07	Coliform	41046 Meadow Dr.	Dear Meadow - Bacteriological Analysis
	VI 2543241-2	2025-05-07	Field Test	41046 Meadow Dr.	Dear Meadow - Bacteriological Analysis
DST_LCR	VI 2345278-2	2023-08-09	Metals, Total	41053 Meadow Dr.	Lead & Copper Monitoring
41053 Meadow Dr	VI 2543241-3	2025-05-07	Coliform	41053 Meadow Dr.	Dear Meadow - Bacteriological Analysis
	VI 2543241-3	2025-05-07	Field Test	41053 Meadow Dr.	Dear Meadow - Bacteriological Analysis
	VI 2545850-4	2025-08-18	Field Test	41053 Meadow Dr.	Deer Meadow - Special Sampling
	VI 2545850-4	2025-08-18	Coliform	41053 Meadow Dr.	Deer Meadow - Special Sampling
	VI 2546300-4	2025-09-03	Coliform	41053 Meadow Dr.	Deer Meadow - Special Sampling

	VI 2546300-4	2025-09-03	Field Test	41053 Meadow Dr.	Deer Meadow - Special Sampling
	VI 2546345-4	2025-09-04	Coliform	41053 Meadow Dr.	Deer Meadow - Special Sampling
	VI 2546345-4	2025-09-04	Field Test	41053 Meadow Dr.	Deer Meadow - Special Sampling
DST_LCR	VI 2345278-1	2023-08-09	Metals, Total	41075 Meadow Dr.	Lead & Copper Monitoring
DBP2 ST2S1	VI 2543240-1	2025-05-07	EPA 551.1	ST2S1 - 40999 MEADOW DR (LOT 1	DBP Monitoring
	VI 2543240-1	2025-05-07	EPA 552.2	ST2S1 - 40999 MEADOW DR (LOT 1	DBP Monitoring
WELL TAP	VI 2546345-1	2025-09-04	Coliform	Well	Deer Meadow - Special Sampling
STW-1	VI 2541025-1	2025-02-11	Metals, Total	Well 01	Well 01 - Mn Monitoring
	VI 2543238-1	2025-05-07	Metals, Total	Well 01	Well 01 - Mn Monitoring
	VI 2545823-1	2025-08-14	Metals, Total	Well 01	Well 01 - Mn Monitoring
	VI 2548245-1	2025-11-20	Metals, Total	Well 01	Well 01 - Mn Monitoring
	VI 2541691-1	2025-03-06	General Mineral	WELL 01 - RAW	Well 01-Water Quality
	VI 2541691-1	2025-03-06	Metals, Total	WELL 01 - RAW	Well 01-Water Quality
	VI 2541691-1	2025-03-06	Wet Chemistry	WELL 01 - RAW	Well 01-Water Quality