

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **MONSON WATER SYSTEM**

Water System Number: **5403212**

The water system above hereby certifies that its Consumer Confidence Report was distributed on June 30, 2020 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name Cedric Perez
Signature [Signature]
Title General Manager
Phone Number 551 730-8035 Date June 30, 2020

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

☐ Posted the CCR on the internet at <http://> _____

☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertised the availability of the CCR in news media (attach a copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

☒ Posted the CCR in public places (attach a list of locations) Sultana Post Office

☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2019 Consumer Confidence Report

Water System Name: MONSON WATER SYSTEM

Report Date: May 2020

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): WELL 01

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at Monson-School District 10643 Ave. 416 Dinuba, Ca. 93618 every first Thursday of each month.

For more information about this report, or any questions relating to your drinking water, please call (559) 458 - 6144 and ask for Jose Padilla.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Hardness (mg/L)	(2019)	83.7	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (mg/L)	(2019)	2.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019)	1.53	ND - 3.50	15	(0)	Erosion of natural deposits.
Total Radium 228 (pCi/L)	(2019)	ND	ND - 1.97	5	n/a	Erosion of natural deposits

Table 3 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2019)	22	n/a	n/a	n/a
Magnesium (mg/L)	(2019)	7	n/a	n/a	n/a

Table 4 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2019)	0.37	0.13 - 0.64	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Sultana Community Serv. Dist* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2019 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment has not been completed for the WELL 01 of the MONSON WATER SYSTEM.

WELL 01 - does not have an assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Sultana Community Serv. Dist

Analytical Results By FGL - 2019

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Hardness		mg/L		none	none			83.7	83.7 - 83.7
WELL 01	VI 1941396-1	mg/L				2019-03-29	83.7		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate as N		mg/L		10	10			2.5	2.5 - 2.5
WELL 01	VI 1941398-1	mg/L				2019-03-29	2.5		
Gross Alpha		pCi/L		15	(0)			1.530	ND - 3.50
WELL 01	VI 1947742-1	pCi/L				2019-12-17	1.41		
WELL 01	VI 1945097-1	pCi/L				2019-09-06	1.21		
WELL 01	VI 1943067-1	pCi/L				2019-06-20	3.50		
WELL 01	VI 1941394-1	pCi/L				2019-03-29	ND		
Total Radium 228		pCi/L	0.019	5	n/a			ND	ND - 1.97
WELL 01	VI 1947742-1	pCi/L				2019-12-17	ND		
WELL 01	VI 1945097-1	pCi/L				2019-09-06	1.97		
WELL 01	VI 1943067-1	pCi/L				2019-06-20	ND		
WELL 01	VI 1941394-1	pCi/L				2019-03-29	ND		
WELL 01	VI 1941393-1	pCi/L				2019-03-29	ND		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			22	22 - 22
WELL 01	VI 1941396-1	mg/L				2019-03-29	22		
Magnesium		mg/L			n/a			7	7 - 7
WELL 01	VI 1941396-1	mg/L				2019-03-29	7		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			0.37	0.13 - 0.64
Monson Hyd #3	VI 1947740-1	mg/L				2019-12-17	0.20		
Monson Hyd #3	VI 1946542-1	mg/L				2019-11-04	.23		
Monson Hyd #3	VI 1946298-1	mg/L				2019-10-23	0.56		
Monson Hyd #3	VI 1945095-1	mg/L				2019-09-06	.14		
Monson Hyd #3	VI 1944320-1	mg/L				2019-08-13	0.13		
Monson Hyd #3	VI 1943907-1	mg/L				2019-07-26	0.23		
Monson Hyd #3	VI 1943065-1	mg/L				2019-06-20	0.43		
Monson Hyd #3	VI 1942397-1	mg/L				2019-05-23	0.38		
Monson Hyd #3	VI 1942291-1	mg/L				2019-05-21	0.43		
Monson Hyd #3	VI 1941522-2	mg/L				2019-04-09	0.54		
Monson Hyd #3	VI 1941114-1	mg/L				2019-03-15	0.64		
Monson Hyd #3	VI 1940739-1	mg/L				2019-02-22	0.41		
Monson Hyd #3	VI 1940060-1	mg/L				2019-01-07	0.52		
Average Monson Hyd #3								0.37	

Sultana Community Serv. Dist

CCR Login Linkage - 2019

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
10507 Ave 388	VI 1943342-7	2019-07-05	Metals, Total	10507 Ave 388	Monson - Lead & Copper
10587 Lewis Dr.	VI 1943342-3	2019-07-05	Metals, Total	10587 Lewis Dr.	Monson - Lead & Copper
10591 Lewis Dr.	VI 1943342-2	2019-07-05	Metals, Total	10591 Lewis Dr.	Monson - Lead & Copper
38660 Monson Dr	VI 1943342-9	2019-07-05	Metals, Total	38660 Monson Dr.	Monson - Lead & Copper
38668 Monson Dr	VI 1943342-10	2019-07-05	Metals, Total	38668 Monson Dr.	Monson - Lead & Copper
38686 Monson Dr	VI 1943342-1	2019-07-05	Metals, Total	38686 Monson Dr.	Monson - Lead & Copper
38734 Monson Dr	VI 1943342-8	2019-07-05	Metals, Total	38734 Monson Dr.	Monson - Lead & Copper
38737 Campbell	VI 1943342-5	2019-07-05	Metals, Total	38737 Campbell Dr.	Monson - Lead & Copper
38769 Campbell	VI 1943342-4	2019-07-05	Metals, Total	38769 Campbell Dr.	Monson - Lead & Copper
38795 Campbell	VI 1943342-6	2019-07-05	Metals, Total	38795 Campbell Dr.	Monson - Lead & Copper
Hydrant #2	VI 1942644-5	2019-06-05	Coliform	Hydrant #2	Monson
	VI 1947963-1	2019-12-27	Coliform	Hydrant #2	Monson
Hydrant #3	VI 1947963-2	2019-12-27	Coliform	Hydrant #3	Monson
Hydrant #4	VI 1942644-3	2019-06-05	Coliform	Hydrant #4	Monson
	VI 1947963-3	2019-12-27	Coliform	Hydrant #4	Monson
Hydrant #5	VI 1947963-4	2019-12-27	Coliform	Hydrant #5	Monson
Hydrant in Alle	VI 1947963-5	2019-12-27	Coliform	Hydrant in Alley	Monson
Hydrant in Ally	VI 1942644-1	2019-06-05	Coliform	Hydrant in Ally	Monson
10678 Simpson R	VI 1842736-10	2018-06-08	Metals, Total	M-10678 Simpson Rd.	Monson Residents
38660 Monson Dr	VI 1842736-8	2018-06-08	Metals, Total	M-38660 Monson Dr.	Monson Residents
38686 Monson Dr	VI 1842736-7	2018-06-08	Metals, Total	M-38686 Monson Dr.	Monson Residents
MONSON HYD 3	VI 1940060-1	2019-01-07	Coliform	Monson Hyd #3	Monson
	VI 1940060-1	2019-01-07	Field Test	Monson Hyd #3	Monson
	VI 1940739-1	2019-02-22	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1940739-1	2019-02-22	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1941114-1	2019-03-15	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1941114-1	2019-03-15	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1941522-2	2019-04-09	Field Test	Monson Hyd #3	Drinking Water Monitoring
	VI 1941522-2	2019-04-09	Coliform	Monson Hyd #3	Drinking Water Monitoring
	VI 1942291-1	2019-05-21	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1942291-1	2019-05-21	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1942397-1	2019-05-23	Coliform	Monson Hyd #3	Drinking Water Monitoring
	VI 1942397-1	2019-05-23	Field Test	Monson Hyd #3	Drinking Water Monitoring
	VI 1942644-4	2019-06-05	Coliform	Monson Hyd #3	Monson
	VI 1943065-1	2019-06-20	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1943065-1	2019-06-20	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1943907-1	2019-07-26	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1943907-1	2019-07-26	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1944320-1	2019-08-13	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1944320-1	2019-08-13	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1945095-1	2019-09-06	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1945095-1	2019-09-06	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1946298-1	2019-10-23	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1946298-1	2019-10-23	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1946542-1	2019-11-04	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1946542-1	2019-11-04	Field Test	Monson Hyd #3	Monson - Routine Monitoring
	VI 1947740-1	2019-12-17	Coliform	Monson Hyd #3	Monson - Routine Monitoring
	VI 1947740-1	2019-12-17	Field Test	Monson Hyd #3	Monson - Routine Monitoring
MONSON HYD 5	VI 1942644-2	2019-06-05	Coliform	Monson Hyd #5	Monson
Water Fill Stat	VI 1945096-1	2019-09-06	Coliform	Water Fill Station	Water Fill Station - Monson
Well	VI 1742919-1	2017-06-26	Sub Contracted	WELL 01	Drinking Water Monitoring
MONSON WELL (RA	VI 1941393-1	2019-03-29	Radio Chemistry	WELL 01	Sultana CSD Well 03-Radio Monitoring
	VI 1941398-1	2019-03-29	Wet Chemistry	WELL 01	Monson Water-Well 01 Water Quality Monitoring

	VI 1941396-1	2019-03-29	Metals, Total	WELL 01	Monson Water-Well 01 Hardness Monitoring - Special
	VI 1941394-1	2019-03-29	Radio Chemistry	WELL 01	Monson Water-Well 01 Radio Monitoring
	VI 1943067-1	2019-06-20	Radio Chemistry	WELL 01	Monson Water-Well 01 Radio Monitoring
	VI 1945097-1	2019-09-06	Radio Chemistry	WELL 01	Monson Water-Well 01 Radio Monitoring
	VI 1947742-1	2019-12-17	Radio Chemistry	WELL 01	Monson Water-Well 01 Radio Monitoring