

APPENDIX F: Certification Form (Suggested Format)

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Water Board's website at

http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	Cutter Public Utility District
Water System Number:	541001

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5/25/2023 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	Name:	Dionicio Rodriguez Jr.	
	Signature:	<i>Dionicio Rodriguez Jr.</i>	
	Title:	Superintendent	
	Phone Number:	(559) 528-3859	Date: 5/25/2023

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: May 25, 2023

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- Posting the CCR on the Internet at www.
- Mailing the CCR to postal patrons within the service area (attach zip codes used)
- Advertising the availability of the CCR in news media (attach copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

*Instructions for Small Water Systems Appendix F
Revised February 2021*

- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)
- For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following address: www. _____
- For investor-owned utilities:* Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

2022 Annual Drinking Water Quality Report

Cutler Public Utility District

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2022 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. Usted puede recoger una copia en español del informe de confianza del consumidor de 2022 en la oficina del distrito.

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water. Our water source comes from five groundwater wells: Well Nos. 5 and 9 are currently active. Well Nos. 3 and 4 are presently inactive and have not been pumped in several years due to high levels of nitrates which were previously observed. Well No. 6 is in a standby mode and will only be pumped in the event of a fire or low pressure situation. The District will have to notify customers if this well is utilized due to the level of DBCP in the water from the well. Continuous chlorination is provided on all wells. Projects are currently being worked on to:

- (a) Equip Well No. 10 to improve the available water supply (permanent well has been completed);
- (b) Connect new pressure tanks to address pressure issues; and
- (c) Connect a new storage tank to address supply needs (storage tank has been completed).

A preliminary study on providing treated surface water to the District was completed in 2017. Additional investigations on this alternate source of supply are ongoing.

A source water assessment was conducted for the water supply wells of the Cutler Public Utility District water system in February, 2003. The sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply: fertilizer, pesticide and/or herbicide applications. The sources are considered most vulnerable to the following activities not associated with any detected contaminants: automobile gas stations; chemical and/or petroleum processing and/or petroleum storage; and historic gas stations. A copy of the complete assessment may be viewed at: Cutler Public Utility District, 40526 Orosi Drive, Cutler, CA 93615. If you would like a summary of the assessment sent to you or if you have any questions about this report or concerning your water utility, please contact Mr. Dionicio Rodriguez Jr., Superintendent, at (559)528-3859.

We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the third Tuesday of each month at 6:00 p.m., in the Cutler Public Utility District Conference Room at 40526 Orosi Drive in Cutler.

The following are definitions of some of the TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs, MRDLs and treatment techniques (TT) for contaminants that affect health along with their monitoring and reporting requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

N/A: Not applicable

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

In general, sources of drinking water (both tap water and bottled water) may include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Constituents that may be present in source water to contamination levels include:

- **Microbial contaminants** such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.
- **Radioactive contaminants** that can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board – Division of Drinking Water (DDW) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. DDW regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cutler Public Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Tables below and on the following page(s), list all the drinking water constituents that were detected during the most recent samplings for the constituent. The presence of these constituents in the water does not necessarily indicate that the water poses a health risk. The DDW requires us to monitor for certain constituents less than once per year because the concentrations of these constituents are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are therefore more than one year old.

SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants			MCL	MCLG	Typical Source of Contamination
Water Supply (Distribution System)	Highest No. of detections	No. of months in violation			
E. coli	(In the year) 0	0	(a)	0	Human and animal fecal waste
Water Source (Groundwater Wells)	Total No. of detections	Sample Dates (of Detections)			
E. coli	(In the year) 0	Not Applicable	0	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E.coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.

E. Coli/Fecal Coliform: E. coli/Fecal coliforms are bacteria whose presence indicate that water may be contaminated with human or animal wastes.

Total Coliform: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

The District collects 9 to 11 samples each month in the water supply (distribution) system. The District collects monthly samples at each operational water well (source).

TEST RESULTS (A)							
Lead and Copper Rule	No. of samples collected	MCLG	Action Level	90 th percentile level detected	No. Sites Exceeding Action Level	Number of Schools Requesting Lead Sampling	Typical Source of Contamination
Lead (ppb) 2021	20	2	15	ND	0	2 (Completed in 2018)	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 2021	20	0.3	1.3	0.18	0	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Constituent	MCL	PHG [MCLG]	Sample Date	Average Level Detected	Range	Typical Source of Contamination
Hardness (ppm)	None	None	7/29/2022	215	170 to 260	Generally found in ground and surface water
Sodium (ppm)	None	None	7/29/2022	31	26 to 36	Generally found in ground and surface water

DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Constituent	MCL	PHG [MCLG]	Sample Date	Average Level Detected	Range (B)	Typical Source of Contamination
Arsenic (As)	10	10	7/26/2022	2.1	2.0 to 2.1 (C)	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	1	2	7/29/2022	0.13	0.10 to 0.16	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2	1	7/29/2022	0.15	N/A	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as N (ppm)	10	10	2022	7.1	4.6 to 10.0 (D)	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

RADIOACTIVE CONTAMINANTS						
Constituent	MCL	PHG (MCLG)	Sample Date	Level Detected	Range	Typical Source of Contamination
Gross Alpha Activity (pCi/L)	15	(0)	2015/2020	4.1	ND TO 5.21	Erosion of natural deposits
Uranium (pCi/L)	20	1.0	11/13/2020	1.7	N/A	Erosion of natural deposits

DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Constituent	MCL	Sample Date	Average Level Detected	Range (B)	Typical Source of Contamination	
Chloride (ppm)	500	7/29/2022	29.5	20 to 39	Runoff/leaching from natural deposits; seawater influence	
Manganese (ppb)	50	7/29/2022	17	ND to 14	Leaching from natural deposits	
Specific Conductance (µS/cm)	1600	7/29/2022	555	440 to 670	Substances that form ions when in water; seawater influence	
Sulfate (ppm)	500	7/29/2022	22	12 to 32	Runoff/leaching from natural deposits; industrial wastes	
Total Dissolved Solids (TDS)(ppm)	1000	7/29/2022	375	300 to 450	Runoff/leaching from natural deposits	
Turbidity (Units)	5	7/29/2022	0.53	0.23 to 0.83	Soil runoff	

DETECTION OF SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES & HERBICIDES						
Constituent	MCL	PHG [MCLG]	Sample Date	Average Level Detected	Range (B)	Typical Source of Contamination
Dibromochloropropane (DBCP) (ppt)	200	1.7	2022	42	ND to 94	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Trichloropropane (E) (1,2,3-TCP) (ppt)	5	0.7	2022	5.3 (E)	4.3 to 6.7 (E)	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides

- (A) Results reported due to regulatory requirement or detection of a constituent.
- (B) Results reported include amounts that are less than the State Water Resources Control Board – Division of Drinking Water (DDW) required detection level for this contaminant.
- (C) ABOUT ARSENIC: While your drinking water meets the current EPA standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. The USEPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.
- (D) ABOUT NITRATE: Nitrate in drinking water at levels above 10 mg/L (as N) is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels as N that are above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.
- (E) ABOUT 1,2,3-TCP: Some people who drink water containing 1,2,3-trichloropropane (1,2,3-TCP) in excess of the MCL over many years may have an increased risk of getting cancer. 1,2,3-TCP had a notification level (NL) of 5 ppt until December 14, 2017, when the MCL of 5 ppt became effective. In August, 2022, the SWRCB issued a Compliance Order to address the MCL violation. The District submitted its Corrective Action Plan to address the Compliance Order in December, 2022. Quarterly public notification regarding the MCL violation is underway.

DISINFECTION BYPRODUCTS AND DISINFECTANT RESIDUALS							
Chemical or Constituent (and reporting units)	MCL [MRDL]	PHG	MCLG [MRDLG]	Sample Date	Running Annual Average	Range	Major Sources in Drinking Water
TTHM [Total Trihalomethanes] (ppb)	80	N/A	N/A	8/22/2022	< 4.3	N/A	Byproduct of drinking water chlorination
HAA5 [Haloacetic Acids] (ppb)	60	N/A	N/A	8/22/2022	< 6.1	N/A	Byproduct of drinking water disinfection
Chlorine as CL2 (ppm)	[4.0]	N/A	[4]	2022	0.45	0.30 to 0.62	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose or stomach discomfort

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that the water poses a health risk. More information about constituents, contaminant levels and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1/800/426-4791 or their website <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1/800/426-4791.