

## 2021 Annual Drinking Water Quality Report

### TONYVILLE SYSTEM

LINDSAY-STRAITHMORE IRRIGATION DISTRICT

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2021 and may include earlier monitoring data.

**Este informe contiene información muy importante sobre su agua de beber.  
Tradúzcalo ó hable con alguien que lo entienda bien.**

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water. Our water source comes from surface water and groundwater wells. Our surface water comes from the Friant Kern Canal. The well water is chlorinated. Surface water treatment is by conventional filtration with chlorination.

A source water assessment was conducted for the water supply wells and surface water source of the Lindsay Strathmore Irrigation District water system in February 2003. Typically, the District uses groundwater as a source of supply to augment the surface water supply during the summer months with high demand and to meet systems needs when the Friant-Kern Canal (Canal) is shut down for maintenance and repair. The period of time that the system relies only on groundwater, during maintenance of the Canal, is short and, therefore, the customer's exposure to any contaminants is for a short period. In 2021, the water supply primarily consisted of surface water. Groundwater was used in January and February, 2022 during Canal maintenance activities. The well water source is considered most vulnerable to the following activities associated with contaminants detected in the water supply: fertilizer, pesticide and/or herbicide applications. The water source is considered most vulnerable to the following activities not associated with any detected contaminants: automobile gas stations; septic systems – low density; sewer collection systems; agricultural/irrigation wells; and wastewater treatment plants and disposal facilities. A sanitary survey report for the Friant-Kern Canal water supply has also been completed. An update to this report was completed in 2019. A copy of the complete assessment and sanitary survey report may be viewed at: Lindsay Strathmore Irrigation District, 23260 Round Valley Road, Lindsay, CA 93247. If you would like a summary of the assessment and sanitary survey sent to you or if you have any questions about this report or concerning your water utility, please contact Mr. Craig Wallace, General Manager, at 559/562-2581.

We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the 2<sup>nd</sup> Tuesday of each month at 1:30 p.m., at the District office located at 23260 Round Valley Road, Lindsay, California.

The following are definitions of some of the TERMS USED IN THIS REPORT:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs, MRDLs and treatment techniques (TT) for contaminants that affect health along with their monitoring and reporting requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**N/A:** Not applicable

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**In general, sources of drinking water** (both tap water and bottled water) may include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

**In order to ensure that tap water is safe to drink,** the U. S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board – Division of Drinking Water (DDW) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. DDW regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**If present, elevated levels of lead can cause serious health problems,** especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lindsay-Strathmore Irrigation District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

and development of the fetus, as well as for normal growth and development in the infant and child. In adults, thyroid hormones are needed for normal metabolism and mental function.

- (G) ABOUT SECONDARY DRINKING WATER STANDARDS: Iron and Manganese were found at levels exceeding the Secondary MCLs. These MCLs are set to protect you against unpleasant aesthetic affects such as color, taste, odor or appearance of drinking water. The elevated levels are typically due to naturally occurring organic materials and/or leaching of natural deposits.
- (H) ABOUT 1,2,3-TCP: Some people who drink water containing 1,2,3-trichloropropane (1,2,3-TCP) in excess of the MCL over many years may have an increased risk of getting cancer. 1,2,3-TCP had a notification level (NL) of 5 ppt until December 14, 2017, when the MCL of 5 ppt became effective. We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.
- (I) ABOUT TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney or central nervous system problems, and may have an increased risk of getting cancer.

#### Additional General Information on Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that the water poses a health risk. More information about constituents, contaminant levels and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1/800/426-4791 or their website <http://www.epa.gov/safewater/hfacts.html>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1/800/426-4791.

The tables below and on the following page lists all the drinking water constituents that were detected during the most recent samplings for the constituent. The presence of these constituents in the water does not necessarily indicate that the water poses a health risk. The DDW requires us to monitor for certain constituents less than once per year because the concentrations of these constituents are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are therefore more than one year old.

| SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES  |   |   |                               |  |
|--|---|---|-------------------------------|--|
| Treatment Technique  | Turbidity Performance Standards (TPS)   | Lowest monthly percentage of samples that met TPS | Number of Months in Violation | Highest single turbidity measurement during the year |
| Conventional Filtration Treatment with Chlorination  | Turbidity of the filtered water must: Be less than or equal to 0.3 NTU in 95% of measurements in a month. | 100%  | 0                             | 0.29   |
| Turbidity (measured in NTU) is a measurement of the cloudiness of water and is an indicator of filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements. |   |   |                               |  |

| TEST RESULTS (A)     |                          |      |              |  |                                  |  |   |
|----------------------|--------------------------|------|--------------|--|----------------------------------|--|---|
| Lead and Copper Rule | No. of samples collected | MCLG | Action Level | 90 <sup>th</sup> percentile level detected | No. Sites Exceeding Action Level | Number of Schools Requesting Lead Sampling | Typical Source of Contamination   |
| Lead (ppb) 2021      | 5                        | 2    | 15           | ND   | 0                                | N/A (No schools served by District)        | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) 2021    | 5                        | 0.3  | 1.3          | ND   | 0                                | N/A  | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

| RADIOACTIVE CONTAMINANTS                      |              |            |                     |                                     |              |                                 |
|---|--------------|------------|---------------------|-------------------------------------|--------------|---------------------------------|
| Chemical or Constituent (and reporting units) | MCL          | PHG (MCLG) | Sample Date         | Weighted Average Level Detected (B) | Range (C)    | Typical Source of Contamination |
| Gross Alpha Activity (pCi/L)                  | 15           | N/A        | 2018/2020/2021      | 2.4                                 | 2.23 to 5.54 | Erosion of natural deposits     |
| Radium 228 (pCi/L)                            | 5 (combined) | 1          | 2011/2020/2021      | 1.0                                 | ND to 1.01   | Erosion of natural deposits     |
| Uranium (pCi/L)                               | 20           | 0.43       | 2001/2002/2008/2021 | 0.94                                | 0.7 to 8.7   | Erosion of natural deposits     |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS      |      |            |                |                                     |           |   |
|---|------|------------|----------------|-------------------------------------|-----------|---|
| Chemical or Constituent (and reporting units) | MCL  | PHG (MCLG) | Sample Date    | Weighted Average Level Detected (B) | Range     | Typical Source of Contamination             |
| Hardness (ppm)                                | None | None       | 2019/2020/2021 | 32                                  | 11 to 350 | Generally found in ground and surface water |
| Sodium (ppm)                                  | None | None       | 2020/2021      | 10                                  | 3.5 to 90 | Generally found in ground and surface water |

| DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD |          |            |             |                                     |                |  |
|--|----------|------------|-------------|-------------------------------------|----------------|--|
| Chemical or Constituent (and reporting units)                    | MCL      | PHG [MCLG] | Sample Date | Weighted Average Level Detected (B) | Range (C)      | Typical Source of Contamination  |
| Aluminum (ppb)   | 1000     | 50         | 2020/2021   | 56.4                                | ND to 340      | Erosion of natural deposits  |
| Arsenic (ppb)  | 10       | 0.004      | 2021        | 2.2                                 | ND to 9.1      | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes               |
| Barium (ppb)   | 1000     | 100        | 2020/2021   | 100                                 | ND to 130      | Discharges of oil drilling wastes; erosion of natural deposits   |
| Chromium, Total (ppb)  | 50       | 10         | 2020/2021   | 10                                  | ND to 31       | Erosion of natural deposits  |
| Hexavalent Chromium (Chromium-6) (ppb)                           | None (D) | 0.02       | 2014/2021   | 1.4                                 | ND to 8.4      | See Note (D)   |
| Flouride (ppm)   | 2.0      | 0.01       | 2020/2021   | 0.03                                | ND to 0.24     | Erosion of natural deposits  |
| Nitrate as N (ppm)   | 10       | 10         | 2021        | 1.3                                 | 0.23 to 14 (E) | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Perchlorate (ppb)  | 6        | 4          | 2021        | 4.3                                 | ND to 11 (F)   | Contamination from industrial operations   |

| DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD |      |             |                                     |                |   |
|--|------|-------------|-------------------------------------|----------------|---|
| Chemical or Constituent (and reporting units)                      | MCL  | Sample Date | Weighted Average Level Detected (B) | Range (C)      | Typical Source of Contamination                             |
| Chloride (ppm)   | 500  | 2020/2021   | 10                                  | 2.4 to 140     | Runoff/leaching from natural deposits                       |
| Color (Units)  | 15   | 2020/2021   | 10                                  | ND to 15       | Naturally-occurring organic materials                       |
| Iron (ppb)   | 300  | 2020/2021   | 129                                 | ND to 1500 (G) | Leaching from natural deposits                              |
| Odor (Units)   | 3    | 2020/2021   | 1                                   | ND to 1        | Naturally-occurring organic materials                       |
| Manganese (ppb)  | 50   | 2020/2021   | 22                                  | ND to 110 (G)  | Leaching from natural deposits                              |
| Specific Conductance (µS/cm)                                       | 1600 | 2021        | 109                                 | 43 to 1000     | Substances that form ions when in water; seawater influence |
| Sulfate (ppm)  | 500  | 2020/2021   | 6.5                                 | 1.2 to 93      | Runoff/leaching from natural deposits                       |
| Total Dissolved Solids (TDS) (ppm)                                 | 1000 | 2020/2021   | 74                                  | 31 to 660      | Runoff/leaching from natural deposits                       |
| Turbidity (Units)  | 5    | 2020/2021   | 1.3                                 | 0.12 to 3.2    | Soil runoff   |

| DETECTION OF SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES & HERBICIDES |     |            |             |                        |       |  |
|---|-----|------------|-------------|------------------------|-------|--|
| Constituent   | MCL | PHG [MCLG] | Sample Date | Average Level Detected | Range | Typical Source of Contamination  |
| Trichloropropane (H) (1,2,3-TCP) (ppt)  | 5   | 0.7        | 2020/2021   | ND                     | N/A   | Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides. |

| Disinfection Byproducts and Disinfectant Residuals |            |     |              |             |                        |                  |  |
|--|------------|-----|--------------|-------------|------------------------|------------------|--|
| Chemical or Constituent (and reporting units)      | MCL [MRDL] | PHG | MCLG [MRDLG] | Sample Date | Running Annual Average | Range (C)        | Major Sources in Drinking Water  |
| TTHM (I) [Total Trihalomethanes] (ppb)             | 80         | N/A | N/A          | 2021        | 61.4                   | 22.3 to 84.5 (I) | Byproduct of drinking water chlorination   |
| HAA5 [Haloacetic Acids] (ppb)                      | 60         | N/A | N/A          | 2021        | 27.6                   | 8.8 to 41.2      | Byproduct of drinking water disinfection   |
| Chlorine as Cl <sub>2</sub> (ppm)                  | [4.0]      | N/A | [4]          | 2021        | 0.95                   | 0.6 to 1.0       | Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose or stomach discomfort. |

| Disinfection Byproduct Precursors |     |      |            |                                     |
|-----------------------------------|-----|------|------------|-------------------------------------|
| Control of DBP precursors (TOC)   | MCL | MCLG | Range      | Major Sources in Drinking Water     |
| Source Water                      | TT  | N/A  | 0.2 to 2.0 | Various natural and manmade sources |
| Treated Water                     | TT  | N/A  | 0.2 to 1.5 | Various natural and manmade sources |

- (A) Results reported due to regulatory requirement or detection of a constituent.
- (B) The weighted average reflects the quantity of water provided from each source of supply, be it groundwater (wells) and/or surface water along with the representative concentration for a particular constituent.
- (C) Results reported include amounts that are less than the State Water Resources Control Board – Division of Drinking Water required detection level for this constituent.
- (D) ABOUT HEXAVALENT CHROMIUM: Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer. There is currently no MCL for hexavalent chromium. The previous MCL of 0.010 mg/L (10 ppb) was withdrawn on September 11, 2017. Much of the low level hexavalent chromium found in drinking water is naturally occurring, reflecting its presence in geological formations throughout the State. However, there are areas of contamination in California from historic industrial use such as the manufacturing of textile dyes, wood preservation, leather tanning and anti-corrosion coatings, where hexavalent chromium contaminated waste has migrated into the underlying groundwater.
- (E) ABOUT NITRATE: Nitrate in drinking water at levels above 10 mg/L (as N) is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels as N that are above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.
- (F) ABOUT PERCHLORATE: Perchlorate has been shown to interfere with uptake of iodide by the thyroid gland and to thereby reduce the production of thyroid hormones, leading to adverse effects associated with inadequate hormone levels. Thyroid hormones are needed for normal prenatal growth