

# SONORA MEADOWS MUTUAL WATER COMPANY

System No. 5510023

## Quarterly Report for Disinfectant/Chlorine Residuals Compliance - 2019

Quarter 1	Quarter 2	Quarter 3	Quarter 4	4.0 Maximum			
1.03	0.97	1.13	1.13	Meets Compliance	Yes	x	No

Measured in milligrams per liter (mg/L)

## Quarterly TTHM Report for Disinfection Byproducts Compliance - 2019

Site	Quarter 1	Quarter 2	Quarter 3	Quarter 4	80.0 Maximum			
900	34.9	61.4	26.7	30.6	Meets Standards	Yes	x	No
901	23.3	50.6	24.6	26.3	Meets Standards	Yes	x	No
Site 900 OEL	42.4	47.8	37.4	37.3				
Site 900 LRAA	43.4	49.0	39.1	38.4				
Site 901 OEL	29.4	38.2	30.8	32.0				
Site 901 LRAA	33.1	36.2	31.7	31.2				

Measured in milligrams per liter (mg/L)

## Quarterly HAA5's Report for Disinfection Byproducts Compliance - 2019

Site	Quarter 1	Quarter 2	Quarter 3	Quarter 4	60.0 Maximum			
900	71.3	54.7	30.6	28.3	Meets Standards	Yes	x	No
901	40.3	43.7	34.3	28.8	Meets Standards	Yes	x	No
Site 900 OEL	57.5	55.4	46.8	35.5				
Site 900 LRAA	50.8	53.4	49.4	46.2				
Site 901 OEL	38.1	40.1	38.2	33.9				
Site 901 LRAA	37.8	39.0	37.8	36.8				

Measured in milligrams per liter (mg/L)

OEL = Operational Evaluation Level

LRAA = Locational Running Annual Average

## LEAD AND COPPER SAMPLING REPORT - 2018 NEXT SAMPLES 2021

For a copy of the Annual Water Quality Report for 2019, please see:

[https://tudwater.com/wp-content/uploads/2020/06/TUD-Annual-Water-Quality-Report\\_2019-Release-June\\_2020.pdf](https://tudwater.com/wp-content/uploads/2020/06/TUD-Annual-Water-Quality-Report_2019-Release-June_2020.pdf)