

**SONORA WATER COMPANY INC.**

**Attachment to CCR Requirements**

Dated: April 1, 2021

System: 55-10024

Listing of Zip Codes for mailings of Consumer Confidence Report

95327	Jamestown, CA
95370	Sonora, CA
97034	Lake Oswego, Oregon
94030	Millbrea, CA
92660	Newport Beach, CA
95678	Roseville, CA
95337	Manteca, CA
94110	San Francisco, CA
95363	Patterson, CA
92648	Huntington Beach, CA
93291	Visalia, CA



---

Beverly Brown, General Manager

**SONORA WATER COMPANY****WATER QUALITY REPORT FOR 2020  
TESTING YEAR 2020**

Each year, Sonora Water Co. is required to provide to its customer's information concerning the testing and treatment of water provided. As Sonora Water Co. purchases all water from Tuolumne Utilities District and does not "treat" said water, it is still required to have certain testings of that water and provide all information. Below we have provided information from TUD for the "Sonora Area", from which Sonora Water Co. receives its water.

Should you desire to examine the entire report, you may go to the website of TUD and do so.

**Regulated Substances:**

	<b>REPORTING</b>	<b>ANALYSES</b>	<b>DLR</b>	<b>MCL</b>
<b>CHEMICAL</b>	<b>UNITS</b>	<b>RESULTS</b>		
1 Hardness (Total) as CaCO <sub>3</sub>	mg/L	22.0		
2 Calcium (CA)	mg/L	6.1		
3 Magnesium (Mg)	mg/L	1.5		
4 Sodium (Na)	mg/L	5.5		
6 Potassium (K)	mg/L	<2.0		
<b>Total Cations</b>		0.67		
7 Alkalinity (Total) (as CaCO <sub>3</sub> )	mg/L	25.0		
8 Hydroxide (OH)	mg/L	<1.0		
9 Carbonate (CO <sub>3</sub> )	mg/L	<1.8		
10 Bicarbonate (HCO <sub>3</sub> )	mg/L	31.0		
11 Sulfate (SO <sub>4</sub> )	mg/L	1.3	0.5	500
12 Chloride (Cl)	mg/L	4.8		500
13 Nitrate as Nitrogen (N)	mg/L	ND	0.4	10
14 Fluoride (F) Natural Source	mg/L	ND	0.01	2
<b>Total Anions</b>		0.67		
15 Color, Apparent (Unfiltered)	Units	.50		15
Foaming Agents (MBAWS)	mg/L	<0.050		0.5
17 Turbidity, Laboratory	NTU	0.3		5
18 Aluminum (Al)	ug/L	ND	50	1000
19 Antimony	ug/L	ND	6	6
20 Arsenic (As)	ug/L	ND	2	10
21 Barium (Ba)	ug/L	ND	100	1000
22 Beryllium	ug/L	ND	1	4
23 Cadmium (Cd)	ug/L	ND	1	5
24 Chromium (Total Cr)	ug/L	ND	10	50
25 Copper (Cu)	ug/L	ND	50	100
26 Iron (Fe)	ug/L	ND	100	300
27 Lead (Pb)	ug/L	ND	5	
28 Manganese (Mn)	ug/L	33	20	50
29 Mercury (Hg)	ug/L	ND	1	2
30 Nickel	ug/L	ND	10	100
31 Selenium (se)	ug/L	ND	5	50
32 Silver (Ag)	ug/L	ND	10	100
33 Thallium	ug/L	ND	1	2
34 Zinc (Zn)	ug/L	ND	50	5000

Conitnue on Reverse Side