



**CALIFORNIA DEPARTMENT OF
FORESTRY AND FIRE PROTECTION**

2025

**ANNUAL
WATER QUALITY
REPORT
OR
CCR**

BASELINE FIRE CENTER

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	CAL FIRE BASELINE CONSERVATION CAMP
Water System Number:	CA5510852

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	BRIAN WEST	
	Signature:	B	
	Title:	WASPO CPO	
	Phone Number:	(209) 813-6102	Date: 7/29/26

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
Posted in OFFICES AND common AREAS AROUND the Facility.

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2025 Consumer Confidence Report

Water System Name: CAL FIRE BASELINE CONSERVATION CAMP

Report Date: April 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Surface Water

Your water comes from 1 source(s): TULLOCH RESERVOIR - RAW
and from 1 treated location(s): BASELINE WTP (WATER BOY) - TRE

Opportunities for public participation in decisions that affect drinking water quality: Baseline Camp

For more information about this report, or any questions relating to your drinking water, please call (209)419-4443 and ask for Brian West.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7, 8 and 9 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2025)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2025)	2	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2025)	23.2	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2025)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD
--

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2025)	2	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2025)	5	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2025)	450	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2025)	79	n/a	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2025)	63	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2025)	2.2	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2025)	60	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2025)	0.95	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2025)	0.02	n/a	5	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Manganese (ug/L)	(2025)	79	n/a	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.
Total Organic Carbon (ug/L)	(2023 - 2025)	1288	1.5 - 2500	n/a	n/a

Table 6 - TREATED DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Total Organic Carbon (ug/L)	(2023)	2400	n/a	n/a	n/a

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2025)	6	n/a	n/a	n/a
Magnesium (mg/L)	(2025)	2	n/a	n/a	n/a
pH (units)	(2025)	7.6	n/a	n/a	n/a
Alkalinity (mg/L)	(2023 - 2025)	32	20 - 70	n/a	n/a
Aggressiveness Index	(2025)	10.3	n/a	n/a	n/a
Langelier Index	(2025)	-1.5	n/a	n/a	n/a

Table 8 - TREATED ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Alkalinity (mg/L)	(2023)	70	n/a	n/a	n/a

Table 9 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
--	-------------	------------------------	---------------------	------------	------------	-----------	--------------------------------

Total Trihalomethanes (TTHMs) (ug/L)	(2025)	33	28 - 40	80	n/a	No	By-product of drinking water disinfection
Chlorine, Free (mg/L)	(2024 - 2025)	1.04	0.15 - 1.04	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2025)	40.5	23 - 51	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *CAL Fire-Jamestown* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language

Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

2025 Consumer Confidence Report
Drinking Water Assessment Information

CAL Fire-Jamestown

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	3.1 - 3.1
Auto Maint. Shop	STK2534832-1					2025-04-07	Absent		
BOQ	STK2555060-1					2025-10-01	Absent		
BOQ 2	STK2557064-1					2025-11-05	Absent		
BOQ2	STK2558399-1					2025-12-03	Absent		
CDF Office	STK2551498-1					2025-08-06	Absent		
Dorm 1 and 2	STK2530132-1					2025-01-03	Absent		
Dorm 3 and 4	STK2531758-1					2025-02-05	Absent		
Dorm 5 and 6	STK2533278-1					2025-03-06	Absent		
Esparanza-Well	STK2556426-3					2025-10-22	<1.0		
Esperanza-Tank	STK2556426-4					2025-10-22	<1.0		
Family Visiting	STK2539680-1					2025-07-02	Absent		
Hermit Springs-NonP	STK2556426-1					2025-10-22	<1		
Hermit Springs-Pot	STK2556426-2					2025-10-22	3.1		
Kitchen	STK2553295-1					2025-09-03	Absent		
Maintenance Shop	STK2536541-1					2025-05-07	Absent		
T.V. Barbershop	STK2538180-1					2025-06-04	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
Auto Maint. Shop	STK2534832-1					2025-04-07	Absent		
BOQ	STK2555060-1					2025-10-01	Absent		
BOQ 2	STK2557064-1					2025-11-05	Absent		
BOQ2	STK2558399-1					2025-12-03	Absent		
CDF Office	STK2551498-1					2025-08-06	Absent		
Dorm 1 and 2	STK2530132-1					2025-01-03	Absent		
Dorm 3 and 4	STK2531758-1					2025-02-05	Absent		
Dorm 5 and 6	STK2533278-1					2025-03-06	Absent		
Esparanza-Well	STK2556426-3					2025-10-22	<1.0		
Esperanza-Tank	STK2556426-4					2025-10-22	<1.0		
Family Visiting	STK2539680-1					2025-07-02	Absent		
Hermit Springs-NonP	STK2556426-1					2025-10-22	<1		
Hermit Springs-Pot	STK2556426-2					2025-10-22	<1.0		
Kitchen	STK2553295-1					2025-09-03	Absent		
Maintenance Shop	STK2536541-1					2025-05-07	Absent		
T.V. Barbershop	STK2538180-1					2025-06-04	Absent		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			2	2 - 2
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	2		
Hardness		mg/L		none	none			23.2	23.2 - 23.2
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	23.2		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
TULLOCH RESERVOIR - RAW	STK2539683-1	ug/L				2025-07-02	2		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			2	2 - 2
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	2		

Color		Units		15	n/a			5	5 - 5
TULLOCH RESERVOIR - RAW	STK2539683-1	Units				2025-07-02	5		
Iron		ug/L		300	n/a			450	450 - 450
TULLOCH RESERVOIR - RAW	STK2539683-1	ug/L				2025-07-02	450		
Manganese		ug/L		50	n/a			79.0	79.0 - 79.0
TULLOCH RESERVOIR - RAW	STK2539683-1	ug/L				2025-07-02	79.0		
Specific Conductance		umhos/cm		1600	n/a			63.0	63.0 - 63.0
TULLOCH RESERVOIR - RAW	STK2539683-1	umhos/cm				2025-07-02	63.0		
Sulfate		mg/L		500	n/a			2.2	2.2 - 2.2
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	2.2		
Total Dissolved Solids		mg/L		1000	n/a			60	60 - 60
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	60		
Turbidity		NTU		5	n/a			0.95	0.95 - 0.95
TULLOCH RESERVOIR - RAW	STK2539683-1	NTU				2025-07-02	0.95		
Zinc		mg/L		5	n/a			0.02	0.02 - 0.02
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	0.02		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Manganese		ug/L		NS	n/a			79.0	79.0 - 79.0
TULLOCH RESERVOIR - RAW	STK2539683-1	ug/L				2025-07-02	79.0		
Total Organic Carbon		ug/L		NS	n/a			1287.9	1.5 - 2500
BOQ 2	STK2557064-1	ug/L				2025-11-05	1200		
BOQ2	STK2558399-1	ug/L				2025-12-03	1600		
DORM 3-4	STK2331374-1	ug/L				2023-02-01	2500		
Dorm 5 & 6	STK2332660-1	ug/L				2023-03-01	1800		
TULLOCH RESERVOIR - RAW	STK2558400-1	ug/L				2025-12-03	1500		
TULLOCH RESERVOIR - RAW	STK2557063-1	ug/L				2025-11-05	1700		
TULLOCH RESERVOIR - RAW	STK2555062-1	ug/L				2025-10-01	1.6		
TULLOCH RESERVOIR - RAW	STK2553296-1	ug/L				2025-09-03	1.5		

TREATED UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Organic Carbon		ug/L		NS	n/a			2400	2400 - 2400
BASELINE WTP (WATER BOY) - TRE	STK2330164-2	ug/L				2023-01-04	2400		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			6	6 - 6
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	6		
Magnesium		mg/L			n/a			2	2 - 2
TULLOCH RESERVOIR - RAW	STK2539683-1	mg/L				2025-07-02	2		
pH		units			n/a			7.6	7.6 - 7.6
TULLOCH RESERVOIR - RAW	STK2539683-1	units				2025-07-02	7.6		
Alkalinity		mg/L			n/a			32	20 - 70
Auto Maint. Shop	STK2534832-1	mg/L				2025-04-07	40		
Auto Shop	STK2334143-1	mg/L				2023-04-05	30		
Barber Shop	STK2438142-1	mg/L				2024-06-05	20		
BOQ	STK2555060-1	mg/L				2025-10-01	30		
BOQ 2	STK2557064-1	mg/L				2025-11-05	30		
BOQ2	STK2558399-1	mg/L				2025-12-03	50		
C.D.F. BOQ	STK2453180-1	mg/L				2024-09-04	30		
CDC Office	STK2456501-1	mg/L				2024-11-06	20		
CDD Office	STK2355119-1	mg/L				2023-11-01	30		
CDF BOQ	STK2352156-1	mg/L				2023-09-06	30		
CDF Office	STK2551498-1	mg/L				2025-08-06	30		
Dorm 1 and 2	STK2530132-1	mg/L				2025-01-03	30		

[illegible]

CAL Fire-Jamestown

CCR Login Linkage - 2025

FGL Code	Lab ID	Date Sampled	Method	Description	Property
Routine	STK2534832-1	2025-04-07	Wet Chemistry	Auto Maint. Shop	Baseline Camp - Routine
	STK2534832-1	2025-04-07	Field Test	Auto Maint. Shop	Baseline Camp - Routine
	STK2534832-1	2025-04-07	Coliform	Auto Maint. Shop	Baseline Camp - Routine
Auto Shop	STK2334143-1	2023-04-05	Wet Chemistry	Auto Shop	Baseline Camp - Routine
Barber Shop	STK2438142-1	2024-06-05	Wet Chemistry	Barber Shop	Baseline Camp - Routine
	STK2438142-1	2024-06-05	Field Test	Barber Shop	Baseline Camp - Routine
Water Boy_002	STK2330164-2	2023-01-04	Wet Chemistry	BASLINE WTP (WATER BOY) - TRE	Baseline Camp - Routine
	STK2330164-2	2023-01-04	TOC	BASLINE WTP (WATER BOY) - TRE	Baseline Camp - Routine
Routine	STK2555060-1	2025-10-01	Coliform	BOQ	Baseline Camp - Routine
	STK2555060-1	2025-10-01	Wet Chemistry	BOQ	Baseline Camp - Routine
	STK2555060-1	2025-10-01	Field Test	BOQ	Baseline Camp - Routine
	STK2557064-1	2025-11-05	Field Test	BOQ 2	CAL FIRE BASELINE CONSERVATION CAMP
	STK2557064-1	2025-11-05	TOC	BOQ 2	CAL FIRE BASELINE CONSERVATION CAMP
	STK2557064-1	2025-11-05	Coliform	BOQ 2	CAL FIRE BASELINE CONSERVATION CAMP
	STK2557064-1	2025-11-05	Wet Chemistry	BOQ 2	CAL FIRE BASELINE CONSERVATION CAMP
BOQ2	STK2558399-1	2025-12-03	TOC	BOQ2	Baseline Camp - Routine
	STK2558399-1	2025-12-03	Field Test	BOQ2	Baseline Camp - Routine
	STK2558399-1	2025-12-03	Coliform	BOQ2	Baseline Camp - Routine
	STK2558399-1	2025-12-03	Wet Chemistry	BOQ2	Baseline Camp - Routine
C.D.F. BOQ	STK2453180-1	2024-09-04	Wet Chemistry	C.D.F. BOQ	Baseline Camp - Routine
	STK2453180-1	2024-09-04	Field Test	C.D.F. BOQ	Baseline Camp - Routine
CDC Office	STK2456501-1	2024-11-06	Wet Chemistry	CDC Office	CAL FIRE BASELINE CONSERVATION CAMP
	STK2456501-1	2024-11-06	Field Test	CDC Office	CAL FIRE BASELINE CONSERVATION CAMP
Routine	STK2355119-1	2023-11-01	Wet Chemistry	CDD Office	Baseline Camp - Routine
	STK2352156-1	2023-09-06	Wet Chemistry	CDF BOQ	Baseline Camp - Routine
	STK2551498-1	2025-08-06	Field Test	CDF Office	CAL FIRE BASELINE CONSERVATION CAMP
	STK2551498-1	2025-08-06	Coliform	CDF Office	CAL FIRE BASELINE CONSERVATION CAMP
	STK2551498-1	2025-08-06	Wet Chemistry	CDF Office	CAL FIRE BASELINE CONSERVATION CAMP
Dorm 1 and 2	STK2530132-1	2025-01-03	Coliform	Dorm 1 and 2	CAL FIRE BASELINE CONSERVATION CAMP
	STK2530132-1	2025-01-03	Wet Chemistry	Dorm 1 and 2	CAL FIRE BASELINE CONSERVATION CAMP
	STK2530132-1	2025-01-03	Field Test	Dorm 1 and 2	CAL FIRE BASELINE CONSERVATION CAMP
DORM 2 & 3	STK2431905-1	2024-02-07	Wet Chemistry	Dorm 2 and 3	CAL FIRE BASELINE CONSERVATION CAMP
	STK2431905-1	2024-02-07	Field Test	Dorm 2 and 3	CAL FIRE BASELINE CONSERVATION CAMP
Dorm 3 and 4	STK2531758-1	2025-02-05	Coliform	Dorm 3 and 4	CAL FIRE BASELINE CONSERVATION CAMP
	STK2531758-1	2025-02-05	Wet Chemistry	Dorm 3 and 4	CAL FIRE BASELINE CONSERVATION CAMP
	STK2531758-1	2025-02-05	Field Test	Dorm 3 and 4	CAL FIRE BASELINE CONSERVATION CAMP
DORM 3-4	STK2331374-1	2023-02-01	Wet Chemistry	DORM 3-4	Baseline Camp - Routine
	STK2331374-1	2023-02-01	TOC	DORM 3-4	Baseline Camp - Routine
Dorm 5 & 6	STK2332660-1	2023-03-01	TOC	Dorm 5 & 6	Baseline Camp - Routine
Dorm 5 and 6	STK2433233-1	2024-03-06	Wet Chemistry	Dorm 5 & 6	CAL FIRE BASELINE CONSERVATION CAMP

	STK2433233-1	2024-03-06	Field Test	Dorm 5 & 6	CAL FIRE BASELINE CONSERVATION CAMP
	STK2533278-1	2025-03-06	Wet Chemistry	Dorm 5 and 6	CAL FIRE BASELINE CONSERVATION CAMP
	STK2533278-1	2025-03-06	Field Test	Dorm 5 and 6	CAL FIRE BASELINE CONSERVATION CAMP
	STK2533278-1	2025-03-06	Coliform	Dorm 5 and 6	CAL FIRE BASELINE CONSERVATION CAMP
Esperanza-Well	STK2556426-3	2025-10-22	Coliform	Esperanza-Well	Bacteriological Monitoring
Esperanza-Tank	STK2556426-4	2025-10-22	Coliform	Esperanza-Tank	Bacteriological Monitoring
Routine	STK2539680-1	2025-07-02	Wet Chemistry	Family Visiting	Baseline Camp - Routine
	STK2539680-1	2025-07-02	Field Test	Family Visiting	Baseline Camp - Routine
	STK2539680-1	2025-07-02	Coliform	Family Visiting	Baseline Camp - Routine
Hermit Springs-	STK2556426-1	2025-10-22	Coliform	Hermit Springs-NonP	Bacteriological Monitoring
	STK2556426-2	2025-10-22	Coliform	Hermit Springs-Pot	Bacteriological Monitoring
Kitchen	STK2553295-1	2025-09-03	Coliform	Kitchen	CAL FIRE BASELINE CAMP - Routine
	STK2553295-1	2025-09-03	Wet Chemistry	Kitchen	CAL FIRE BASELINE CAMP - Routine
	STK2553295-1	2025-09-03	Field Test	Kitchen	CAL FIRE BASELINE CAMP - Routine
Maintenance Sho	STK2536541-1	2025-05-07	Coliform	Maintenance Shop	Baseline Camp - Routine
	STK2536541-1	2025-05-07	Wet Chemistry	Maintenance Shop	Baseline Camp - Routine
	STK2536541-1	2025-05-07	Field Test	Maintenance Shop	Baseline Camp - Routine
Routine	STK2457797-1	2024-12-04	Field Test	Mess Hall	Baseline Camp - Routine
	STK2457797-1	2024-12-04	Wet Chemistry	Mess Hall	Baseline Camp - Routine
SEW Shop	STK2353790-1	2023-10-04	Wet Chemistry	SEW Shop	CAL FIRE BASELINE CONSERVATION CAMP
Sew Shop	STK2454769-1	2024-10-02	Field Test	Sew Shop	CAL FIRE BASELINE CONSERVATION CAMP
	STK2454769-1	2024-10-02	Wet Chemistry	Sew Shop	CAL FIRE BASELINE CONSERVATION CAMP
ST2DBP_900	STK2530131-1	2025-01-03	EPA 551.1	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2530131-1	2025-01-03	EPA 552.2	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2534834-1	2025-04-07	EPA 551.1	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2534834-1	2025-04-07	EPA 552.2	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2539682-1	2025-07-02	EPA 551.1	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2539682-1	2025-07-02	EPA 552.2	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2555061-1	2025-10-01	EPA 551.1	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
	STK2555061-1	2025-10-01	EPA 552.2	ST2DBP - SP # 8	Baseline Camp - DBP Monitoring
T.V. Barbershop	STK2538180-1	2025-06-04	Wet Chemistry	T.V. Barbershop	Baseline Camp - Routine
	STK2538180-1	2025-06-04	Field Test	T.V. Barbershop	Baseline Camp - Routine
	STK2538180-1	2025-06-04	Coliform	T.V. Barbershop	Baseline Camp - Routine
Tulloch Res Raw	STK2530133-1	2025-01-03	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2531759-1	2025-02-05	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2533276-1	2025-03-06	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2534833-1	2025-04-07	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2536540-1	2025-05-07	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2538179-1	2025-06-04	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2539683-1	2025-07-02	General Mineral	TULLOCH RESERVOIR - RAW	Baseline Camp Water Quality Monitoring
	STK2539679-1	2025-07-02	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2539683-1	2025-07-02	Metals, Total	TULLOCH RESERVOIR - RAW	Baseline Camp Water Quality Monitoring
	STK2539683-1	2025-07-02	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp Water Quality Monitoring
	STK2551499-1	2025-08-06	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2553296-1	2025-09-03	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2553296-1	2025-09-03		TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2555062-1	2025-10-01	TOC	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2555062-1	2025-10-01	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2557063-1	2025-11-05	TOC	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2557063-1	2025-11-05	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2558400-1	2025-12-03	TOC	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw
	STK2558400-1	2025-12-03	Wet Chemistry	TULLOCH RESERVOIR - RAW	Baseline Camp - Raw