

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	FILLMORE IRRIGATION CO
Water System Number:	CA5601105

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<i>NOAH ARCA</i>	
	Signature:	<i>Noah Arca</i>	
	Title:	<i>SUPERINTENDENT</i>	
	Phone Number:	<i>(805) 746-7001</i>	Date: <i>6-29-2026</i>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	FILLMORE IRRIGATION CO
Water System Number:	CA5601105

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
- _____
- _____
- ☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
- ☐ Posted the CCR on the internet at http:// _____
 - ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2025 Consumer Confidence Report

Water System Name: FILLMORE IRRIGATION CO

Report Date: June 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): WELL 02 and WELL 03

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board meetings are held at 540 Sespe Ave. #2 Fillmore Ca, 93015 every third Thursday of the month at 6:30 p.m. ..

For more information about this report, or any questions relating to your drinking water, please call (805)978-6570 and ask for Noah Arca or email FICdgalerts@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	Range	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2023)	5	0	0	ND -	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2023)	5	0.10	0	0.01 - 0.10	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021 - 2025)	70	66 - 73	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021 - 2025)	473	406 - 533	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Chromium (ug/L)	(2024)	16	n/a	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	(2021 - 2025)	0.9	0.8 - 1	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2023 - 2025)	2.5	0.9 - 4.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021 - 2025)	1.7	0.8 - 2.9	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2021 - 2024)	ND	ND - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2018 - 2024)	6.13	2.62 - 12.4	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2018 - 2024)	4.079	3.618 - 4.60	20	0.43	Erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021 - 2025)	60	45 - 66	500	n/a	Runoff/leaching from natural deposits; seawater influence
Manganese (ug/L)	(2024 - 2025)	1.5	ND - 3.0	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2021 - 2025)	1151	985 - 1280	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021 - 2025)	311	261 - 375	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021 - 2025)	838	710 - 980	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021 - 2024)	0.36	0.2 - 0.55	5	n/a	Soil runoff
Zinc (mg/L)	(2024 - 2025)	0.01	ND - 0.01	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2021 - 2025)	1.3	1.2 - 1.3	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2024)	5	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021 - 2025)	134	115 - 151	n/a	n/a
Magnesium (mg/L)	(2021 - 2025)	34	29 - 38	n/a	n/a
pH (units)	(2021 - 2025)	7.88	7.5 - 8.20	n/a	n/a
Alkalinity (mg/L)	(2021 - 2025)	198	170 - 220	n/a	n/a
Aggressiveness Index	(2021 - 2025)	12.7	12.4 - 12.9	n/a	n/a
Langelier Index	(2021 - 2025)	0.8	0.5 - 1.0	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Free (mg/L)	(2025)	0.66	0.34 - 1.16	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Fillmore Irrigation Company* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 of the FILLMORE IRRIGATION CO water system in March, 2001, as well as for the WELL 03 of the FILLMORE IRRIGATION CO water system in June, 2002.

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Chemical/petroleum processing/storage

WELL 03 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Crops, irrigated [Berries, hops, mint, orchards, sod, greenhouses,

Discussion of Vulnerability

Well 02 - No discussion.

Well 03 - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jason Cunningham

District Engineer

805 566 1326

Fillmore Irrigation Company

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
1416 Grand Avenue (Spigot)	SP 2521759-1					2025-12-18	Absent		
1416 Grand Avenue (Spigot)	SP 2520267-1					2025-11-25	Absent		
1416 Grand Avenue (Spigot)	SP 2517700-1					2025-10-15	Absent		
1416 Grand Avenue (Spigot)	SP 2515339-1					2025-09-10	Absent		
1416 Grand Avenue (Spigot)	SP 2513663-1					2025-08-13	Absent		
1416 Grand Avenue (Spigot)	SP 2511536-1					2025-07-09	Absent		
1416 Grand Avenue (Spigot)	SP 2509642-1					2025-06-06	Absent		
1416 Grand Avenue (Spigot)	SP 2507249-1					2025-05-05	Absent		
1416 Grand Avenue (Spigot)	SP 2505224-1					2025-04-03	Absent		
1416 Grand Avenue (Spigot)	SP 2503555-1					2025-03-10	Absent		
1416 Grand Avenue (Spigot)	SP 2502366-1					2025-02-17	Absent		
1416 Grand Avenue (Spigot)	SP 2500497-1					2025-01-13	Absent		
1425 Goodenough	SP 2512075-1					2025-07-18	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
1416 Grand Avenue (Spigot)	SP 2521759-1					2025-12-18	Absent		
1416 Grand Avenue (Spigot)	SP 2520267-1					2025-11-25	Absent		
1416 Grand Avenue (Spigot)	SP 2517700-1					2025-10-15	Absent		
1416 Grand Avenue (Spigot)	SP 2515339-1					2025-09-10	Absent		
1416 Grand Avenue (Spigot)	SP 2513663-1					2025-08-13	Absent		
1416 Grand Avenue (Spigot)	SP 2511536-1					2025-07-09	Absent		
1416 Grand Avenue (Spigot)	SP 2509642-1					2025-06-06	Absent		
1416 Grand Avenue (Spigot)	SP 2507249-1					2025-05-05	Absent		
1416 Grand Avenue (Spigot)	SP 2505224-1					2025-04-03	Absent		
1416 Grand Avenue (Spigot)	SP 2503555-1					2025-03-10	Absent		
1416 Grand Avenue (Spigot)	SP 2502366-1					2025-02-17	Absent		
1416 Grand Avenue (Spigot)	SP 2500497-1					2025-01-13	Absent		
1425 Goodenough	SP 2512075-1					2025-07-18	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
1143 Cliff Ave.	SP 2310883-4	ug/L				2023-06-27	ND		
1172 N. Oak Ave.	SP 2310883-3	ug/L				2023-06-27	ND		
1413 Grand Ave.	SP 2310883-2	ug/L				2023-06-27	ND		
822 N. Oak Ave.	SP 2310883-1	ug/L				2023-06-27	ND		
966 W. Bridge St.	SP 2310883-5	ug/L				2023-06-27	ND		
Copper		mg/L		1.3	.3			0.1	5
1143 Cliff Ave.	SP 2310883-4	mg/L				2023-06-27	0.05		
1172 N. Oak Ave.	SP 2310883-3	mg/L				2023-06-27	0.10		
1413 Grand Ave.	SP 2310883-2	mg/L				2023-06-27	ND		
822 N. Oak Ave.	SP 2310883-1	mg/L				2023-06-27	0.10		
966 W. Bridge St.	SP 2310883-5	mg/L				2023-06-27	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			70	66 - 73
Well 02	SP 2402574-1	mg/L				2024-02-22	66		
WELL 02	SP 2103656-1	mg/L				2021-03-17	68		
Well 03	SP 2511649-1	mg/L				2025-07-10	71		
WELL 03	SP 2211372-1	mg/L				2022-07-13	73		
Hardness		mg/L		none	none			473	406 - 533

Well 02	SP 2402574-1	mg/L				2024-02-22	406		
WELL 02	SP 2103656-1	mg/L				2021-03-17	452		
Well 03	SP 2511649-1	mg/L				2025-07-10	500		
WELL 03	SP 2211372-1	mg/L				2022-07-13	533		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chromium		ug/L	100	50.0	n/a			16	16 - 16
Well 02	SP 2402574-1	ug/L				2024-02-22	16		
Fluoride		mg/L		2	1			0.9	0.8 - 1
Well 02	SP 2402574-1	mg/L				2024-02-22	1		
WELL 02	SP 2103656-1	mg/L				2021-03-17	0.9		
Well 03	SP 2511649-1	mg/L				2025-07-10	0.8		
WELL 03	SP 2211372-1	mg/L				2022-07-13	0.8		
Nitrate as N		mg/L		10	10			2.5	0.9 - 4.7
WELL 02	SP 2503558-1	mg/L				2025-03-10	1.5		
Well 02	SP 2402574-1	mg/L				2024-02-22	0.9		
Well 03	SP 2511649-1	mg/L				2025-07-10	2.9		
WELL 03	SP 2312849-1	mg/L				2023-07-27	4.7		
Nitrate + Nitrite as N		mg/L		10	10			1.7	0.8 - 2.9
Well 02	SP 2402574-1	mg/L				2024-02-22	0.9		
WELL 02	SP 2103656-1	mg/L				2021-03-17	0.8		
Well 03	SP 2511649-1	mg/L				2025-07-10	2.9		
WELL 03	SP 2211372-1	mg/L				2022-07-13	2.3		
Selenium		ug/L	50	50	30			ND	ND - 7
Well 02	SP 2402574-1	ug/L				2024-02-22	6		
WELL 02	SP 2103656-1	ug/L				2021-03-17	ND		
WELL 03	SP 2310034-1	ug/L				2023-06-15	7		
Gross Alpha		pCi/L		15	(0)			6.13	2.62 - 12.4
Well 02	SP 2402574-1	pCi/L				2024-02-22	2.62		
WELL 02	SP 1803964-1	pCi/L				2018-03-26	5.24		
Well 03	SP 2418526-1	pCi/L				2024-11-12	12.4		
WELL 03	SP 1815277-1	pCi/L				2018-11-19	4.25		
Uranium		pCi/L		20	0.43			4.079	3.618 - 4.60
WELL 02	SP 1803964-1	pCi/L				2018-03-26	3.618		
Well 03	SP 2418526-1	pCi/L				2024-11-12	4.60		
WELL 03	SP 1815277-1	pCi/L				2018-11-19	4.02		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			60	45 - 66
Well 02	SP 2402574-1	mg/L				2024-02-22	45		
WELL 02	SP 2103656-1	mg/L				2021-03-17	61		
Well 03	SP 2511649-1	mg/L				2025-07-10	66		
WELL 03	SP 2211372-1	mg/L				2022-07-13	66		
Manganese		ug/L		50	n/a			1.5	ND - 3.0
Well 02	SP 2402574-1	ug/L				2024-02-22	3.0		
Well 03	SP 2511649-1	ug/L				2025-07-10	ND		
Specific Conductance		umhos/cm		1600	n/a			1151	985 - 1280
Well 02	SP 2402574-1	umhos/cm				2024-02-22	985		
WELL 02	SP 2103656-1	umhos/cm				2021-03-17	1080		
Well 03	SP 2511649-1	umhos/cm				2025-07-10	1260		
WELL 03	SP 2211372-1	umhos/cm				2022-07-13	1280		
Sulfate		mg/L		500	n/a			311	261 - 375
Well 02	SP 2402574-1	mg/L				2024-02-22	261		
WELL 02	SP 2103656-1	mg/L				2021-03-17	280		
Well 03	SP 2511649-1	mg/L				2025-07-10	375		
WELL 03	SP 2211372-1	mg/L				2022-07-13	326		

[illegible]

Fillmore Irrigation Company

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DST_LCR	SP 2310883-4	2023-06-27	Metals, Total	1143 Cliff Ave.	Copper & Lead Monitoring
	SP 2310883-3	2023-06-27	Metals, Total	1172 N. Oak Ave.	Copper & Lead Monitoring
	SP 2310883-2	2023-06-27	Metals, Total	1413 Grand Ave.	Copper & Lead Monitoring
1416GrndAvn-(Sp	SP 2500497-1	2025-01-13	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2500497-1	2025-01-13	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2502366-1	2025-02-17	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2502366-1	2025-02-17	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2503555-1	2025-03-10	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2503555-1	2025-03-10	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2505224-1	2025-04-03	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2505224-1	2025-04-03	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2507249-1	2025-05-05	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2507249-1	2025-05-05	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2509642-1	2025-06-06	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2509642-1	2025-06-06	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2511536-1	2025-07-09	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2511536-1	2025-07-09	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2513663-1	2025-08-13	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2513663-1	2025-08-13	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2515339-1	2025-09-10	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2515339-1	2025-09-10	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2517700-1	2025-10-15	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2517700-1	2025-10-15	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2520267-1	2025-11-25	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2520267-1	2025-11-25	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2521759-1	2025-12-18	Field Test	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
	SP 2521759-1	2025-12-18	Coliform	1416 Grand Avenue (Spigot)	Drinking Water Monitoring
1425 Goodenough	SP 2512075-1	2025-07-18	Coliform	1425 Goodenough	1425 Goodenough
DST_LCR	SP 2310883-1	2023-06-27	Metals, Total	822 N. Oak Ave.	Copper & Lead Monitoring
	SP 2310883-5	2023-06-27	Metals, Total	966 W. Bridge St.	Copper & Lead Monitoring
WELL#02	SP 1803964-1	2018-03-26	Radio Chemistry	WELL 02	Well 02 Water Monitoring
	SP 1803964-1	2018-03-26	Metals, Total	WELL 02	Well 02 Water Monitoring
	SP 2103656-1	2021-03-17	Wet Chemistry	WELL 02	Well 02 Water Monitoring
	SP 2103656-1	2021-03-17	General Mineral	WELL 02	Well 02 Water Monitoring
	SP 2103656-1	2021-03-17	Metals, Total	WELL 02	Well 02 Water Monitoring
	SP 2402574-1	2024-02-22	Metals, Total	Well 02	Well 02 Water Monitoring
	SP 2402574-1	2024-02-22	Wet Chemistry	Well 02	Well 02 Water Monitoring
	SP 2402574-1	2024-02-22	Radio Chemistry	Well 02	Well 02 Water Monitoring
	SP 2402574-1	2024-02-22	General Mineral	Well 02	Well 02 Water Monitoring
	SP 2503558-1	2025-03-10	Wet Chemistry	WELL 02	FILLMORE IRRIGATION CO
WELL#03	SP 1815277-1	2018-11-19	Metals, Total	WELL 03	Well 03 Water Monitoring
	SP 1815277-1	2018-11-19	Radio Chemistry	WELL 03	Well 03 Water Monitoring
	SP 2211372-1	2022-07-13	General Mineral	WELL 03	Well 03 Water Monitoring
	SP 2310034-1	2023-06-15	Metals, Total	WELL 03	Well 03 Water Monitoring
	SP 2310034-1	2023-06-15	Wet Chemistry	WELL 03	Well 03 Water Monitoring
	SP 2312849-1	2023-07-27	Wet Chemistry	WELL 03	Well 03 Water Monitoring
	SP 2418526-1	2024-11-12	Radio Chemistry	Well 03	Well 03 Water Monitoring
	SP 2418526-1	2024-11-12	Metals, Total	Well 03	Well 03 Water Monitoring
	SP 2511649-1	2025-07-10	General Mineral	Well 03	Well 03 Water Monitoring