

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certific/drinkingwater/CCR.shtml)

Water System Name:	FILLMORE WEST MOBILE HOME PARK
Water System Number:	CA5601106

The water system named above hereby certifies that its Consumer Confidence Report was distributed on JUNE 17, 2024 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<i>Wesley Housley</i>	
	Signature:	<i>[Signature]</i>	
	Title:	<i>Operator/Manager</i>	
	Phone Number:	<i>(805) 625-0286</i>	Date: <i>JUNE 17, 2024</i>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

DIRECT HAND DELIVERED.

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2023 Consumer Confidence Report

Water System Name: FILLMORE WEST MOBILE HOME PARK

Report Date: June 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): WELL 02

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) ~~524-2174~~ 625-0286 and ask for Luis Lomelli or email mdivincenzo@rtresi.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2023)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	69	66 - 72	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	454	433 - 475	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2021)	0.7	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2023)	2.2	2.1 - 2.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Nitrate + Nitrite as N (mg/L)	(2021)	2.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2021)	6	5 - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2015)	2.82	n/a	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021)	49	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2021)	1160	1150 - 1170	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	322	320 - 323	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	830	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2021)	1.1	1.0 - 1.1	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021)	130	124 - 136	n/a	n/a
Magnesium (mg/L)	(2021)	32	30 - 33	n/a	n/a
pH (units)	(2021)	7.73	7.2 - 8.26	n/a	n/a
Alkalinity (mg/L)	(2021)	210	n/a	n/a	n/a
Aggressiveness Index	(2021)	12.6	12.0 - 13.1	n/a	n/a
Langelier Index	(2021)	0.7	0.1 - 1.2	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2023)	8	6 - 8	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2023)	8	4 - 8	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Alturas Fillmore MHP* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

2023 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 of the FILLMORE WEST MOBILE HOME PARK water system in March, 2001.

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Septic systems - low density [$<1/\text{acre}$]

Acquiring Information

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore

District Engineer

805 566 1326

Alturas Fillmore MHP

Analytical Results By FGL - 2023

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
6 Storage Tanks	SP 2303178-1					2023-03-06	Absent		
Space 23 - Distribution Syste	SP 2319357-1					2023-11-21	Absent		
Space 23 - Distribution Syste	SP 2313228-1					2023-08-03	Absent		
Space 23 - Distribution Syste	SP 2307524-1					2023-05-10	Absent		
Space 23 - Distribution Syste	SP 2301742-1					2023-02-06	Absent		
Space 28 - Distribution System	SP 2320668-1					2023-12-18	Absent		
Space 28 - Distribution System	SP 2316193-1					2023-09-22	<1		
Space 28 - Distribution System	SP 2316045-1					2023-09-21	Present		
Space 28 - Distribution System	SP 2310569-1					2023-06-22	Absent		
Space 28 - Distribution System	SP 2304210-1					2023-03-23	Absent		
Space 29 - Distribution System	SP 2316193-3					2023-09-22	<1		
Space 32 - Distribution System	SP 2316193-2					2023-09-22	<1		
Space 6 - Distribution System	SP 2317710-1					2023-10-19	Absent		
Space 6 - Distribution System	SP 2312128-1					2023-07-17	Absent		
Space 6 - Distribution System	SP 2305341-1					2023-04-11	Absent		
Space 6 - Distribution System	SP 2300517-1					2023-01-12	<1.0		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			69	66 - 72
WELL 02	SP 2117980-1	mg/L				2021-12-16	72		
WELL 02	SP 2107737-2	mg/L				2021-06-10	66		
Hardness		mg/L		none	none			454	433 - 475
WELL 02	SP 2117980-1	mg/L				2021-12-16	475		
WELL 02	SP 2107737-2	mg/L				2021-06-10	433		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.7	0.7 - 0.7
WELL 02	SP 2117980-1	mg/L				2021-12-16	0.7		
WELL 02	SP 2107737-2	mg/L				2021-06-10	0.7		
Nitrate as N		mg/L		10	10			2.2	2.1 - 2.2
WELL 02	SP 2320669-1	mg/L				2023-12-18	2.2		
WELL 02	SP 2310569-2	mg/L				2023-06-22	2.1		
Nitrate + Nitrite as N		mg/L		10	10			2.2	2.2 - 2.2
WELL 02	SP 2117980-1	mg/L				2021-12-16	2.2		
WELL 02	SP 2107737-2	mg/L				2021-06-10	2.2		
Selenium		ug/L	50	50	30			6	5 - 7
WELL 02	SP 2117980-1	ug/L				2021-12-16	7		
WELL 02	SP 2107737-2	ug/L				2021-06-10	5		
Gross Alpha		pCi/L		15	(0)			2.82	2.82 - 2.82
WELL 02	SP 1513798-1	pCi/L				2015-12-10	2.82		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			49	49 - 49
WELL 02	SP 2117980-1	mg/L				2021-12-16	49		
WELL 02	SP 2107737-2	mg/L				2021-06-10	49		
Specific Conductance		umhos/cm		1600	n/a			1160	1150 - 1170

[illegible]

Alturas Fillmore MHP

CCR Login Linkage - 2023

FGL Code	Lab ID	Date Sampled	Method	Description	Property
6 Storage Tanks	SP 2303178-1	2023-03-06	Coliform	6 Storage Tanks	Alturas Fillmore MHP
DST_LCR	SP 2310570-3	2023-06-22	Metals, Total	Space #11	Copper & Lead Monitoring
	SP 2310570-5	2023-06-22	Metals, Total	Space #19	Copper & Lead Monitoring
	SP 2310570-4	2023-06-22	Metals, Total	Space #21	Copper & Lead Monitoring
	SP 2310570-1	2023-06-22	Metals, Total	Space #32	Copper & Lead Monitoring
	SP 2310570-2	2023-06-22	Metals, Total	Space #33	Copper & Lead Monitoring
Space 23 - Dis	SP 2301742-1	2023-02-06	Coliform	Space 23 - Distribution Syste	State Assessment Monitoring
	SP 2307524-1	2023-05-10	Coliform	Space 23 - Distribution Syste	State Assessment Monitoring
	SP 2313228-1	2023-08-03	Coliform	Space 23 - Distribution Syste	Drinking water monitoring
	SP 2319357-1	2023-11-21	Coliform	Space 23 - Distribution Syste	State Assessment Monitoring
Space 28 - Dist	SP 2304210-1	2023-03-23	Coliform	Space 28 - Distribution System	State Assessment Monitoring
	SP 2310569-1	2023-06-22	Coliform	Space 28 - Distribution System	State Assessment Monitoring
	SP 2316045-1	2023-09-21	Coliform	Space 28 - Distribution System	State Assessment Monitoring
	SP 2316193-1	2023-09-22	Coliform	Space 28 - Distribution System	Alturas Fillmore MHP
	SP 2320668-1	2023-12-18	Coliform	Space 28 - Distribution System	State Assessment Monitoring
Space 29 - Dist	SP 2316193-3	2023-09-22	Coliform	Space 29 - Distribution System	Alturas Fillmore MHP
Space 32 - Dist	SP 2316193-2	2023-09-22	Coliform	Space 32 - Distribution System	Alturas Fillmore MHP
Sp.33-Dist.Syst	SP 2313226-1	2023-08-03	EPA 551.1	Space 33 - Distribution System	State Assesment Monitoring
	SP 2313226-1	2023-08-03	EPA 552.2	Space 33 - Distribution System	State Assesment Monitoring
Sp.6-Dist.Syst	SP 2300517-1	2023-01-12	Coliform	Space 6 - Distribution System	State Assessment Monitoring
	SP 2305341-1	2023-04-11	Coliform	Space 6 - Distribution System	State Assessment Monitoring
	SP 2312128-1	2023-07-17	Coliform	Space 6 - Distribution System	State Assessment Monitoring
	SP 2317710-1	2023-10-19	Coliform	Space 6 - Distribution System	State Assessment Monitoring
Sp.33-Dist.Syst	SP 2316044-1	2023-09-21	EPA 551.1	STG 2 - 1906 OLD TELEGRAPH RD	DBP Monitoring
	SP 2316044-1	2023-09-21	EPA 552.2	STG 2 - 1906 OLD TELEGRAPH RD	DBP Monitoring
Well 2	SP 1513798-1	2015-12-10	Radio Chemistry	WELL 02	Well #2
	SP 2107737-2	2021-06-10	General Mineral	WELL 02	State Assessment Monitoring
	SP 2107737-2	2021-06-10	Metals, Total	WELL 02	State Assessment Monitoring
	SP 2117980-1	2021-12-16	Metals, Total	WELL 02	Well 02-Water Quality
	SP 2117980-1	2021-12-16	General Mineral	WELL 02	Well 02-Water Quality
	SP 2310569-2	2023-06-22	Wet Chemistry	WELL 02	State Assessment Monitoring
	SP 2320669-1	2023-12-18	Wet Chemistry	WELL 02	Well 02-Water Quality