

Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	Senior Canyon Mutual Water Company
Water System Number:	5601117

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 06/27/2022 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Peter Thielke	Title: President
Signature: Peter Thielke	Date: 06/27/2022
Phone number: 805-798-2971	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - Posting the CCR at the following URL: www. _____
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)

- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www.seniorcanyonwater.com
- Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- Water system emailed the CCR as an electronic file email attachment.
- Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- Requires prior DDW review and approval. Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

The 2021 CCR was uploaded onto our website on 06/27/22. Notification was mailed to all customers in the early July, 2022, billing. We also provided the option of mailing a hard copy of the CCR to any shareholder.

2021 Consumer Confidence Report

Water System Name: SENIOR CANYON MUTUAL WATER CO

Report Date: June 2022

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the source Surface Source is Surface Water. This Assessment was done using the Surface Water System (Watershed with Zones) Method. The source of standby water is an intertie SCMWC has with Casitas Municipal Water District

Your water comes from 1 source(s): Surface Source

Opportunities for public participation in decisions that affect drinking water quality: Regularly-held months Board meetings are held on the third Friday of a given month at 3 PM. The location of the meeting is given on the monthly bills that typically are mailed on the 8th of each month.

For more information about this report, or any questions relating to your drinking water, please call 805-665-0587 ext 3 and ask for Peter Thielke or email seniorcanyonmutualwatercompmany@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	11/year (2021)	11	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	11/year (2021)	11	no more than 1 positive monthly sample	0	Human and animal fecal waste.

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2021)	10	0.24	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	34	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	291	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (mg/L)	(2021)	0.12	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	(2021)	0.4	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2021)	0.6	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021)	0.6	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2015)	1.2	n/a	15	(0)	Erosion of natural deposits.

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021)	25	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2021)	5	n/a	15	n/a	Naturally-occurring organic materials
Odor Threshold at 60 °C (TON)	(2021)	4	n/a	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2021)	711	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	182	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	470	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021)	0.2	n/a	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2021)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021)	69	n/a	n/a	n/a
Magnesium (mg/L)	(2021)	29	n/a	n/a	n/a
pH (units)	(2021)	6.8	n/a	n/a	n/a
Alkalinity (mg/L)	(2021)	150	n/a	n/a	n/a
Aggressiveness Index	(2021)	11.2	n/a	n/a	n/a
Langelier Index	(2021)	-0.7	n/a	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2021)	41	36 - 41	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2021)	39	34 - 39	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Senior Canyon Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Odor Threshold at 60 °C				Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

2021 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the SURFACE SOURCE of the SENIOR CANYON MUTUAL WATER CO water system in May, 2001.

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Drinking Water Field Operations Branch
1180 Eugenia Place
Suite 200
Carpenteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore
District Engineer
805 566 1326

Senior Canyon Mutual Water Co.

Analytical Results By FGL - 2021

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
Canyon Intake Raw	SP 2117027-1					2021-12-01	>200.5		
Canyon Intake Raw	SP 2115479-1					2021-11-01	>200.5		
Canyon Intake Raw	SP 2113843-1					2021-10-04	>200.5		
Canyon Intake Raw	SP 2112317-1					2021-09-07	<1.0		
Canyon Intake Raw	SP 2110524-1					2021-08-04	>200.5		
Canyon Intake Raw	SP 2108765-1					2021-07-01	>200.5		
Canyon Intake Raw	SP 2107339-1					2021-06-03	>200.5		
Canyon Intake Raw	SP 2105796-1					2021-05-03	>200.5		
Canyon Intake Raw	SP 2104363-1					2021-04-01	>200.5		
Canyon Intake Raw	SP 2103183-1					2021-03-08	>200.5		
Canyon Intake Raw	SP 2101704-1					2021-02-08	>200.5		
Canyon Intake Raw	SP 2100026-1					2021-01-05	>200.5		
Ladera Rd.	SP 2106838-1					2021-05-21	Absent		
Shipee Lane	SP 2117027-2					2021-12-01	Absent		
Shipee Lane	SP 2115479-2					2021-11-01	Absent		
Shipee Lane	SP 2113843-2					2021-10-04	Absent		
Shipee Lane	SP 2112317-2					2021-09-07	Absent		
Shipee Lane	SP 2110524-2					2021-08-04	Absent		
Shipee Lane	SP 2108765-2					2021-07-01	Absent		
Shipee Lane	SP 2107339-2					2021-06-03	Absent		
Shipee Lane	SP 2105796-2					2021-05-03	Absent		
Shipee Lane	SP 2104363-2					2021-04-01	Absent		
Shipee Lane	SP 2103183-2					2021-03-08	Absent		
Shipee Lane	SP 2101704-2					2021-02-08	Absent		
Shipee Lane	SP 2100026-2					2021-01-05	Absent		
Thatcher Rd @ Bridge	SP 2114753-1					2021-10-19	<1.0		
Whale Rock	SP 2117027-3					2021-12-01	Absent		
Whale Rock	SP 2115479-3					2021-11-01	Absent		
Whale Rock	SP 2113843-3					2021-10-04	Absent		
Whale Rock	SP 2112317-3					2021-09-07	Absent		
Whale Rock	SP 2110524-3					2021-08-04	Absent		
Whale Rock	SP 2108765-3					2021-07-01	Absent		
Whale Rock	SP 2107339-3					2021-06-03	Absent		
Whale Rock	SP 2105796-3					2021-05-03	Absent		
Whale Rock	SP 2104363-3					2021-04-01	Absent		
Whale Rock	SP 2103183-3					2021-03-08	Absent		
Whale Rock	SP 2101704-3					2021-02-08	Absent		
Whale Rock	SP 2100026-3					2021-01-05	Absent		
Fecal coliform and E. coli			0		n/a			0	1 - 17.8
Canyon Intake Raw	SP 2117027-1					2021-12-01	2		
Canyon Intake Raw	SP 2115479-1					2021-11-01	17.8		
Canyon Intake Raw	SP 2113843-1					2021-10-04	2		
Canyon Intake Raw	SP 2112317-1					2021-09-07	<1.0		
Canyon Intake Raw	SP 2110524-1					2021-08-04	12.4		
Canyon Intake Raw	SP 2108765-1					2021-07-01	9.9		
Canyon Intake Raw	SP 2107339-1					2021-06-03	4.2		
Canyon Intake Raw	SP 2105796-1					2021-05-03	5.3		
Canyon Intake Raw	SP 2104363-1					2021-04-01	2		
Canyon Intake Raw	SP 2103183-1					2021-03-08	1		
Canyon Intake Raw	SP 2101704-1					2021-02-08	4.2		
Canyon Intake Raw	SP 2100026-1					2021-01-05	7.5		
Ladera Rd.	SP 2106838-1					2021-05-21	Absent		

Shipee Lane	SP 2117027-2					2021-12-01	Absent		
Shipee Lane	SP 2115479-2					2021-11-01	Absent		
Shipee Lane	SP 2113843-2					2021-10-04	Absent		
Shipee Lane	SP 2112317-2					2021-09-07	Absent		
Shipee Lane	SP 2110524-2					2021-08-04	Absent		
Shipee Lane	SP 2108765-2					2021-07-01	Absent		
Shipee Lane	SP 2107339-2					2021-06-03	Absent		
Shipee Lane	SP 2105796-2					2021-05-03	Absent		
Shipee Lane	SP 2104363-2					2021-04-01	Absent		
Shipee Lane	SP 2103183-2					2021-03-08	Absent		
Shipee Lane	SP 2101704-2					2021-02-08	Absent		
Shipee Lane	SP 2100026-2					2021-01-05	Absent		
Thatcher Rd @ Bridge	SP 2114753-1					2021-10-19	<1.0		
Whale Rock	SP 2117027-3					2021-12-01	Absent		
Whale Rock	SP 2115479-3					2021-11-01	Absent		
Whale Rock	SP 2113843-3					2021-10-04	Absent		
Whale Rock	SP 2112317-3					2021-09-07	Absent		
Whale Rock	SP 2110524-3					2021-08-04	Absent		
Whale Rock	SP 2108765-3					2021-07-01	Absent		
Whale Rock	SP 2107339-3					2021-06-03	Absent		
Whale Rock	SP 2105796-3					2021-05-03	Absent		
Whale Rock	SP 2104363-3					2021-04-01	Absent		
Whale Rock	SP 2103183-3					2021-03-08	Absent		
Whale Rock	SP 2101704-3					2021-02-08	Absent		
Whale Rock	SP 2100026-3					2021-01-05	Absent		

LEAD AND COPPER RULE

	Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper	mg/L		1.3	.3			0.24	10
1115 McNell Rd.	SP 2108766-6	mg/L			2021-06-28	ND		
1155 McAndrew Rd.	SP 2108766-9	mg/L			2021-06-28	0.08		
1462 McAndrew Rd.	SP 2108766-2	mg/L			2021-07-01	0.22		
2102 McNell Rd.	SP 2108766-3	mg/L			2021-06-28	0.11		
2560 Ladera Rd.	SP 2108766-7	mg/L			2021-06-28	0.23		
2580 Ladera Rd.	SP 2108766-10	mg/L			2021-06-28	ND		
3187 Grand Ave.	SP 2108766-1	mg/L			2021-06-28	0.18		
3396 Thacher Rd.	SP 2108766-4	mg/L			2021-06-30	ND		
4183 Grand Ave.	SP 2108766-8	mg/L			2021-06-29	0.24		
4589 Thacher Rd.	SP 2108766-5	mg/L			2021-06-28	0.38		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium	mg/L		none	none			34	34 - 34
Surface Source	SP 2104299-1	mg/L			2021-03-31	34		
Hardness	mg/L		none	none			291	291 - 291
Surface Source	SP 2104299-1	mg/L			2021-03-31	291		

PRIMARY DRINKING WATER STANDARDS (PDWS)

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Barium	mg/L	2	1	2			0.12	0.12 - 0.12
Surface Source	SP 2104299-1	mg/L			2021-03-31	0.12		
Fluoride	mg/L		2	1			0.4	0.4 - 0.4
Surface Source	SP 2104299-1	mg/L			2021-03-31	0.4		
Nitrate as N	mg/L		10	10			0.6	0.6 - 0.6
Surface Source	SP 2104299-1	mg/L			2021-03-31	0.6		
Nitrate + Nitrite as N	mg/L		10	10			0.6	0.6 - 0.6

Senior Canyon Mutual Water Co. CCR Login Linkage - 2021

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CuPb SS-06	SP 2108766-6	2021-06-28	Metals, Total	1115 McNell Rd.	Copper & Lead Monitoring
CuPb SS-09	SP 2108766-9	2021-06-28	Metals, Total	1155 McAndrew Rd.	Copper & Lead Monitoring
CuPb SS-02	SP 2108766-2	2021-07-01	Metals, Total	1462 McAndrew Rd.	Copper & Lead Monitoring
CuPb SS-03	SP 2108766-3	2021-06-28	Metals, Total	2102 McNell Rd.	Copper & Lead Monitoring
CuPb SS-07	SP 2108766-7	2021-06-28	Metals, Total	2560 Ladera Rd.	Copper & Lead Monitoring
CuPb SS-10	SP 2108766-10	2021-06-28	Metals, Total	2580 Ladera Rd.	Copper & Lead Monitoring
CuPb SS-01	SP 2108766-1	2021-06-28	Metals, Total	3187 Grand Ave.	Copper & Lead Monitoring
CuPb SS-04	SP 2108766-4	2021-06-30	Metals, Total	3396 Thacher Rd.	Copper & Lead Monitoring
CuPb SS-08	SP 2108766-8	2021-06-29	Metals, Total	4183 Grand Ave.	Copper & Lead Monitoring
CuPb SS-05	SP 2108766-5	2021-06-28	Metals, Total	4589 Thacher Rd.	Copper & Lead Monitoring
Canyon Intake R	SP 2100026-1	2021-01-05	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2101704-1	2021-02-08	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2103183-1	2021-03-08	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2104363-1	2021-04-01	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2105796-1	2021-05-03	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2107339-1	2021-06-03	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2108765-1	2021-07-01	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2110524-1	2021-08-04	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2112317-1	2021-09-07	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2113843-1	2021-10-04	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2115479-1	2021-11-01	Coliform	Canyon Intake Raw	Surface Water Monitoring
	SP 2117027-1	2021-12-01	Coliform	Canyon Intake Raw	Surface Water Monitoring
Ladera Rd.	SP 2106838-1	2021-05-21	Coliform	Ladera Rd.	Ladera Rd. New Water Line
McAndPmp Stg2DBP	SP 2113841-1	2021-10-04	EPA 551.1	MC ANDREW PUMP STN - STAGE 2 D	IDSE Stage 2 DBP
	SP 2113841-1	2021-10-04	EPA 552.2	MC ANDREW PUMP STN - STAGE 2 D	IDSE Stage 2 DBP
Shipee Ln	SP 2100026-2	2021-01-05	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2101704-2	2021-02-08	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2103183-2	2021-03-08	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2104363-2	2021-04-01	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2105796-2	2021-05-03	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2107339-2	2021-06-03	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2108765-2	2021-07-01	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2110524-2	2021-08-04	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2112317-2	2021-09-07	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2113843-2	2021-10-04	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2115479-2	2021-11-01	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2117027-2	2021-12-01	Coliform	Shipee Lane	Surface Water Monitoring
SHIP LN Stg2DBP	SP 2113841-2	2021-10-04	EPA 552.2	SHIPEE LANE - STAGE 2 DBP	IDSE Stage 2 DBP
	SP 2113841-2	2021-10-04	EPA 551.1	SHIPEE LANE - STAGE 2 DBP	IDSE Stage 2 DBP
SCynSW Src	SP 1303756-1	2013-04-15		Surface Source	Senior Canyon SW Monitoring
	SP 1500445-1	2015-01-13	Radio Chemistry	Surface Source	Surface Source
	SP 2104299-1	2021-03-31	Wet Chemistry	Surface Source	Senior Canyon SW Monitoring
	SP 2104299-1	2021-03-31	General Mineral	Surface Source	Senior Canyon SW Monitoring
	SP 2104299-1	2021-03-31	Metals, Total	Surface Source	Senior Canyon SW Monitoring
Thatcher Rd @ B	SP 2114753-1	2021-10-19	Coliform	Thatcher Rd @ Bridge	Thatcher Rd. New Water Main
WHALE RCK	SP 2100026-3	2021-01-05	Coliform	Whale Rock	Surface Water Monitoring
	SP 2101704-3	2021-02-08	Coliform	Whale Rock	Surface Water Monitoring
	SP 2103183-3	2021-03-08	Coliform	Whale Rock	Surface Water Monitoring
	SP 2104363-3	2021-04-01	Coliform	Whale Rock	Surface Water Monitoring
	SP 2105796-3	2021-05-03	Coliform	Whale Rock	Surface Water Monitoring
	SP 2107339-3	2021-06-03	Coliform	Whale Rock	Surface Water Monitoring
	SP 2108765-3	2021-07-01	Coliform	Whale Rock	Surface Water Monitoring
	SP 2110524-3	2021-08-04	Coliform	Whale Rock	Surface Water Monitoring
	SP 2112317-3	2021-09-07	Coliform	Whale Rock	Surface Water Monitoring

	SP 2113843-3	2021-10-04	Coliform	Whale Rock	Surface Water Monitoring
	SP 2115479-3	2021-11-01	Coliform	Whale Rock	Surface Water Monitoring
	SP 2117027-3	2021-12-01	Coliform	Whale Rock	Surface Water Monitoring