

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	SENIOR CANYON MUTUAL WATER CO
Water System Number:	CA5601117

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	(     )	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

---

---

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2022 Consumer Confidence Report

Water System Name: SENIOR CANYON MUTUAL WATER CO

Report Date: June 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, the source Surface Source is Surface Water. This Assessment was done using the Surface Water System (Watershed with Zones) Method. The source of standby water is an intertie SCMWC has with Casitas Municipal Water District

**Your water comes from 1 source(s):** SURFACE SOURCE

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-held months Board meetings are held on the third Friday of a given month at 3 PM. The location of the meeting is given on the monthly bills that typically are mailed on the 8th of each month.

For more information about this report, or any questions relating to your drinking water, please call 805-665-0587 ext 3 and ask for Peter Thielke or email [seniorcanyonmutualwatercompmany@gmail.com](mailto:seniorcanyonmutualwatercompmany@gmail.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2021)	10	0.24	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	29	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	396	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2022)	0.2	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2015)	1.2	n/a	15	(0)	Erosion of natural deposits.

<b>Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Chloride (mg/L)	(2022)	4	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2022)	5	n/a	15	n/a	Naturally-occurring organic materials
Specific Conductance (umhos/cm)	(2022)	786	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	221	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	570	n/a	1000	n/a	Runoff/leaching from natural deposits

<b>Table 5 - ADDITIONAL DETECTIONS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>	
Calcium (mg/L)	(2022)	116	n/a	n/a	n/a	
Magnesium (mg/L)	(2022)	26	n/a	n/a	n/a	
pH (units)	(2022)	6.2	n/a	n/a	n/a	
Alkalinity (mg/L)	(2022)	190	n/a	n/a	n/a	
Aggressiveness Index	(2022)	10.9	n/a	n/a	n/a	
Langelier Index	(2022)	-0.9	n/a	n/a	n/a	

<b>Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE</b>							
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL (MRDL)</b>	<b>PHG (MCLG)</b>	<b>Violation</b>	<b>Typical Sources of Contaminant</b>
Total Trihalomethanes (TTHMs) (ug/L)	(2022)	50	42 - 50.0	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2022)	46	42 - 46	60	n/a	No	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Senior Canyon Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

# **2022 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the SURFACE SOURCE of the SENIOR CANYON MUTUAL WATER CO water system in May, 2001.

### **Discussion of Vulnerability**

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:  
SWRCB Drinking Water Field Operations Branch  
1180 Eugenia Place  
Suite 200  
Carpenteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:  
Jeff Densmore  
District Engineer  
805 566 1326

# Senior Canyon Mutual Water Co.

## Analytical Results By FGL - 2022

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.24	10
1115 McNell Rd.	SP 2108766-6	mg/L				2021-06-28	ND		
1155 McAndrew Rd.	SP 2108766-9	mg/L				2021-06-28	0.08		
1462 McAndrew Rd.	SP 2108766-2	mg/L				2021-07-01	0.22		
2102 McNell Rd.	SP 2108766-3	mg/L				2021-06-28	0.11		
2560 Ladera Rd.	SP 2108766-7	mg/L				2021-06-28	0.23		
2580 Ladera Rd.	SP 2108766-10	mg/L				2021-06-28	ND		
3187 Grand Ave.	SP 2108766-1	mg/L				2021-06-28	0.18		
3396 Thacher Rd.	SP 2108766-4	mg/L				2021-06-30	ND		
4183 Grand Ave.	SP 2108766-8	mg/L				2021-06-29	0.24		
4589 Thacher Rd.	SP 2108766-5	mg/L				2021-06-28	0.38		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			29	29 - 29
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	29		
<b>Hardness</b>		mg/L		none	none			396	396 - 396
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	396		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Fluoride</b>		mg/L		2	1			0.2	0.2 - 0.2
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	0.2		
<b>Gross Alpha</b>		pCi/L		15	(0)			1.20	1.20 - 1.20
SURFACE SOURCE	SP 1500445-1	pCi/L				2015-01-13	1.20		

### SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			4	4 - 4
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	4		
<b>Color</b>		Units		15	n/a			5	5 - 5
SURFACE SOURCE	SP 2203798-1	Units				2022-03-10	5		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			786	786 - 786
SURFACE SOURCE	SP 2203798-1	umhos/cm				2022-03-10	786		
<b>Sulfate</b>		mg/L		500	n/a			221	221 - 221
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	221		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			570	570 - 570
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	570		

### ADDITIONAL DETECTIONS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			116	116 - 116
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	116		
<b>Magnesium</b>		mg/L			n/a			26	26 - 26
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	26		
<b>pH</b>		units			n/a			6.2	6.2 - 6.2
SURFACE SOURCE	SP 2203798-1	units				2022-03-10	6.2		
<b>Alkalinity</b>		mg/L			n/a			190	190 - 190
SURFACE SOURCE	SP 2203798-1	mg/L				2022-03-10	190		

<b>Aggressiveness Index</b>					n/a			10.9	10.9 - 10.9
SURFACE SOURCE	SP 2203798-1					2022-03-10	10.9		
<b>Langelier Index</b>					n/a			-0.9	-0.9 - -0.9
SURFACE SOURCE	SP 2203798-1					2022-03-10	-0.9		

[illegible]

# Senior Canyon Mutual Water Co.

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CuPb SS-06	SP 2108766-6	2021-06-28	Metals, Total	1115 McNeil Rd.	Copper & Lead Monitoring
CuPb SS-09	SP 2108766-9	2021-06-28	Metals, Total	1155 McAndrew Rd.	Copper & Lead Monitoring
CuPb SS-02	SP 2108766-2	2021-07-01	Metals, Total	1462 McAndrew Rd.	Copper & Lead Monitoring
CuPb SS-03	SP 2108766-3	2021-06-28	Metals, Total	2102 McNeil Rd.	Copper & Lead Monitoring
CuPb SS-07	SP 2108766-7	2021-06-28	Metals, Total	2560 Ladera Rd.	Copper & Lead Monitoring
CuPb SS-10	SP 2108766-10	2021-06-28	Metals, Total	2580 Ladera Rd.	Copper & Lead Monitoring
CuPb SS-01	SP 2108766-1	2021-06-28	Metals, Total	3187 Grand Ave.	Copper & Lead Monitoring
CuPb SS-04	SP 2108766-4	2021-06-30	Metals, Total	3396 Thacher Rd.	Copper & Lead Monitoring
CuPb SS-08	SP 2108766-8	2021-06-29	Metals, Total	4183 Grand Ave.	Copper & Lead Monitoring
CuPb SS-05	SP 2108766-5	2021-06-28	Metals, Total	4589 Thacher Rd.	Copper & Lead Monitoring
McAndPmp Stg2DB	SP 2216025-1	2022-10-05	EPA 551.1	MC ANDREW PUMP STN - STAGE 2 D	IDSE Stage 2 DBP
	SP 2216025-1	2022-10-05	EPA 552.2	MC ANDREW PUMP STN - STAGE 2 D	IDSE Stage 2 DBP
Shipee Ln	SP 2200157-2	2022-01-05	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2202065-2	2022-02-08	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2203487-2	2022-03-07	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2207224-2	2022-05-03	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2209270-2	2022-06-02	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2210895-2	2022-07-05	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2212552-2	2022-08-04	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2214355-2	2022-09-08	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2215879-2	2022-10-04	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2217465-2	2022-11-02	Coliform	Shipee Lane	Surface Water Monitoring
	SP 2219183-2	2022-12-05	Coliform	Shipee Lane	Surface Water Monitoring
SHIP LN Stg2DBP	SP 2216025-2	2022-10-05	EPA 551.1	SHIPEE LANE - STAGE 2 DBP	IDSE Stage 2 DBP
	SP 2216025-2	2022-10-05	EPA 552.2	SHIPEE LANE - STAGE 2 DBP	IDSE Stage 2 DBP
	SP 2205540-2	2022-04-07	Coliform	Shipee Ln	Monthly Bac-T
SCynSW Src	SP 1303756-1	2013-04-15		SURFACE SOURCE	Senior Canyon SW Monitoring
	SP 1500445-1	2015-01-13	Radio Chemistry	SURFACE SOURCE	Surface Source
	SP 2203798-1	2022-03-10		SURFACE SOURCE	SENIOR CANYON MUTUAL WATER CO
	SP 2203798-1	2022-03-10	Wet Chemistry	SURFACE SOURCE	SENIOR CANYON MUTUAL WATER CO
	SP 2203798-1	2022-03-10	General Mineral	SURFACE SOURCE	SENIOR CANYON MUTUAL WATER CO
WHALE RCK	SP 2200157-3	2022-01-05	Coliform	Whale Rock	Surface Water Monitoring
	SP 2202065-3	2022-02-08	Coliform	Whale Rock	Surface Water Monitoring
	SP 2203487-3	2022-03-07	Coliform	Whale Rock	Surface Water Monitoring
	SP 2205540-3	2022-04-07	Coliform	Whale Rock	Monthly Bac-T
WHALE RCK	SP 2207224-3	2022-05-03	Coliform	Whale Rock	Surface Water Monitoring
	SP 2209270-3	2022-06-02	Coliform	Whale Rock	Surface Water Monitoring
	SP 2210895-3	2022-07-05	Coliform	Whale Rock	Surface Water Monitoring
	SP 2212552-3	2022-08-04	Coliform	Whale Rock	Surface Water Monitoring
	SP 2214355-3	2022-09-08	Coliform	Whale Rock	Surface Water Monitoring
	SP 2215879-3	2022-10-04	Coliform	Whale Rock	Surface Water Monitoring
	SP 2217465-3	2022-11-02	Coliform	Whale Rock	Surface Water Monitoring
	SP 2219183-3	2022-12-05	Coliform	Whale Rock	Surface Water Monitoring