

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **Siete Robles Mutual Water Company**

Water System Number: **5601119**

The water system above hereby certifies that its Consumer Confidence Report was distributed on
5/24/19 (date) to customers (and appropriate notices of availability have been given). Further, the system
certifies that the information contained in the report is correct and consistent with the compliance monitoring data
previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name	Dan Breen	
	Signature	<u>Dan Breen</u>	
	Title	Director	
	Phone Number	(805-551-8991	Date 5/24/19

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items
that apply and fill-in where appropriate:

 X CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

USPS

 "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following
methods:

 Posted the CCR on the internet at http:// _____

 Mailed the CCR to postal patrons within the service area (attach zip codes used)

 Advertised the availability of the CCR in news media (attach a copy of press release)

 Publication of the CCR in a local newspaper of general circulation (attach a copy of the
published notice, including name of the newspaper and date published)

 Posted the CCR in public places (attach a list of locations)

 Delivery of multiple copies of CCR to single bill addresses serving several persons,
such as apartments, businesses, and schools

 Delivery to community organizations (attach a list of organizations)

 Other (attach a list of other methods used)

 For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site
at the following address: http:// _____

 For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement
of section 64483(c), California Code of Regulations.)

2018 Consumer Confidence Report

Water System Name: Siete Robles Mutual Water Company Report Date: May 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Well 04
and from 1 treated location(s): Well 04 - Trt Fe & Mn TP, CL2

Opportunities for public participation in decisions that affect drinking water quality: Opportunities for public participation in decisions that affect drinking water quality: Please contact Board President Jim Gerard at (818) 264-5443 for information regarding SRMWC shareholder meetings.

For more information about this report, or any questions relating to your drinking water, please call 818-264-5443 and ask for Jim Gerard.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	5 (2018)	0.15	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2016)	50	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2016)	353	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2016)	0.5	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2018)	4.5	3.9 - 5.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Nitrate + Nitrite as N (mg/L)	(2016)	4.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2013)	1.7	n/a	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2016)	15	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2018)	ND	ND - 110	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2018)	703	660 - 740	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2016)	885	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2016)	211	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2016)	590	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2016)	0.3	n/a	5	n/a	Soil runoff

Table 5 - TREATED DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Iron (ug/L)	(2018)	ND	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2018)	ND	n/a	50	n/a	Leaching from natural deposits

Table 6 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2016)	105	n/a	n/a	n/a
Magnesium (mg/L)	(2016)	22	n/a	n/a	n/a
pH (units)	(2016)	7.2	n/a	n/a	n/a
Alkalinity (mg/L)	(2016)	260	n/a	n/a	n/a
Aggressiveness Index	(2016)	12	n/a	n/a	n/a
Langelier Index	(2016)	0.2	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	6	ND - 6	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2018)	5	2 - 5	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Siete Robles Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 04 of the SIETE ROBLES MUTUAL WATER CO water system in March, 2003.

Well 04 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Septic systems - high density [$>1/\text{acre}$]

Discussion of Vulnerability

Because there are no detected contaminants, use this language or similar: "There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source."

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water
1180 Eugenia Place
Suite 200
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
805 566 1326

Siete Robles Water Co.

Analytical Results By FGL - 2018

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.145	5
215 Avenida del Recreo	SP 1815395-4	mg/L				2018-11-20	0.06		
312 Avenida del Recreo	SP 1815395-1	mg/L				2018-11-20	ND		
317 Avenida del Recreo	SP 1815395-3	mg/L				2018-11-20	0.19		
362 Avenida del Recreo	SP 1815395-5	mg/L				2018-11-20	ND		
450 Avenida de la Vereda	SP 1815395-2	mg/L				2018-11-20	0.10		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			50	50 - 50
Well 04	SP 1604341-1	mg/L				2016-04-19	50		
Hardness		mg/L		none	none			353	353 - 353
Well 04	SP 1604341-1	mg/L				2016-04-19	353		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.5	0.5 - 0.5
Well 04	SP 1604341-1	mg/L				2016-04-19	0.5		
Nitrate as N		mg/L		10	10			4.5	3.9 - 5.0
Well 04	SP 1813495-1	mg/L				2018-10-09	4.3		
Well 04	SP 1809359-1	mg/L				2018-07-17	5.0		
Well 04	SP 1805155-1	mg/L				2018-04-17	3.9		
Well 04	SP 1800520-1	mg/L				2018-01-12	4.9		
Nitrate + Nitrite as N		mg/L		10	10			4.5	4.5 - 4.5
Well 04	SP 1604341-1	mg/L				2016-04-19	4.5		
Gross Alpha		pCi/L		15	(0)			1.70	1.70 - 1.70
Well 04	SP 1310585-1	pCi/L				2013-10-08	1.70		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			15	15 - 15
Well 04	SP 1604341-1	mg/L				2016-04-19	15		
Iron		ug/L		300	n/a			ND	ND - 110
Well 04	SP 1816293-3	ug/L				2018-12-07	ND		
Well 04	SP 1815031-3	ug/L				2018-11-13	ND		
Well 04	SP 1813494-3	ug/L				2018-10-09	110		
Well 04	SP 1812863-3	ug/L				2018-09-25	ND		
Well 04	SP 1810965-3	ug/L				2018-08-21	ND		
Well 04	SP 1809361-3	ug/L				2018-07-17	ND		
Well 04	SP 1807666-3	ug/L				2018-06-12	110		
Well 04	SP 1806444-3	ug/L				2018-05-15	ND		
Well 04	SP 1805157-3	ug/L				2018-04-17	ND		
Well 04	SP 1803743-3	ug/L				2018-03-20	ND		
Well 04	SP 1801668-3	ug/L				2018-02-08	ND		
Well 04	SP 1800519-3	ug/L				2018-01-12	100		
Manganese		ug/L		50	n/a			703	660 - 740
Well 04	SP 1816293-3	ug/L				2018-12-07	720		
Well 04	SP 1815031-3	ug/L				2018-11-13	700		
Well 04	SP 1813494-3	ug/L				2018-10-09	740		
Well 04	SP 1812863-3	ug/L				2018-09-25	730		

Well 04	SP 1810965-3	ug/L				2018-08-21	710		
Well 04	SP 1809361-3	ug/L				2018-07-17	680		
Well 04	SP 1807666-3	ug/L				2018-06-12	690		
Well 04	SP 1806444-3	ug/L				2018-05-15	660		
Well 04	SP 1805157-3	ug/L				2018-04-17	710		
Well 04	SP 1803743-3	ug/L				2018-03-20	660		
Well 04	SP 1801668-3	ug/L				2018-02-08	740		
Well 04	SP 1800519-3	ug/L				2018-01-12	700		
Specific Conductance		umhos/cm		1600	n/a			885	885 - 885
Well 04	SP 1604341-1	umhos/cm				2016-04-19	885		
Sulfate		mg/L		500	n/a			211	211 - 211
Well 04	SP 1604341-1	mg/L				2016-04-19	211		
Total Dissolved Solids		mg/L		1000	n/a			590	590 - 590
Well 04	SP 1604341-1	mg/L				2016-04-19	590		
Turbidity		NTU		5	n/a			0.3	0.3 - 0.3
Well 04	SP 1604341-1	NTU				2016-04-19	0.3		

TREATED SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Iron		ug/L		300	n/a			ND	ND - ND
Well 04 - Trt Fe & Mn TP, CL2	SP 1816293-2	ug/L				2018-12-07	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1815031-2	ug/L				2018-11-13	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1813494-2	ug/L				2018-10-09	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1812863-2	ug/L				2018-09-25	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1810965-2	ug/L				2018-08-21	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1809361-2	ug/L				2018-07-17	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1807666-2	ug/L				2018-06-12	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1806444-2	ug/L				2018-05-15	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1805157-2	ug/L				2018-04-17	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1803743-2	ug/L				2018-03-20	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1801668-2	ug/L				2018-02-08	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1800519-2	ug/L				2018-01-12	ND		
Manganese		ug/L		50	n/a			ND	ND - ND
Well 04 - Trt Fe & Mn TP, CL2	SP 1816293-2	ug/L				2018-12-07	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1815031-2	ug/L				2018-11-13	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1813494-2	ug/L				2018-10-09	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1812863-2	ug/L				2018-09-25	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1810965-2	ug/L				2018-08-21	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1809361-2	ug/L				2018-07-17	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1807666-2	ug/L				2018-06-12	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1806444-2	ug/L				2018-05-15	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1805157-2	ug/L				2018-04-17	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1803743-2	ug/L				2018-03-20	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1801668-2	ug/L				2018-02-08	ND		
Well 04 - Trt Fe & Mn TP, CL2	SP 1800519-2	ug/L				2018-01-12	ND		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			105	105 - 105
Well 04	SP 1604341-1	mg/L				2016-04-19	105		
Magnesium		mg/L			n/a			22	22 - 22
Well 04	SP 1604341-1	mg/L				2016-04-19	22		
pH		units			n/a			7.2	7.2 - 7.2
Well 04	SP 1604341-1	units				2016-04-19	7.2		
Alkalinity		mg/L			n/a			260	260 - 260
Well 04	SP 1604341-1	mg/L				2016-04-19	260		
Aggressiveness Index					n/a			12.0	12.0 - 12.0
Well 04	SP 1604341-1					2016-04-19	12.0		

Langelier Index					n/a			0.2	0.2 - 0.2
Well 04	SP 1604341-1					2016-04-19	0.2		

[illegible]

Siete Robles Water Co.

CCR Login Linkage - 2018

FGL Code	Lab ID	Date Sampled	Method	Description	Property
CuPb-ss04	SP 1815395-4	2018-11-20	Metals, Total	215 Avenida del Recreo	Copper & Lead Monitoring
CuPb-ss01	SP 1815395-1	2018-11-20	Metals, Total	312 Avenida del Recreo	Copper & Lead Monitoring
CuPb-ss03	SP 1815395-3	2018-11-20	Metals, Total	317 Avenida del Recreo	Copper & Lead Monitoring
CuPb-ss05	SP 1815395-5	2018-11-20	Metals, Total	362 Avenida del Recreo	Copper & Lead Monitoring
CuPb-ss02	SP 1815395-2	2018-11-20	Metals, Total	450 Avenida de la Vereda	Copper & Lead Monitoring
Bacti-Rout-01	SP 1800519-1	2018-01-12	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1801668-1	2018-02-08	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1803743-1	2018-03-20	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1805157-1	2018-04-17	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1806444-1	2018-05-15	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1807666-1	2018-06-12	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1809361-1	2018-07-17	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1810965-1	2018-08-21	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1812863-1	2018-09-25	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1813494-1	2018-10-09	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1815031-1	2018-11-13	Coliform	Bacti-Sample Tap	Routine Water Monitoring
	SP 1816293-1	2018-12-07	Coliform	Bacti-Sample Tap	Routine Water Monitoring
DBP-ss02	SP 1810966-2	2018-08-21	EPA 552.2	DBP-215 Avenida de la Recreo	Disinfection Bi-Product THM & HAA Monitoring
	SP 1810966-2	2018-08-21	EPA 551.1	DBP-215 Avenida de la Recreo	Disinfection Bi-Product THM & HAA Monitoring
DBP-ss01	SP 1810966-1	2018-08-21	EPA 552.2	DBP-Sample Tap	Disinfection Bi-Product THM & HAA Monitoring
	SP 1810966-1	2018-08-21	EPA 551.1	DBP-Sample Tap	Disinfection Bi-Product THM & HAA Monitoring
WELL 4 RAW	SP 1310585-1	2013-10-08	Radio Chemistry	Well 04	Radiochem Monitoring
Well 04	SP 1604341-1	2016-04-19	Wet Chemistry	Well 04	Water Quality Monitoring
	SP 1604341-1	2016-04-19	General Mineral	Well 04	Water Quality Monitoring
WELL4-RAW	SP 1800520-1	2018-01-12	Wet Chemistry	Well 04	Water Quality Monitoring
	SP 1800519-3	2018-01-12	Metals, Total	Well 04	Routine Water Monitoring
	SP 1801668-3	2018-02-08	Metals, Total	Well 04	Routine Water Monitoring
	SP 1803743-3	2018-03-20	Metals, Total	Well 04	Routine Water Monitoring
	SP 1805155-1	2018-04-17	Wet Chemistry	Well 04	Water Quality Monitoring
	SP 1805157-3	2018-04-17	Metals, Total	Well 04	Routine Water Monitoring
	SP 1806444-3	2018-05-15	Metals, Total	Well 04	Routine Water Monitoring
	SP 1807666-3	2018-06-12	Metals, Total	Well 04	Routine Water Monitoring
	SP 1809359-1	2018-07-17	Wet Chemistry	Well 04	Water Quality Monitoring
	SP 1809361-3	2018-07-17	Metals, Total	Well 04	Routine Water Monitoring
	SP 1810965-3	2018-08-21	Metals, Total	Well 04	Routine Water Monitoring
	SP 1812863-3	2018-09-25	Metals, Total	Well 04	Routine Water Monitoring
	SP 1813495-1	2018-10-09	Wet Chemistry	Well 04	Water Quality Monitoring
	SP 1813494-3	2018-10-09	Metals, Total	Well 04	Routine Water Monitoring
	SP 1815031-3	2018-11-13	Metals, Total	Well 04	Routine Water Monitoring
	SP 1816293-3	2018-12-07	Metals, Total	Well 04	Routine Water Monitoring
WELL4-FeMnTRTD	SP 1800519-2	2018-01-12	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1801668-2	2018-02-08	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1803743-2	2018-03-20	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1805157-2	2018-04-17	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1806444-2	2018-05-15	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1807666-2	2018-06-12	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1809361-2	2018-07-17	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1810965-2	2018-08-21	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1812863-2	2018-09-25	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1813494-2	2018-10-09	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1815031-2	2018-11-13	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring
	SP 1816293-2	2018-12-07	Metals, Total	Well 04 - Trt Fe & Mn TP, CL2	Routine Water Monitoring