2025 Consumer Confidence Report

Water System Name: TICO MUTUAL WATER CO Report Date: May 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alquien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the Sources are Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): PURCHASED-CASITAS MW - TREATED and WELL 01
and from 1 treated location(s): BLENDED WATER - NO3 - TREATED

Opportunities for public participation in decisions that affect drinking water quality: Water board or city/county council meetings currently are not regularly scheduled and you may call Frances Fitting for information.

For more information about this report, or any questions relating to your drinking water, please call (805) 991-7333 ext 703 and ask for Exodus Water Services or email info@exoduswater.com or visit our website at https://www.exoduswater.com/.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants,* such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants,* such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides,* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants,* including synthetic and volatile organic chemicals, that are by-products if industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants,* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	**Highest No. of Detections**	**No. of Months in Violation**	**MCL**	**MCLG**	**Typical Sources of Contaminant**
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	**Sample Date**	**No. of Samples**	**90th percentile level detected**	**No. Sites Exceeding AL**	**Range**	**AL**	**PHG**	**Typical Sources of Contaminant**
Lead (ug/L)	(2025)	5	0	0	ND -	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2025)	5	0.16	0	0.03 - 0.16	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	**Sample Date**	**Average Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Sodium (mg/L)	(2023)	62	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2023)	285	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Average Level Detected**	**Range of Detections**	**MCL [MRDL]**	**PHG (MCLG) [MRDLG]**	**Typical Sources of Contaminant**
Barium (mg/L)	(2023)	0.1	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	(2023)	0.4	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2022 - 2025)	8.3	6.4 - 9.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2023)	8.8	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2023)	1.8	n/a	15	(0)	Erosion of natural deposits.

Table 5 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Average Level Detected**	**Range of Detections**	**MCL [MRDL]**	**PHG (MCLG) [MRDLG]**	**Typical Sources of Contaminant**
Nitrate as N (mg/L)	(2025)	5.5	0.5 - 6.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 6 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Average Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Chloride (mg/L)	(2023)	56	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2023 - 2025)	390	340 - 440	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2023)	819	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2023)	100	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2023)	550	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2023)	0.98	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2023)	0.06	n/a	5	n/a	Runoff/leaching from natural deposits

Table 7 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2023)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 8 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2023)	73	n/a	n/a	n/a
Magnesium (mg/L)	(2023)	25	n/a	n/a	n/a
pH (units)	(2023)	7.51	n/a	n/a	n/a
Alkalinity (mg/L)	(2023)	210	n/a	n/a	n/a
Aggressiveness Index	(2023)	12.1	n/a	n/a	n/a
Langelier Index	(2023)	0.2	n/a	n/a	n/a

Table 9 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2025)	14	12 - 14	80	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Tico Mutual Water Company* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/lead.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	**Explanation**	**Duration**	**Actions Taken To Correct the Violation**	**Health Effects Language**
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment (DWSAPP) was completed for the WELL 01 of the TICO MUTUAL WATER CO water system in April, 2001. A Drinking Water Source Assessment (DWSAPP) has not been completed for the CASITAS MUNICIPAL-TREATED of the TICO MUTUAL WATER COMPANY water system.

PURCHASED-CASITAS MW - TREATED	- This information is currently unavailable, see Discussion of Vulnerability section below.
WELL 01	- is considered most vulnerable to the following activities not associated with any detected contaminants: Historic gas stations

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:
ï¿½ The Assessment has not been completed. Contact the local DDW district office or the water system to find out when the Assessment is scheduled to be done.
ï¿½ The source is not active. It may be out of service, or new and not yet in service.
ï¿½ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water
1180 Eugenia Place
Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Jason Cunningham
District Engineer
805 566 1326

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Tico Mutual Water Company

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Total Coliform Bacteria			0	5%	n/a			ND	-
1976 S. Rice Rd	SP 2521893-1					2025-12-22	Absent		
1976 S. Rice Rd	SP 2519826-1					2025-11-19	Absent		
1976 S. Rice Rd	SP 2517467-1					2025-10-13	Absent		
1976 S. Rice Rd	SP 2515131-1					2025-09-08	Absent		
1976 S. Rice Rd	SP 2513151-1					2025-08-06	Absent		
1976 S. Rice Rd	SP 2512339-1					2025-07-23	Absent		
1976 S. Rice Rd	SP 2510811-1					2025-06-25	Absent		
1976 S. Rice Rd	SP 2507967-1					2025-05-14	Absent		
1976 S. Rice Rd	SP 2506018-1					2025-04-16	Absent		
1976 S. Rice Rd	SP 2504170-1					2025-03-19	Absent		
1976 S. Rice Rd	SP 2502498-1					2025-02-19	Absent		
1976 S. Rice Rd	SP 2500914-1					2025-01-21	<1		
BLENDED WATER - NO3 - TREATED	SP 2513151-2					2025-08-06	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
1976 S. Rice Rd	SP 2521893-1					2025-12-22	Absent		
1976 S. Rice Rd	SP 2519826-1					2025-11-19	Absent		
1976 S. Rice Rd	SP 2517467-1					2025-10-13	Absent		
1976 S. Rice Rd	SP 2515131-1					2025-09-08	Absent		
1976 S. Rice Rd	SP 2513151-1					2025-08-06	Absent		
1976 S. Rice Rd	SP 2512339-1					2025-07-23	Absent		
1976 S. Rice Rd	SP 2510811-1					2025-06-25	Absent		
1976 S. Rice Rd	SP 2507967-1					2025-05-14	Absent		
1976 S. Rice Rd	SP 2506018-1					2025-04-16	Absent		
1976 S. Rice Rd	SP 2504170-1					2025-03-19	Absent		
1976 S. Rice Rd	SP 2502498-1					2025-02-19	Absent		
1976 S. Rice Rd	SP 2500914-1					2025-01-21	<1		
BLENDED WATER - NO3 - TREATED	SP 2513151-2					2025-08-06	Absent		

LEAD AND COPPER RULE									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**90th Percentile**	**# Samples**
Lead		ug/L	0	15	0.2			0	5
1884 S. Rice Road	SP 2512487-1	ug/L				2025-07-10	ND		
1924 S. Rice Road	SP 2512487-2	ug/L				2025-07-10	ND		
1936 S. Rice Road	SP 2512487-3	ug/L				2025-07-10	ND		
1976 S. Rice Road	SP 2512487-4	ug/L				2025-07-10	ND		
2394 S. Rice Road	SP 2512487-5	ug/L				2025-07-10	ND		
Copper		mg/L		1.3	.3			0.155	5
1884 S. Rice Road	SP 2512487-1	mg/L				2025-07-10	0.16		
1924 S. Rice Road	SP 2512487-2	mg/L				2025-07-10	0.14		
1936 S. Rice Road	SP 2512487-3	mg/L				2025-07-10	0.14		
1976 S. Rice Road	SP 2512487-4	mg/L				2025-07-10	0.15		
2394 S. Rice Road	SP 2512487-5	mg/L				2025-07-10	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Sodium		mg/L		none	none			62	62 - 62
WELL 01	SP 2313908-1	mg/L				2023-08-15	62		
Hardness		mg/L		none	none			285	285 - 285
WELL 01	SP 2313908-1	mg/L				2023-08-15	285		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Barium		mg/L	2	1	2			0.10	0.10 - 0.10
WELL 01	SP 2313908-1	mg/L				2023-08-15	0.10		
Fluoride		mg/L		2	1			0.4	0.4 - 0.4
WELL 01	SP 2313908-1	mg/L				2023-08-15	0.4		
Nitrate as N		mg/L		10	10			8.3	6.4 - 9.8
PURCHASED-CASITAS MW - TREATED	SP 2205869-1	mg/L				2022-04-12	6.4		
WELL 01	SP 2522238-2	mg/L				2025-12-30	9.7		
WELL 01	SP 2521893-3	mg/L				2025-12-22	9.7		
WELL 01	SP 2520889-2	mg/L				2025-12-08	9.3		
WELL 01	SP 2520364-2	mg/L				2025-11-26	8.5		
WELL 01	SP 2519826-3	mg/L				2025-11-19	7.2		
WELL 01	SP 2519415-3	mg/L				2025-11-13	7.8		
WELL 01	SP 2518846-2	mg/L				2025-11-04	7.3		
WELL 01	SP 2516647-2	mg/L				2025-10-01	7.2		
WELL 01	SP 2516114-2	mg/L				2025-09-23	8.1		
WELL 01	SP 2515131-2	mg/L				2025-09-08	7.5		
WELL 01	SP 2513151-4	mg/L				2025-08-06	7.3		
WELL 01	SP 2511587-2	mg/L				2025-07-09	7.3		
WELL 01	SP 2510811-4	mg/L				2025-06-25	8.8		
WELL 01	SP 2509816-2	mg/L				2025-06-10	8.3		
WELL 01	SP 2508963-2	mg/L				2025-05-29	8.5		
WELL 01	SP 2507967-3	mg/L				2025-05-14	7.6		
WELL 01	SP 2507583-2	mg/L				2025-05-08	8.5		
WELL 01	SP 2507068-2	mg/L				2025-05-01	7.9		
WELL 01	SP 2506494-2	mg/L				2025-04-23	8.1		
WELL 01	SP 2506018-4	mg/L				2025-04-16	8.7		
WELL 01	SP 2505436-2	mg/L				2025-04-08	9.7		
WELL 01	SP 2505130-2	mg/L				2025-04-02	8.1		
WELL 01	SP 2504743-2	mg/L				2025-03-26	9.8		
WELL 01	SP 2504170-3	mg/L				2025-03-19	8.4		
WELL 01	SP 2503639-2	mg/L				2025-03-11	9.4		
WELL 01	SP 2503190-2	mg/L				2025-03-04	9.0		
WELL 01	SP 2502498-3	mg/L				2025-02-19	7.7		
WELL 01	SP 2501885-2	mg/L				2025-02-06	8.8		
WELL 01	SP 2500914-3	mg/L				2025-01-21	8.7		
WELL 01	SP 2500765-2	mg/L				2025-01-16	8.5		
WELL 01	SP 2500194-3	mg/L				2025-01-07	7.4		
Nitrate + Nitrite as N		mg/L		10	10			8.8	8.8 - 8.8
WELL 01	SP 2313908-1	mg/L				2023-08-15	8.8		
Gross Alpha		pCi/L		15	(0)			1.80	1.80 - 1.80
WELL 01	SP 2313912-1	pCi/L				2023-08-15	1.80		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate as N		mg/L		10	10			5.5	0.5 - 6.7
BLENDED WATER - NO3 - TREATED	SP 2522238-1	mg/L				2025-12-30	6.4		
BLENDED WATER - NO3 - TREATED	SP 2521893-2	mg/L				2025-12-22	6.7		
BLENDED WATER - NO3 - TREATED	SP 2520889-1	mg/L				2025-12-08	6.4		
BLENDED WATER - NO3 - TREATED	SP 2520364-1	mg/L				2025-11-26	5.7		
BLENDED WATER - NO3 - TREATED	SP 2519826-2	mg/L				2025-11-19	4.8		
BLENDED WATER - NO3 - TREATED	SP 2519415-2	mg/L				2025-11-13	5.4		

BLENDED WATER - NO3 - TREATED	SP 2518846-1	mg/L				2025-11-04	5.2		
BLENDED WATER - NO3 - TREATED	SP 2516647-1	mg/L				2025-10-01	5.1		
BLENDED WATER - NO3 - TREATED	SP 2516114-1	mg/L				2025-09-23	5.3		
BLENDED WATER - NO3 - TREATED	SP 2515131-3	mg/L				2025-09-08	5.2		
BLENDED WATER - NO3 - TREATED	SP 2513151-3	mg/L				2025-08-06	5.3		
BLENDED WATER - NO3 - TREATED	SP 2512339-2	mg/L				2025-07-23	0.5		
BLENDED WATER - NO3 - TREATED	SP 2511587-1	mg/L				2025-07-09	5.5		
BLENDED WATER - NO3 - TREATED	SP 2510811-3	mg/L				2025-06-25	5.6		
BLENDED WATER - NO3 - TREATED	SP 2509816-1	mg/L				2025-06-10	5.2		
BLENDED WATER - NO3 - TREATED	SP 2508963-1	mg/L				2025-05-29	5.5		
BLENDED WATER - NO3 - TREATED	SP 2507967-2	mg/L				2025-05-14	5.6		
BLENDED WATER - NO3 - TREATED	SP 2507583-1	mg/L				2025-05-08	5.6		
BLENDED WATER - NO3 - TREATED	SP 2507068-1	mg/L				2025-05-01	5.4		
BLENDED WATER - NO3 - TREATED	SP 2506494-1	mg/L				2025-04-23	5.6		
BLENDED WATER - NO3 - TREATED	SP 2506018-3	mg/L				2025-04-16	6.1		
BLENDED WATER - NO3 - TREATED	SP 2505436-1	mg/L				2025-04-08	5.6		
BLENDED WATER - NO3 - TREATED	SP 2505130-1	mg/L				2025-04-02	6.3		
BLENDED WATER - NO3 - TREATED	SP 2504743-1	mg/L				2025-03-26	5.4		
BLENDED WATER - NO3 - TREATED	SP 2504170-2	mg/L				2025-03-19	6.2		
BLENDED WATER - NO3 - TREATED	SP 2503639-1	mg/L				2025-03-11	6.4		
BLENDED WATER - NO3 - TREATED	SP 2503190-1	mg/L				2025-03-04	6.1		
BLENDED WATER - NO3 - TREATED	SP 2502498-2	mg/L				2025-02-19	5.4		
BLENDED WATER - NO3 - TREATED	SP 2501885-1	mg/L				2025-02-06	5.9		
BLENDED WATER - NO3 - TREATED	SP 2500914-2	mg/L				2025-01-21	5.7		
BLENDED WATER - NO3 - TREATED	SP 2500765-1	mg/L				2025-01-16	5.6		
BLENDED WATER - NO3 - TREATED	SP 2500194-2	mg/L				2025-01-07	5.4		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			56	56 - 56
WELL 01	SP 2313908-1	mg/L				2023-08-15	56		
Iron		ug/L		300	n/a			390	340 - 440
Well 01	SP 2517466-1	ug/L				2025-10-13	340		
WELL 01	SP 2313908-1	ug/L				2023-08-15	440		
Specific Conductance		umhos/cm		1600	n/a			819	819 - 819
WELL 01	SP 2313908-1	umhos/cm				2023-08-15	819		
Sulfate		mg/L		500	n/a			100	100 - 100
WELL 01	SP 2313908-1	mg/L				2023-08-15	100		
Total Dissolved Solids		mg/L		1000	n/a			550	550 - 550

WELL 01	SP 2313908-1	mg/L				2023-08-15	550		
Turbidity		NTU		5	n/a			0.98	0.98 - 0.98
WELL 01	SP 2313908-1	NTU				2023-08-15	0.98		
Zinc		mg/L		5	n/a			0.06	0.06 - 0.06
WELL 01	SP 2313908-1	mg/L				2023-08-15	0.06		

UNREGULATED CONTAMINANTS									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Boron		mg/L		NS	n/a			0.2	0.2 - 0.2
WELL 01	SP 2313908-1	mg/L				2023-08-15	0.2		

ADDITIONAL DETECTIONS									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Calcium		mg/L			n/a			73	73 - 73
WELL 01	SP 2313908-1	mg/L				2023-08-15	73		
Magnesium		mg/L			n/a			25	25 - 25
WELL 01	SP 2313908-1	mg/L				2023-08-15	25		
pH		units			n/a			7.51	7.51 - 7.51
WELL 01	SP 2313908-1	units				2023-08-15	7.51		
Alkalinity		mg/L			n/a			210	210 - 210
WELL 01	SP 2313908-1	mg/L				2023-08-15	210		
Aggressiveness Index					n/a			12.1	12.1 - 12.1
WELL 01	SP 2313908-1					2023-08-15	12.1		
Langelier Index					n/a			0.2	0.2 - 0.2
WELL 01	SP 2313908-1					2023-08-15	0.2		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			14	12 - 14
11134 N. Ventura Ave - STG 2 D	SP 2515057-2	ug/L				2025-09-05	12		
Average 11134 N. Ventura Ave - STG 2 D								12	
11168 N. Ventura Ave - STG 2 D	SP 2515057-1	ug/L				2025-09-05	14		
Average 11168 N. Ventura Ave - STG 2 D								14	

Tico Mutual Water Company

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DBPR-ss02	SP 2515057-2	2025-09-05	EPA 551.1	11134 N. Ventura Ave - STG 2 D	Stage 2 DBP Monitoring
DBPR-ss01	SP 2515057-1	2025-09-05	EPA 551.1	11168 N. Ventura Ave - STG 2 D	Stage 2 DBP Monitoring
CA5601122_DST_L	SP 2512487-1	2025-07-10	Metals, Total	1884 S. Rice Road	TICO MUTUAL WATER CO
	SP 2512487-2	2025-07-10	Metals, Total	1924 S. Rice Road	TICO MUTUAL WATER CO
	SP 2512487-3	2025-07-10	Metals, Total	1936 S. Rice Road	TICO MUTUAL WATER CO
Bacti-Rout-ss02	SP 2500914-1	2025-01-21	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2502498-1	2025-02-19	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2504170-1	2025-03-19	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2506018-1	2025-04-16	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2507967-1	2025-05-14	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2510811-1	2025-06-25	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2512339-1	2025-07-23	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2513151-1	2025-08-06	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2515131-1	2025-09-08	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2517467-1	2025-10-13	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2519826-1	2025-11-19	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
	SP 2521893-1	2025-12-22	Coliform	1976 S. Rice Rd	Drinking Water Monitoring
CA5601122_DST_L	SP 2512487-4	2025-07-10	Metals, Total	1976 S. Rice Road	TICO MUTUAL WATER CO
	SP 2512487-5	2025-07-10	Metals, Total	2394 S. Rice Road	TICO MUTUAL WATER CO
Trtd-NO3-ss01	SP 2500194-2	2025-01-07	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2500765-1	2025-01-16	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
Bacti-Rout-ss01	SP 2500914-2	2025-01-21	Wet Chemistry	BLENDED WATER - NO3 - TREATED	Drinking Water Monitoring
Trtd-NO3-ss01	SP 2501885-1	2025-02-06	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2502498-2	2025-02-19	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2503190-1	2025-03-04	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2503639-1	2025-03-11	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2504170-2	2025-03-19	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
Trtd-NO3-SS01	SP 2504743-1	2025-03-26	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
Trtd-NO3-ss01	SP 2505130-1	2025-04-02	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2505436-1	2025-04-08	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2506018-3	2025-04-16	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2506494-1	2025-04-23	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2507068-1	2025-05-01	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2507583-1	2025-05-08	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2507967-2	2025-05-14	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2508963-1	2025-05-29	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2509816-1	2025-06-10	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
Bacti-Rout-ss01	SP 2510811-3	2025-06-25	Wet Chemistry	BLENDED WATER - NO3 - TREATED	Drinking Water Monitoring
Trtd-NO3-ss01	SP 2511587-1	2025-07-09	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2512339-2	2025-07-23	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO

Bacti-Rout-ss01	SP 2513151-2	2025-08-06	Coliform	BLENDED WATER - NO3 - TREATED	Drinking Water Monitoring
	SP 2513151-3	2025-08-06	Wet Chemistry	BLENDED WATER - NO3 - TREATED	Drinking Water Monitoring
Trtd-NO3-ss01	SP 2515131-3	2025-09-08	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2516114-1	2025-09-23	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2516647-1	2025-10-01	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2518846-1	2025-11-04	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2519415-2	2025-11-13	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2519826-2	2025-11-19	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2520364-1	2025-11-26	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
	SP 2520889-1	2025-12-08	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
Bacti-Rout-ss01	SP 2521893-2	2025-12-22	Wet Chemistry	BLENDED WATER - NO3 - TREATED	Drinking Water Monitoring
Trtd-NO3-ss01	SP 2522238-1	2025-12-30	Wet Chemistry	BLENDED WATER - NO3 - TREATED	TICO MUTUAL WATER CO
CA5601120_003_0	SP 2205869-1	2022-04-12	Wet Chemistry	PURCHASED-CASITAS MW - TREATED	Tico Mutual Water Company
WELL 01	SP 2313908-1	2023-08-15	Wet Chemistry	WELL 01	Water Quality Monitoring
	SP 2313912-1	2023-08-15	Radio Chemistry	WELL 01	Radio Monitoring
	SP 2313908-1	2023-08-15	General Mineral	WELL 01	Water Quality Monitoring
	SP 2313908-1	2023-08-15	Metals, Total	WELL 01	Water Quality Monitoring
	SP 2500194-3	2025-01-07	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2500765-2	2025-01-16	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2500914-3	2025-01-21	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2501885-2	2025-02-06	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2502498-3	2025-02-19	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2503190-2	2025-03-04	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2503639-2	2025-03-11	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2504170-3	2025-03-19	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2504743-2	2025-03-26	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2505130-2	2025-04-02	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2505436-2	2025-04-08	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2506018-4	2025-04-16	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2506494-2	2025-04-23	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2507068-2	2025-05-01	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2507583-2	2025-05-08	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2507967-3	2025-05-14	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2508963-2	2025-05-29	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2509816-2	2025-06-10	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2510811-4	2025-06-25	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2511587-2	2025-07-09	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2513151-4	2025-08-06	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2515131-2	2025-09-08	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2516114-2	2025-09-23	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2516647-2	2025-10-01	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2517466-1	2025-10-13	Metals, Total	Well 01	Well 01 - Water Quality
	SP 2518846-2	2025-11-04	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2519415-3	2025-11-13	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2519826-3	2025-11-19	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2520364-2	2025-11-26	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2520889-2	2025-12-08	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO
	SP 2521893-3	2025-12-22	Wet Chemistry	WELL 01	Drinking Water Monitoring
	SP 2522238-2	2025-12-30	Wet Chemistry	WELL 01	TICO MUTUAL WATER CO