

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>Del Norte Mutual Water Co.</b>
Water System Number:	<b>CA5602104</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	(     )	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

---

---

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2022 Consumer Confidence Report

Water System Name: Del Norte Mutual Water Co.

Report Date: February 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well 10

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held annually in February.

For more information about this report, or any questions relating to your drinking water, please call (805) 647-1092 and ask for David Vanoni.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.**

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	6/year (2022)	2	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	2/year (2022)	2			Human and animal fecal waste.

<b>Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>							
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>No. of Samples</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Copper (mg/L)	(2021)	10	0.05	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (mg/L)	(2020)	69	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	340	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2020)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2020)	0.3	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2022)	8.2	7.5 - 10.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2020)	8.3	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2020)	20	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2020)	10.8	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2020)	7.66	n/a	20	0.43	Erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2020)	83	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2020)	10	n/a	15	n/a	Naturally-occurring organic materials
Manganese (ug/L)	(2020)	20	n/a	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2020)	1020	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2020)	137	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2020)	640	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2020)	0.3	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2020)	0.05	n/a	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2020)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2020)	85	n/a	n/a	n/a
Magnesium (mg/L)	(2020)	31	n/a	n/a	n/a
pH (units)	(2020)	8.2	n/a	n/a	n/a
Alkalinity (mg/L)	(2020)	180	n/a	n/a	n/a
Aggressiveness Index	(2020)	12.8	n/a	n/a	n/a

Langelier Index	(2020)	0.9	n/a	n/a	n/a
-----------------	--------	-----	-----	-----	-----

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Del Norte Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Fecal coliform and E. coli				<p>E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.</p> <p>- We had an E. coli-positive repeat sample following a total coliform-positive sample.</p> <p>- We had a total coliform-positive repeat sample following an E. coli positive routine sample.</p> <p>- We failed to take all required repeat samples following an E. coli-positive routine sample.</p>
Nitrate as N				<p>Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.</p>

**About your Nitrate as N:** Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

## 2022 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL 10 of the DEL NORTE MUTUAL WATER CO. water system in May, 2001.

Well 10 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - high density [ $>1/\text{acre}$ ]

**Acquiring Information**

A copy of the complete assessment may be viewed at:  
SWRCB Division of Drinking Water  
1180 Eugenia Place, Suite 200  
Carpinteria, CA 930133

You may request a summary of the assessment be sent to you by contacting:  
Jeff Densmore  
District Engineer  
(805)566-1326

# Del Norte Water Co.

## Analytical Results By FGL - 2022

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			2	1 - 50.4
1177 E. La Loma Ave.	SP 2213570-1					2022-08-21	<1.0		
1177 La Loma	SP 2217987-1					2022-11-10	Absent		
1177 La Loma	SP 2216842-1					2022-10-19	Absent		
1177 La Loma	SP 2213903-1					2022-08-29	<1.0		
1177 La Loma	SP 2213874-5					2022-08-26	<1.0		
1177 La Loma	SP 2208822-1					2022-05-24	<1.0		
1177 La Loma	SP 2208637-3					2022-05-22	<1.0		
1177 Laloma	SP 2208624-2					2022-05-20	<1.0		
1201 La Loma	SP 2213903-2					2022-08-29	<1.0		
1201 La Loma	SP 2213874-4					2022-08-26	<1.0		
1201 La Loma	SP 2213570-2					2022-08-21	<1.0		
Beck Tank	SP 2213906-1					2022-08-29	<1.0		
Booster Station	SP 2220230-2					2022-12-20	Absent		
Booster Station	SP 2220068-3					2022-12-16	Absent		
Booster Station	SP 2219549-2					2022-12-08	Absent		
Booster Station	SP 2219119-2					2022-12-01	Absent		
Booster Station	SP 2218692-4					2022-11-22	Absent		
Booster Station	SP 2218493-2					2022-11-18	Absent		
Booster Station	SP 2217987-2					2022-11-10	Absent		
Booster Station	SP 2217654-2					2022-11-04	Absent		
Booster Station	SP 2217301-2					2022-10-28	Absent		
Booster Station	SP 2216842-2					2022-10-19	Absent		
Booster Station	SP 2216567-2					2022-10-14	Absent		
Booster Station	SP 2216113-3					2022-10-06	Absent		
Booster Station	SP 2215527-2					2022-09-28	Absent		
Booster Station	SP 2214978-2					2022-09-19	Absent		
Booster Station	SP 2214692-3					2022-09-13	Absent		
Booster Station	SP 2214505-2					2022-09-09	Absent		
Booster Station	SP 2213903-5					2022-08-29	<1.0		
Booster Station	SP 2213874-3					2022-08-26	<1.0		
Booster Station	SP 2213570-3					2022-08-21	<1.0		
Booster Station	SP 2213551-1					2022-08-19	<1.0		
Booster Station	SP 2210328-3					2022-06-21	Absent		
Booster Station	SP 2208682-1					2022-05-23	<1.0		
Booster Station	SP 2208637-1					2022-05-22	<1.0		
Booster Station	SP 2208624-4					2022-05-20	<1.0		
Green tank	SP 2213601-1					2022-08-22	<1.0		
La Loma 1177	SP 2220230-1					2022-12-20	Absent		
La Loma 1177	SP 2220068-2					2022-12-16	Absent		
La Loma 1177	SP 2219549-1					2022-12-08	Absent		
La Loma 1177	SP 2219119-1					2022-12-01	Absent		
La Loma 1177	SP 2218692-2					2022-11-22	Absent		
La Loma 1177	SP 2218493-1					2022-11-18	Absent		
La Loma 1177	SP 2217654-1					2022-11-04	Absent		
La Loma 1177	SP 2217301-1					2022-10-28	Absent		
La Loma 1177	SP 2216567-1					2022-10-14	Absent		
La Loma 1177	SP 2216113-2					2022-10-06	Absent		
La Loma 1177	SP 2215527-1					2022-09-28	Absent		
La Loma 1177	SP 2214978-1					2022-09-19	Absent		
La Loma 1177	SP 2214692-2					2022-09-13	Absent		
La Loma 1177	SP 2214505-1					2022-09-09	Absent		
La Loma 1177	SP 2213551-4					2022-08-19	28.8		



La Loma 1177	SP 2213435-2					2022-08-18	Absent		
La Loma 1177	SP 2211705-2					2022-07-19	Absent		
La Loma 1177	SP 2210328-2					2022-06-21	Absent		
La Loma 1177	SP 2208682-5					2022-05-23	<1.0		
La Loma 1177	SP 2208511-2					2022-05-19	Present		
La Loma 1177	SP 2206243-2					2022-04-15	Absent		
La Loma 1177	SP 2204318-2					2022-03-17	Absent		
La Loma 1177	SP 2202984-2					2022-02-23	Absent		
La Loma 1177	SP 2201174-2					2022-01-21	Absent		
Murata	SP 2220230-3					2022-12-20	Absent		
Murata	SP 2220068-1					2022-12-16	Absent		
Murata	SP 2219549-3					2022-12-08	Absent		
Murata	SP 2219119-3					2022-12-01	Absent		
Murata	SP 2218692-1					2022-11-22	Absent		
Murata	SP 2218493-3					2022-11-18	Absent		
Murata	SP 2217987-3					2022-11-10	Absent		
Murata	SP 2217654-3					2022-11-04	Absent		
Murata	SP 2217301-3					2022-10-28	Absent		
Murata	SP 2216842-3					2022-10-19	Absent		
Murata	SP 2216567-3					2022-10-14	Absent		
Murata	SP 2216113-1					2022-10-06	Absent		
Murata	SP 2215527-3					2022-09-28	Absent		
Murata	SP 2214978-3					2022-09-19	Absent		
Murata	SP 2214692-1					2022-09-13	Absent		
Murata	SP 2214505-3					2022-09-09	Absent		
Murata	SP 2213903-4					2022-08-29	<1.0		
Murata	SP 2213874-1					2022-08-26	<1.0		
Murata	SP 2213570-5					2022-08-21	<1.0		
Murata	SP 2213551-3					2022-08-19	<1.0		
Murata	SP 2213435-1					2022-08-18	Present		
Murata	SP 2211705-1					2022-07-19	Absent		
Murata	SP 2208900-2					2022-05-25	<1.0		
Murata	SP 2208822-2					2022-05-24	<1.0		
Murata	SP 2208682-4					2022-05-23	<1.0		
Murata	SP 2208637-5					2022-05-22	<1.0		
Murata	SP 2208624-5					2022-05-20	50.4		
Murata	SP 2208511-1					2022-05-19	Present		
Murata	SP 2206243-1					2022-04-15	Absent		
Murata	SP 2204318-1					2022-03-17	Absent		
Murata	SP 2202984-1					2022-02-23	Absent		
Murata	SP 2201174-1					2022-01-21	Absent		
MURATA - 875 LA AVE - STG 2 DB	SP 2210328-1					2022-06-21	Absent		
Murata Blow Off	SP 2208682-3					2022-05-23	<1.0		
Murata Blow Off	SP 2208637-4					2022-05-22	<1.0		
Murata Blowoff	SP 2213903-3					2022-08-29	<1.0		
Murata Blowoff	SP 2213874-2					2022-08-26	<1.0		
Murata Blowoff	SP 2213570-4					2022-08-21	<1.0		
Murata Blowoff	SP 2213551-2					2022-08-19	1		
Murata Blowoff	SP 2210328-6					2022-06-21	Absent		
Walnut	SP 2210328-4					2022-06-21	Absent		
Walnut	SP 2208682-2					2022-05-23	<1.0		
Walnut	SP 2208637-2					2022-05-22	<1.0		
Walnut	SP 2208624-3					2022-05-20	<1.0		
<b>Fecal coliform and E. coli</b>				0	n/a			0	6.4 - 9.9
1177 E. La Loma Ave.	SP 2213570-1					2022-08-21	<1.0		
1177 La Loma	SP 2217987-1					2022-11-10	Absent		
1177 La Loma	SP 2216842-1					2022-10-19	Absent		
1177 La Loma	SP 2213903-1					2022-08-29	<1.0		
1177 La Loma	SP 2213874-5					2022-08-26	<1.0		
1177 La Loma	SP 2208822-1					2022-05-24	<1.0		

1177 La Loma	SP 2208637-3					2022-05-22	<1.0		
1177 Laloma	SP 2208624-2					2022-05-20	<1.0		
1201 La Loma	SP 2213903-2					2022-08-29	<1.0		
1201 La Loma	SP 2213874-4					2022-08-26	<1.0		
1201 La Loma	SP 2213570-2					2022-08-21	<1.0		
Beck Tank	SP 2213906-1					2022-08-29	<1.0		
Booster Station	SP 2220230-2					2022-12-20	Absent		
Booster Station	SP 2220068-3					2022-12-16	Absent		
Booster Station	SP 2219549-2					2022-12-08	Absent		
Booster Station	SP 2219119-2					2022-12-01	Absent		
Booster Station	SP 2218692-4					2022-11-22	Absent		
Booster Station	SP 2218493-2					2022-11-18	Absent		
Booster Station	SP 2217987-2					2022-11-10	Absent		
Booster Station	SP 2217654-2					2022-11-04	Absent		
Booster Station	SP 2217301-2					2022-10-28	Absent		
Booster Station	SP 2216842-2					2022-10-19	Absent		
Booster Station	SP 2216567-2					2022-10-14	Absent		
Booster Station	SP 2216113-3					2022-10-06	Absent		
Booster Station	SP 2215527-2					2022-09-28	Absent		
Booster Station	SP 2214978-2					2022-09-19	Absent		
Booster Station	SP 2214692-3					2022-09-13	Absent		
Booster Station	SP 2214505-2					2022-09-09	Absent		
Booster Station	SP 2213903-5					2022-08-29	<1.0		
Booster Station	SP 2213874-3					2022-08-26	<1.0		
Booster Station	SP 2213570-3					2022-08-21	<1.0		
Booster Station	SP 2213551-1					2022-08-19	<1.0		
Booster Station	SP 2210328-3					2022-06-21	Absent		
Booster Station	SP 2208682-1					2022-05-23	<1.0		
Booster Station	SP 2208637-1					2022-05-22	<1.0		
Booster Station	SP 2208624-4					2022-05-20	<1.0		
Green tank	SP 2213601-1					2022-08-22	<1.0		
La Loma 1177	SP 2220230-1					2022-12-20	Absent		
La Loma 1177	SP 2220068-2					2022-12-16	Absent		
La Loma 1177	SP 2219549-1					2022-12-08	Absent		
La Loma 1177	SP 2219119-1					2022-12-01	Absent		
La Loma 1177	SP 2218692-2					2022-11-22	Absent		
La Loma 1177	SP 2218493-1					2022-11-18	Absent		
La Loma 1177	SP 2217654-1					2022-11-04	Absent		
La Loma 1177	SP 2217301-1					2022-10-28	Absent		
La Loma 1177	SP 2216567-1					2022-10-14	Absent		
La Loma 1177	SP 2216113-2					2022-10-06	Absent		
La Loma 1177	SP 2215527-1					2022-09-28	Absent		
La Loma 1177	SP 2214978-1					2022-09-19	Absent		
La Loma 1177	SP 2214692-2					2022-09-13	Absent		
La Loma 1177	SP 2214505-1					2022-09-09	Absent		
La Loma 1177	SP 2213551-4					2022-08-19	9.9		
La Loma 1177	SP 2213435-2					2022-08-18	Absent		
La Loma 1177	SP 2211705-2					2022-07-19	Absent		
La Loma 1177	SP 2210328-2					2022-06-21	Absent		
La Loma 1177	SP 2208682-5					2022-05-23	<1.0		
La Loma 1177	SP 2208511-2					2022-05-19	Present		
La Loma 1177	SP 2206243-2					2022-04-15	Absent		
La Loma 1177	SP 2204318-2					2022-03-17	Absent		
La Loma 1177	SP 2202984-2					2022-02-23	Absent		
La Loma 1177	SP 2201174-2					2022-01-21	Absent		
Murata	SP 2220230-3					2022-12-20	Absent		
Murata	SP 2220068-1					2022-12-16	Absent		
Murata	SP 2219549-3					2022-12-08	Absent		
Murata	SP 2219119-3					2022-12-01	Absent		
Murata	SP 2218692-1					2022-11-22	Absent		

Murata	SP 2218493-3					2022-11-18	Absent		
Murata	SP 2217987-3					2022-11-10	Absent		
Murata	SP 2217654-3					2022-11-04	Absent		
Murata	SP 2217301-3					2022-10-28	Absent		
Murata	SP 2216842-3					2022-10-19	Absent		
Murata	SP 2216567-3					2022-10-14	Absent		
Murata	SP 2216113-1					2022-10-06	Absent		
Murata	SP 2215527-3					2022-09-28	Absent		
Murata	SP 2214978-3					2022-09-19	Absent		
Murata	SP 2214692-1					2022-09-13	Absent		
Murata	SP 2214505-3					2022-09-09	Absent		
Murata	SP 2213903-4					2022-08-29	<1.0		
Murata	SP 2213874-1					2022-08-26	<1.0		
Murata	SP 2213570-5					2022-08-21	<1.0		
Murata	SP 2213551-3					2022-08-19	<1.0		
Murata	SP 2213435-1					2022-08-18	Present		
Murata	SP 2211705-1					2022-07-19	Absent		
Murata	SP 2208900-2					2022-05-25	<1.0		
Murata	SP 2208822-2					2022-05-24	<1.0		
Murata	SP 2208682-4					2022-05-23	<1.0		
Murata	SP 2208637-5					2022-05-22	<1.0		
Murata	SP 2208624-5					2022-05-20	6.4		
Murata	SP 2208511-1					2022-05-19	Present		
Murata	SP 2206243-1					2022-04-15	Absent		
Murata	SP 2204318-1					2022-03-17	Absent		
Murata	SP 2202984-1					2022-02-23	Absent		
Murata	SP 2201174-1					2022-01-21	Absent		
MURATA - 875 LA AVE - STG 2 DB	SP 2210328-1					2022-06-21	Absent		
Murata Blow Off	SP 2208682-3					2022-05-23	<1.0		
Murata Blow Off	SP 2208637-4					2022-05-22	<1.0		
Murata Blowoff	SP 2213903-3					2022-08-29	<1.0		
Murata Blowoff	SP 2213874-2					2022-08-26	<1.0		
Murata Blowoff	SP 2213570-4					2022-08-21	<1.0		
Murata Blowoff	SP 2213551-2					2022-08-19	<1.0		
Murata Blowoff	SP 2210328-6					2022-06-21	Absent		
Walnut	SP 2210328-4					2022-06-21	Absent		
Walnut	SP 2208682-2					2022-05-23	<1.0		
Walnut	SP 2208637-2					2022-05-22	<1.0		
Walnut	SP 2208624-3					2022-05-20	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.05	10
1033 W. La Loma Ave.	SP 2107447-9	mg/L				2021-06-07	ND		
1177 E. La Loma Ave.	SP 2107447-1	mg/L				2021-06-07	0.07		
360 W. La Loma Ave.	SP 2107447-7	mg/L				2021-06-07	ND		
4051 Walnut Ave.	SP 2107447-6	mg/L				2021-06-07	ND		
455 E. La Loma Ave.	SP 2107447-2	mg/L				2021-06-07	ND		
4725 Walnut Ave.	SP 2107447-4	mg/L				2021-06-07	ND		
647 W. La Loma Ave.	SP 2107447-8	mg/L				2021-06-07	ND		
66 E. La Loma Ave.	SP 2107447-3	mg/L				2021-06-07	0.05		
729 Center Rd.	SP 2107447-5	mg/L				2021-06-07	ND		
875 W. Los Angeles Ave.	SP 2107447-10	mg/L				2021-06-07	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			69	69 - 69
WELL 10	SP 2002326-1	mg/L				2020-02-18	69		

<b>Hardness</b>		mg/L		none	none			340	340 - 340
WELL 10	SP 2002326-1	mg/L				2020-02-18	340		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			2	2 - 2
WELL 10	SP 2002326-1	ug/L				2020-02-18	2		
<b>Fluoride</b>		mg/L		2	1			0.3	0.3 - 0.3
WELL 10	SP 2002326-1	mg/L				2020-02-18	0.3		
<b>Nitrate as N</b>		mg/L		10	10			8.2	7.5 - 10.1
WELL 10	SP 2218694-1	mg/L				2022-11-22	7.5		
WELL 10	SP 2213437-1	mg/L				2022-08-18	7.6		
WELL 10	SP 2211704-1	mg/L				2022-07-19	7.7		
WELL 10	SP 2208900-1	mg/L				2022-05-25	8.06		
WELL 10	SP 2208513-1	mg/L				2022-05-19	10.1		
WELL 10	SP 2202983-1	mg/L				2022-02-23	8.0		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			8.3	8.3 - 8.3
WELL 10	SP 2002326-1	mg/L				2020-02-18	8.3		
<b>Selenium</b>		ug/L	50	50	30			20	20 - 20
WELL 10	SP 2002326-1	ug/L				2020-02-18	20		
<b>Gross Alpha</b>		pCi/L		15	(0)			10.8	10.8 - 10.8
WELL 10	SP 2002326-1	pCi/L				2020-02-18	10.8		
<b>Uranium</b>		pCi/L		20	0.43			7.66	7.66 - 7.66
WELL 10	SP 2002326-1	pCi/L				2020-02-18	7.66		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			83	83 - 83
WELL 10	SP 2002326-1	mg/L				2020-02-18	83		
<b>Color</b>		Units		15	n/a			10	10 - 10
WELL 10	SP 2002326-1	Units				2020-02-18	10		
<b>Manganese</b>		ug/L		50	n/a			20	20 - 20
WELL 10	SP 2002326-1	ug/L				2020-02-18	20		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			1020	1020 - 1020
WELL 10	SP 2002326-1	umhos/cm				2020-02-18	1020		
<b>Sulfate</b>		mg/L		500	n/a			137	137 - 137
WELL 10	SP 2002326-1	mg/L				2020-02-18	137		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			640	640 - 640
WELL 10	SP 2002326-1	mg/L				2020-02-18	640		
<b>Turbidity</b>		NTU		5	n/a			0.3	0.3 - 0.3
WELL 10	SP 2002326-1	NTU				2020-02-18	0.3		
<b>Zinc</b>		mg/L		5	n/a			0.05	0.05 - 0.05
WELL 10	SP 2002326-1	mg/L				2020-02-18	0.05		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>		mg/L		NS	n/a			0.2	0.2 - 0.2
WELL 10	SP 2002326-1	mg/L				2020-02-18	0.2		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			85	85 - 85
WELL 10	SP 2002326-1	mg/L				2020-02-18	85		
<b>Magnesium</b>		mg/L			n/a			31	31 - 31
WELL 10	SP 2002326-1	mg/L				2020-02-18	31		

<b>pH</b>		units			n/a			8.2	8.2 - 8.2
WELL 10	SP 2002326-1	units				2020-02-18	8.2		
<b>Alkalinity</b>		mg/L			n/a			180	180 - 180
WELL 10	SP 2002326-1	mg/L				2020-02-18	180		
<b>Aggressiveness Index</b>					n/a			12.8	12.8 - 12.8
WELL 10	SP 2002326-1					2020-02-18	12.8		
<b>Langelier Index</b>					n/a			0.9	0.9 - 0.9
WELL 10	SP 2002326-1					2020-02-18	0.9		

# Del Norte Water Co.

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date Sampled	Method	Description	Property
CuPb-ss09	SP 2107447-9	2021-06-07	Metals, Total	1033 W. La Loma Ave.	Lead & Copper Monitoring
CuPb-ss01	SP 2107447-1	2021-06-07	Metals, Total	1177 E. La Loma Ave.	Lead & Copper Monitoring
	SP 2213570-1	2022-08-21	Coliform	1177 E. La Loma Ave.	Copper & Lead Monitoring
1177 LA LOMA	SP 2208637-3	2022-05-22	Coliform	1177 La Loma	Drinking Water Monitoring
	SP 2208822-1	2022-05-24	Coliform	1177 La Loma	Drinking Water Monitoring
	SP 2213874-5	2022-08-26	Coliform	1177 La Loma	Routine Bacteriological Monitoring
	SP 2213903-1	2022-08-29	Coliform	1177 La Loma	Del Norte Water
	SP 2216842-1	2022-10-19	Coliform	1177 La Loma	Drinking Water Monitoring
	SP 2217987-1	2022-11-10	Coliform	1177 La Loma	Routine Bacteriological Monitoring
1177 Laloma	SP 2208624-2	2022-05-20	Coliform	1177 Laloma	Del Norte Water Company
1201 La Loma	SP 2213570-2	2022-08-21	Coliform	1201 La Loma	Copper & Lead Monitoring
	SP 2213874-4	2022-08-26	Coliform	1201 La Loma	Routine Bacteriological Monitoring
	SP 2213903-2	2022-08-29	Coliform	1201 La Loma	Del Norte Water
CuPb-ss07	SP 2107447-7	2021-06-07	Metals, Total	360 W. La Loma Ave.	Lead & Copper Monitoring
CuPb-ss06	SP 2107447-6	2021-06-07	Metals, Total	4051 Walnut Ave.	Lead & Copper Monitoring
CuPb-ss02	SP 2107447-2	2021-06-07	Metals, Total	455 E. La Loma Ave.	Lead & Copper Monitoring
CuPb-ss04	SP 2107447-4	2021-06-07	Metals, Total	4725 Walnut Ave.	Lead & Copper Monitoring
CuPb-ss08	SP 2107447-8	2021-06-07	Metals, Total	647 W. La Loma Ave.	Lead & Copper Monitoring
CuPb-ss03	SP 2107447-3	2021-06-07	Metals, Total	66 E. La Loma Ave.	Lead & Copper Monitoring
CuPb-ss05	SP 2107447-5	2021-06-07	Metals, Total	729 Center Rd.	Lead & Copper Monitoring
CuPb-ss10	SP 2107447-10	2021-06-07	Metals, Total	875 W. Los Angeles Ave.	Lead & Copper Monitoring
Beck Tank	SP 2213906-1	2022-08-29	Coliform	Beck Tank	Del Note Water
Booster Station	SP 2208624-4	2022-05-20	Coliform	Booster Station	Del Norte Water Company
BOOSTER STA	SP 2208637-1	2022-05-22	Coliform	Booster Station	Drinking Water Monitoring
	SP 2208682-1	2022-05-23	Coliform	Booster Station	Del Norte Water
	SP 2210328-3	2022-06-21	Coliform	Booster Station	Routine Bacteriological Monthly Monitoring
	SP 2213551-1	2022-08-19	Coliform	Booster Station	Del Norte Water
	SP 2213570-3	2022-08-21	Coliform	Booster Station	Copper & Lead Monitoring
	SP 2213874-3	2022-08-26	Coliform	Booster Station	Routine Bacteriological Monitoring
	SP 2213903-5	2022-08-29	Coliform	Booster Station	Del Norte Water
	SP 2214505-2	2022-09-09	Coliform	Booster Station	Routine Bacteriological Monitoring
	SP 2214692-3	2022-09-13	Coliform	Booster Station	Routine Bacteriological Monthly Monitoring
	SP 2214978-2	2022-09-19	Coliform	Booster Station	Drinking Water Monitoring
	SP 2215527-2	2022-09-28	Coliform	Booster Station	Del Norte Water
	SP 2216113-3	2022-10-06	Coliform	Booster Station	Routine Bacteriological Monthly Monitoring
	SP 2216567-2	2022-10-14	Coliform	Booster Station	Drinking Water Monitoring
	SP 2216842-2	2022-10-19	Coliform	Booster Station	Drinking Water Monitoring
	SP 2217301-2	2022-10-28	Coliform	Booster Station	Routine Bacteriological Monitoring
	SP 2217654-2	2022-11-04	Coliform	Booster Station	Drinking Water Monitoring
	SP 2217987-2	2022-11-10	Coliform	Booster Station	Drinking Water Monitoring
	SP 2218493-2	2022-11-18	Coliform	Booster Station	Drinking Water Monitoring
	SP 2218692-4	2022-11-22	Coliform	Booster Station	Drinking Water Monitoring
	SP 2219119-2	2022-12-01	Coliform	Booster Station	Del Norte Water
	SP 2219549-2	2022-12-08	Coliform	Booster Station	Drinking Water Monitoring
	SP 2220068-3	2022-12-16	Coliform	Booster Station	Routine Bacteriological Monthly Monitoring
	SP 2220230-2	2022-12-20	Coliform	Booster Station	Drinking Water Monitoring
	SP 2213601-1	2022-08-22	Coliform	Green tank	Del Norte Water Co.
Bacti-Rout-ss02	SP 2201174-2	2022-01-21	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2202984-2	2022-02-23	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2204318-2	2022-03-17	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring

	SP 2206243-2	2022-04-15	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2208511-2	2022-05-19	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2208682-5	2022-05-23	Coliform	La Loma 1177	Del Norte Water
	SP 2210328-2	2022-06-21	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2211705-2	2022-07-19	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2213435-2	2022-08-18	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2213551-4	2022-08-19	Coliform	La Loma 1177	Del Norte Water
	SP 2214505-1	2022-09-09	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2214692-2	2022-09-13	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2214978-1	2022-09-19	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2215527-1	2022-09-28	Coliform	La Loma 1177	Del Norte Water
	SP 2216113-2	2022-10-06	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2216567-1	2022-10-14	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2217301-1	2022-10-28	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2217654-1	2022-11-04	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2218493-1	2022-11-18	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2218692-2	2022-11-22	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2219119-1	2022-12-01	Coliform	La Loma 1177	Del Norte Water
	SP 2219549-1	2022-12-08	Coliform	La Loma 1177	Routine Bacteriological Monitoring
	SP 2220068-2	2022-12-16	Coliform	La Loma 1177	Routine Bacteriological Monthly Monitoring
	SP 2220230-1	2022-12-20	Coliform	La Loma 1177	Routine Bacteriological Monitoring
Bacti-Rout-ss04	SP 2201174-1	2022-01-21	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2202984-1	2022-02-23	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2204318-1	2022-03-17	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2206243-1	2022-04-15	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2208511-1	2022-05-19	Coliform	Murata	Routine Bacteriological Monthly Monitoring
Murata	SP 2208624-5	2022-05-20	Coliform	Murata	Del Norte Water Company
Bacti-Rout-ss04	SP 2208637-5	2022-05-22	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2208682-4	2022-05-23	Coliform	Murata	Del Norte Water
	SP 2208822-2	2022-05-24	Coliform	Murata	Routine Bacteriological Monitoring
Murata	SP 2208900-2	2022-05-25	Coliform	Murata	Del Norte Water
Bacti-Rout-ss04	SP 2211705-1	2022-07-19	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2213435-1	2022-08-18	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2213551-3	2022-08-19	Coliform	Murata	Del Norte Water
	SP 2213570-5	2022-08-21	Coliform	Murata	Copper & Lead Monitoring
	SP 2213874-1	2022-08-26	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2213903-4	2022-08-29	Coliform	Murata	Del Norte Water
	SP 2214505-3	2022-09-09	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2214692-1	2022-09-13	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2214978-3	2022-09-19	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2215527-3	2022-09-28	Coliform	Murata	Del Norte Water
	SP 2216113-1	2022-10-06	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2216567-3	2022-10-14	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2216842-3	2022-10-19	Coliform	Murata	Drinking Water Monitoring
	SP 2217301-3	2022-10-28	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2217654-3	2022-11-04	Coliform	Murata	Routine Bacteriological Monitoring

	SP 2217987-3	2022-11-10	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2218493-3	2022-11-18	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2218692-1	2022-11-22	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2219119-3	2022-12-01	Coliform	Murata	Del Norte Water
	SP 2219549-3	2022-12-08	Coliform	Murata	Routine Bacteriological Monitoring
	SP 2220068-1	2022-12-16	Coliform	Murata	Routine Bacteriological Monthly Monitoring
	SP 2220230-3	2022-12-20	Coliform	Murata	Routine Bacteriological Monitoring
DBPR-STG2-ss01	SP 2210328-1	2022-06-21	Coliform	MURATA - 875 LA AVE - STG 2 DB	Routine Bacteriological Monthly Monitoring
Murata Blow Off	SP 2208637-4	2022-05-22	Coliform	Murata Blow Off	Routine Bacteriological Monitoring
	SP 2208682-3	2022-05-23	Coliform	Murata Blow Off	Del Norte Water
Murata Blowoff	SP 2210328-6	2022-06-21	Coliform	Murata Blowoff	Routine Bacteriological Monthly Monitoring
	SP 2213551-2	2022-08-19	Coliform	Murata Blowoff	Del Norte Water
	SP 2213570-4	2022-08-21	Coliform	Murata Blowoff	Copper & Lead Monitoring
	SP 2213874-2	2022-08-26	Coliform	Murata Blowoff	Routine Bacteriological Monitoring
Murata Blowoff	SP 2213903-3	2022-08-29	Coliform	Murata Blowoff	Del Norte Water
Walnut	SP 2208624-3	2022-05-20	Coliform	Walnut	Del Norte Water Company
WALNUT	SP 2208637-2	2022-05-22	Coliform	Walnut	Drinking Water Monitoring
	SP 2208682-2	2022-05-23	Coliform	Walnut	Del Norte Water
Walnut	SP 2210328-4	2022-06-21	Coliform	Walnut	Routine Bacteriological Monthly Monitoring
WELL10	SP 2002326-1	2020-02-18	Metals, Total	WELL 10	Well 10 Monitoring
	SP 2002326-1	2020-02-18	Radio Chemistry	WELL 10	Well 10 Monitoring
	SP 2002326-1	2020-02-18	Wet Chemistry	WELL 10	Well 10 Monitoring
	SP 2002326-1	2020-02-18	General Mineral	WELL 10	Well 10 Monitoring
	SP 2202983-1	2022-02-23	Wet Chemistry	WELL 10	Well 10 Monitoring
	SP 2208513-1	2022-05-19	Wet Chemistry	WELL 10	Well 10 Monitoring
	SP 2208900-1	2022-05-25	Wet Chemistry	WELL 10	Del Norte Water
	SP 2211704-1	2022-07-19	Wet Chemistry	WELL 10	DEL NORTE MUTUAL WATER CO.
	SP 2213437-1	2022-08-18	Wet Chemistry	WELL 10	Well 10 Monitoring
	SP 2218694-1	2022-11-22	Wet Chemistry	WELL 10	Well 10 Monitoring