



United Water

CONSERVATION DISTRICT

2018 Consumer Confidence Report

Oxnard-Hueneme Water Delivery System

Board of Directors

Daniel C. Naumann, President
Michael W. Mobley, Vice President
Bruce E. Dandy, Secretary/Treasurer
Sheldon G. Berger
Robert Eranio
Lynn E. Maulhardt
Edwin T. McFadden III

General Manager

Mauricio E. Guardado, Jr.



Testing and Results

Last year we conducted thousands of tests for over 180 chemicals and contaminants that could be found in your drinking water. We did not detect any contaminants that would make the water unsafe to drink. This report highlights the quality of water we delivered to our customers last year. Included are details about where your water comes from, what it contains, and how it compares to State standards. For more information about your water, please call our Operations and Maintenance Manager, Brian Collins at (805) 485-5114.

Public Meetings

Our monthly Board meetings are usually held on the second Wednesday of every month at 1:00 PM in our board room at our "Irv Wilde Headquarters" located at 106 North 8th Street in Santa Paula. Our meetings are open to the public and we would welcome your questions and comments.

About Your Water Supply

United Water's Oxnard-Hueneme Delivery System supplies about 11,500 acre-feet of water per year to several agencies in the Oxnard Plain, including the city of Oxnard, the Port Hueneme Water Agency (PHWA), and several smaller water companies. These agencies supply our water to over 222,000 people, most of it treated or blended with other supplies. Our water source is 100% local groundwater, pumped from wells near El Rio, north of Oxnard. Water from those wells has its origin in the mountains and valleys of the 1,600 square mile Santa Clara River watershed. The wells are in an aquifer called the Oxnard Forebay. Our water is naturally high in minerals that affect its taste, but is safe to drink. Our groundwater is considered to be "under the influence of surface water," which means we do extensive monitoring of turbidity and other parameters to meet health regulations.

United Water Conservation District
106 North 8th Street
Santa Paula, CA 93060
805/525-4431 Fax 805/525-2661
www.unitedwater.org

Water produced by our wells is naturally filtered through the ground. We use chlorine as a disinfectant to kill bacteria, parasites, and viruses. Then we add chloramines to provide a long-lasting disinfection residual to keep the water safe until it reaches our customers. Due to the longer-lasting residual of chloramines, owners of pet fish must treat their tap water before putting it into aquariums or ponds.

Types of Potential Contamination

In general, sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Organic chemical contamination, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems;

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that your tap water is safe to drink, USEPA and the State Water Resources Control Board prescribe regulations that limit the amount of certain contaminants in public drinking water. We treat our water to meet these health regulations. The State Board's regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health. Scientists and health experts are continually studying the effects of various chemicals in drinking water to make sure the public water supply is safe.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Definitions

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect odor, taste and appearance of drinking water.

Primary Drinking Water Standard (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Detection Limit for Reporting (DLR): The level above which a chemical is to be reported.

NA: not applicable

ppm: parts per million, or milligrams per liter

ppb: parts per billion, or micrograms per liter

ND: none detected

pCi/L: picocuries per liter (a measure of radioactivity)

µS/cm: micro-Siemens/centimeter (a measure of conductivity)

TON: threshold odor number

NTU: Nephelometric Turbidity Units

Turbidity

Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our water treatment. Turbidity is measured in units called NTUs. We achieved 100% compliance with turbidity standards in 2018.

Contaminants Detected in 2018

Contaminant	Units	State MCL [MRDL]	PHG (MCLG) [MRDLG]	Avg	Range	Sample Date	Violation	Typical Sources in Drinking Water
Microbiological Contaminants								
Total Coliform Bacteria	Absence/ Presence/ 100ml	Systems that collect <40 samples/month: no more than 1 positive sample	0	Absent	Absent	2018	No	Naturally present in the environment.
Fecal Coliform Bacteria and <i>E.coli</i>	Absence/ Presence/ 100ml	A routine and repeat sample are total coliform positive, and one of these is fecal or <i>E.coli</i> positive	0	Absent	Absent	2018	No	Human and animal fecal waste.
Delivered Water Turbidity	NTU	TT	NA	Highest Single Value 0.11		2018	No	Well corrosion byproducts. Microscopic soil particles.
		95% < 0.2 NTU	NA	100% = Lowest monthly % of samples meeting < 0.2 NTU		2018	No	
Radioactivity Contaminents								
Gross Alpha	pCi/L	15	0	10.46	7.46-14.9	2018	No	Erosion of natural deposits.
Radon	pCi/L	NA	NA	283	0-508	2018	No	Decay of natural deposits.
Uranium	pCi/L	20	0.43	3.6	2.32-5.68	2018	No	Erosion of natural deposits.
Inorganic Contaminants								
Arsenic	ppb	10	0.004	5	4-6	2018	No	Erosion of natural deposits.
Fluoride	ppm	2	1	0.6	0.6-0.6	2018	No	Erosion of natural deposits.
Nitrate (as N)	ppm	10	10	7.75	6.6-8.7	2018	No	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium	ppb	50	30	24.5	21-28	2018	No	Erosion of natural deposits. Discharge from mines, runoff from livestock lots.
Disinfection								
Chloramine Residual (as Cl2)	ppm	[4.0]	[4]	1.54	1.35-1.65	2018	No	Drinking water disinfectant added for treatment.
Disinfection By-Products								
Haloacetic Acids	ppb	60	NA	4	3-5	2018	No	By-product of drinking water disinfection.
Total Trihalomethanes	ppb	80	NA	22	18-26	2018	No	By-product of drinking water disinfection.
Disinfection By-Product Precursors								
Total Organic Carbon (TOC)	ppm	TT	NA	0.65	0-1	2018	No	Various natural and man-made sources.
Secondary Standards								
Chloride	ppm	500	NA	60.5	57-64	2018	No	Leaching from natural mineral deposits.
Sodium	ppm	NA	NA	98.5	96-101	2018	No	Leaching from natural mineral deposits.
Specific Conductance	µS/cm	1600	NA	1508.33	1210-1560	2018	No	Substances that form ions in water; seawater influence
Sulfate	ppm	500	NA	512.17	473-538	2018	Yes	Runoff/leaching from natural deposits.
Total Dissolved Solids, TDS	ppm	1000	NA	1119.17	1090-1150	2018	Yes	Runoff/leaching from natural deposits.
Total Hardness	ppm	NA	NA	643	602-684	2018	No	Leaching from natural mineral deposits.
Iron	ppb	300	NA	0	0-0	2018	No	Leaching from natural deposits.
Manganese	ppb	50	NA	0.37	0-20	2018	No	Leaching from natural deposits.
Unregulated Chemicals								
Boron	ppb	NA	NA	600	600-600	2018	No	Naturally present in the environment.

Water Quality Data

The table on page three lists all of the drinking water contaminants that we detected during the 2018 calendar year. The presence of these contaminants in the water does not indicate that the water poses a health risk. In addition to the contaminants on the table, we tested for many other chemicals which were not detected at significant levels. Please call us if you would like a copy of the complete list of chemicals we tested for and the test results.

Secondary Drinking Water Standards

Chloride, Sodium, Specific Conductance, Sulfate, TDS, Total Hardness, Iron and Manganese are secondary standards related to the taste of the water, and water exceeding the MCL is generally safe for human consumption. Our water exceeds the secondary standards for TDS and Sulfate because of naturally occurring minerals in the water.

Source Water Assessment

United Water completed a Source Water Assessment for its drinking water wells in October 2001. The current report is available for public review at our office in Santa Paula. The assessment provides a survey of potential sources of contamination of the groundwater that supplies our wells. Activities that constitute the highest risk to our water are the following: petroleum storage tanks and fueling operations, septic systems, and animal feed lots that are no longer in use. The most recent update for the Surface Water Sanitary Survey was completed in January of 2016 and was submitted to the State Water Resources Control Board.

Cryptosporidium

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our source water monitoring in 2018 did not indicate the presence of these organisms.

Security of your Water

We have completed a Vulnerability Assessment of our OH water facilities. This work, funded by an EPA grant, has improved the security and safety of our water supply.

Radon

Radon is a radioactive gas that you cannot see, taste or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water through showering, washing dishes and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, you may test the air in your home. There are simple ways to fix a radon problem that are not too costly. For additional information, call the National Safety Council's Radon Hotline (800-SOS-RADON).

About Nitrate

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. Nitrate levels may rise quickly because of rainfall or agricultural activity.

Immuno-compromised Persons

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Hablamos Español

Este informe contiene información muy importante sobre su agua potable. Para información en español llámenos al (805) 525-4431.

2018 Consumer Confidence Report

Water System Name: Saviors Road Mutual Water Company Report Date: May 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: This water is purchased from United Water Conservation District, Santa Paula.

Your water comes from 1 source(s): UWCD Purchased Water

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held Annually, time and place are announced.

For more information about this report, or any questions relating to your drinking water, please call (805)844-6857 and ask for Rosalinda Romo or email rosalinda.romo@navy.mil.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1 and 2 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	20 (2018)	1.2	1	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	19	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2018)	1.73	1.44 - 2.10	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2018)	5	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Saviers Road Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Copper: Copper is an essential nutrient, but some people who use water containing copper in excess of the action level over a relatively short amount of time may experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years may suffer liver or kidney damage. People with Wilson`s Disease should consult their personal doctor.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment has not been completed the UWCD PURCHASED WATER of the SAVIERS ROAD MUTUAL WATER CO water system, as this water is purchased from United Water Conservation District in Santa Paula.

UWCD Purchased Water - is water purchased from United Water Conservation District in Santa Paula.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Analytical Results By FGL - 2018

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			1.24	20
#14 4740 Bradfield St.	SP 1807841-4	mg/L				2018-06-15	0.36		
#20 4801 Refsing Pl.	SP 1812957-9	mg/L				2018-09-26	0.25		
#26 4900 Saviers Rd.	SP 1812957-8	mg/L				2018-09-26	0.35		
#40 4941 Refsing Pl.	SP 1812957-7	mg/L				2018-09-26	0.99		
#52 267 Ashton St.	SP 1812957-1	mg/L				2018-09-26	0.28		
#52 267 Ashton St.	SP 1807841-1	mg/L				2018-06-15	0.28		
#52 267 Ashton St.	SP 1804042-1	mg/L				2018-03-27	0.31		
#54 284 Ashton	SP 1812957-3	mg/L				2018-09-26	0.39		
#63 283 Rose St.	SP 1812957-2	mg/L				2018-09-26	0.14		
#63 283 Rose St.	SP 1807841-2	mg/L				2018-06-15	0.23		
#63 283 Rose St.	SP 1804042-2	mg/L				2018-03-26	0.44		
#68 268 Rose St.	SP 1807841-3	mg/L				2018-06-15	0.26		
#68 268 Rose St.	SP 1804042-3	mg/L				2018-03-26	1.27		
#75 268 Smith St.	SP 1812957-6	mg/L				2018-09-26	0.50		
#86 5012 Bradfield Pl.	SP 1812957-10	mg/L				2018-09-26	0.42		
#92 4846 Bradfield St.	SP 1812957-4	mg/L				2018-09-26	1.24		
#92 4846 Bradfield St.	SP 1804042-4	mg/L				2018-03-26	1.42		
#94 4810 Bradfield St.	SP 1812957-5	mg/L				2018-09-26	0.40		
#94 4810 Bradfield St.	SP 1807841-5	mg/L				2018-06-15	0.36		
#94 4810 Bradfield St.	SP 1804042-5	mg/L				2018-03-27	0.91		

[illegible]

Saviers Road Mutual Water Co.

CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
#14 4740 Bradfi	SP 1807841-4	2018-06-15	Metals, Total	#14 4740 Bradfield St.	Lead & Copper Monitoring
#20 4801 Refsin	SP 1812957-9	2018-09-26	Metals, Total	#20 4801 Refsing Pl.	Lead & Copper Monitoring
#26 4900 Savier	SP 1812957-8	2018-09-26	Metals, Total	#26 4900 Saviers Rd.	Lead & Copper Monitoring
#40 4941 Refi	SP 1812957-7	2018-09-26	Metals, Total	#40 4941 Refsing Pl.	Lead & Copper Monitoring
CuPb03	SP 1804042-1	2018-03-27	Metals, Total	#52 267 Ashton St.	Lead & Copper Monitoring
	SP 1807841-1	2018-06-15	Metals, Total	#52 267 Ashton St.	Lead & Copper Monitoring
	SP 1812957-1	2018-09-26	Metals, Total	#52 267 Ashton St.	Lead & Copper Monitoring
CuPb01	SP 1812957-3	2018-09-26	Metals, Total	#54 284 Ashton	Lead & Copper Monitoring
CuPb02	SP 1804042-2	2018-03-26	Metals, Total	#63 283 Rose St.	Lead & Copper Monitoring
	SP 1807841-2	2018-06-15	Metals, Total	#63 283 Rose St.	Lead & Copper Monitoring
	SP 1812957-2	2018-09-26	Metals, Total	#63 283 Rose St.	Lead & Copper Monitoring
CuPb01	SP 1804042-3	2018-03-26	Metals, Total	#68 268 Rose St.	Lead & Copper Monitoring
	SP 1807841-3	2018-06-15	Metals, Total	#68 268 Rose St.	Lead & Copper Monitoring
#75 268 Smith	SP 1812957-6	2018-09-26	Metals, Total	#75 268 Smith St.	Lead & Copper Monitoring
ROUT01	SP 1800801-1	2018-01-18	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1800801-1	2018-01-18	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1801366-1	2018-02-01	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1801366-1	2018-02-01	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1803684-1	2018-03-19	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1803684-1	2018-03-19	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1805322-1	2018-04-20	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1805322-1	2018-04-20	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1806705-1	2018-05-21	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1806705-1	2018-05-21	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1807380-1	2018-06-06	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1807380-1	2018-06-06	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1809830-1	2018-07-26	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1809830-1	2018-07-26	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1811465-1	2018-08-29	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1811465-1	2018-08-29	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1812317-1	2018-09-14	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1812317-1	2018-09-14	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1813939-1	2018-10-18	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1813939-1	2018-10-18	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1815445-1	2018-11-21	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1815445-1	2018-11-21	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1816328-1	2018-12-10	Coliform	#8 (261 Dollie St.)	Drinking Water Monitoring
	SP 1816328-1	2018-12-10	Field Test	#8 (261 Dollie St.)	Drinking Water Monitoring
#86 5012 Bradfi	SP 1812957-10	2018-09-26	Metals, Total	#86 5012 Bradfield Pl.	Lead & Copper Monitoring
CuPb05	SP 1804042-4	2018-03-26	Metals, Total	#92 4846 Bradfield St.	Lead & Copper Monitoring
	SP 1812957-4	2018-09-26	Metals, Total	#92 4846 Bradfield St.	Lead & Copper Monitoring
CuPb04	SP 1804042-5	2018-03-27	Metals, Total	#94 4810 Bradfield St.	Lead & Copper Monitoring
	SP 1807841-5	2018-06-15	Metals, Total	#94 4810 Bradfield St.	Lead & Copper Monitoring
	SP 1812957-5	2018-09-26	Metals, Total	#94 4810 Bradfield St.	Lead & Copper Monitoring
DBP2	SP 1811471-1	2018-08-29	EPA 551.1	143 DOLLIE ST - STG 2 DBP	TTHM/HAA5 Monitoring
	SP 1811471-1	2018-08-29	EPA 552.2	143 DOLLIE ST - STG 2 DBP	TTHM/HAA5 Monitoring
ROUT01	SP 1704359-1	2017-04-12	Coliform	UWCD Purchased Water	Drinking Water Monitoring