

2018 Consumer Confidence Report

Water System Name: STRICKLAND MUTUAL WATER Co.

Report Date: June 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the Sources are Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): Well 02 and Well 03

Opportunities for public participation in decisions that affect drinking water quality: Water Board meetings are scheduled irregularly, as needed for decision-making, and typically held at 6:30 PM on a weekday. Meeting location varies, please call for more information or, to request to be notified of meetings e-mail Paul McDaniel at mcdanielph@gmail.com

For more information about this report, or any questions relating to your drinking water, please call (805) 647 - 1569 and ask for Theodore Provencio or visit our website at www.stricklandwater.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/mo. (2018)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	5 (2017)	3	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	5 (2017)	0.59	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2017)	125	121 - 129	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2017)	516	510 - 522	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (mg/L)	(2017)	0.4	ND - 0.80	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Fluoride (mg/L)	(2017)	0.6	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2018)	1.9	1.7 - 2.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2017)	2.3	2.0 - 2.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2017)	9	8 - 10	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2017 - 2018)	10	6.98 - 16.5	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2017)	6.23	5.86 - 6.59	20	0.43	Erosion of natural deposits
Uranium (pCi/L)	(2018)	5.672	4.73 - 6.231	20	0.43	Erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2017)	56	54 - 57	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2017)	720	ND - 1440	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2017)	55	ND - 110	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2017)	1450	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2017)	502	499 - 504	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2017)	1060	1030 - 1090	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2017)	5	0.4 - 9.6	5	n/a	Soil runoff
Zinc (mg/L)	(2017)	0.34	ND - 0.68	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2017)	0.6	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (mg/L)	(2017)	ND	ND - 0.004	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - ADDITIONAL DETECTIONS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant	
Calcium (mg/L)	(2017)	134	132 - 135	n/a	n/a	

Magnesium (mg/L)	(2017)	45	44 - 45	n/a	n/a
pH (units)	(2017)	7.5	7.2 - 7.7	n/a	n/a
Alkalinity (mg/L)	(2017)	215	200 - 230	n/a	n/a
Aggressiveness Index	(2017)	12.3	12.0 - 12.6	n/a	n/a
Langelier Index	(2017)	0.4	0.1 - 0.7	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	22	n/a	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2018)	3	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *The Mutual Water Co of Strickland Tract* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Total Coliform Bacteria: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

About our Gross Alpha: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and

clothing while washing. Violating this MCL does not pose a risk to public health.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic effects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

About our Total Dissolved Solids: The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic effects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

About our Turbidity: Turbidity is Secondary Drinking Water Standards and has found no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

2018 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 of the STRICKLAND ACRES water system in May, 2001.

Well 02 - are considered vulnerable to the following activities not associated with any detected contaminants:
Septic systems - high density [>1 /acre]

Well 03 - are considered vulnerable to the following activities not associated with any detected contaminants:
Septic systems - high density [>1 /acre]

Discussion of Vulnerability

Following the 2001 sanitary survey, the Strickland Acres area was converted to sewers and all septic tanks in the Strickland Mutual Water service area were abandoned. Three septic systems remain in use nearby at homes along Vineyard Avenue, adjacent to but outside the Strickland Mutual Water Company service area.

Acquiring Information

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore

District Engineer

805 566 1326

The Mutual Water Co of Strickland Tract

Analytical Results By FGL - 2018

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	1 - 1
4771 Burson St.	SP 1811993-3					2018-09-07	<1.0		
4779 Burson Way	SP 1814870-1					2018-11-08	Absent		
4779 Burson Way	SP 1811993-1					2018-09-07	<1.0		
4779 Burson Way	SP 1811890-1					2018-09-06	Present		
4779 Burson Way	SP 1809435-1					2018-07-18	Absent		
4779 Burson Way	SP 1806984-2					2018-05-27	Absent		
4779 Burson Way	SP 1806981-2					2018-05-26	Absent		
4779 Burson Way	SP 1806973-2					2018-05-25	<1.0		
4779 Burson Way	SP 1806393-1					2018-05-14	Absent		
4779 Burson Way	SP 1802740-1					2018-03-01	Absent		
4779 Burson Way	SP 1800186-1					2018-01-05	Absent		
4807 Burson St.	SP 1811993-2					2018-09-07	<1.0		
4919 Strickland Dr.	SP 1806984-3					2018-05-27	Absent		
4919 Strickland Dr.	SP 1806981-3					2018-05-26	Absent		
4919 Strickland Drive	SP 1816132-1					2018-12-05	Absent		
4919 Strickland Drive	SP 1814051-1					2018-10-22	Absent		
4919 Strickland Drive	SP 1811131-1					2018-08-23	Absent		
4919 Strickland Drive	SP 1807738-1					2018-06-13	Absent		
4919 Strickland Drive	SP 1806973-1					2018-05-25	<1.0		
4919 Strickland Drive	SP 1804640-1					2018-04-06	Absent		
4919 Strickland Drive	SP 1801493-1					2018-02-05	Absent		
Well 02 Bact 2	SP 1806933-1					2018-05-25	1		
Well 02 Bact 3	SP 1806933-2					2018-05-25	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			3	5
CuPb- 363 Central Ave.	SP 1711445-5	ug/L				2017-09-15	ND		
CuPb- 4878 Joan Wy.	SP 1711445-2	ug/L				2017-09-14	6.0		
CuPb- 4920 Strickland Dr.	SP 1711445-3	ug/L				2017-09-16	ND		
CuPb- 4941 Perry Wy.	SP 1711445-1	ug/L				2017-09-15	ND		
CuPb- 4979 Burson Wy.	SP 1711445-4	ug/L				2017-09-15	ND		
Copper		mg/L		1.3	.3			0.585	5
CuPb- 363 Central Ave.	SP 1711445-5	mg/L				2017-09-15	0.12		
CuPb- 4878 Joan Wy.	SP 1711445-2	mg/L				2017-09-14	1.00		
CuPb- 4920 Strickland Dr.	SP 1711445-3	mg/L				2017-09-16	0.14		
CuPb- 4941 Perry Wy.	SP 1711445-1	mg/L				2017-09-15	ND		
CuPb- 4979 Burson Wy.	SP 1711445-4	mg/L				2017-09-15	0.17		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			125	121 - 129
Well 02	SP 1715789-1	mg/L				2017-12-22	121		
Well 03	SP 1703596-1	mg/L				2017-03-23	129		
Hardness		mg/L		none	none			516	510 - 522
Well 02	SP 1715789-1	mg/L				2017-12-22	510		
Well 03	SP 1703596-1	mg/L				2017-03-23	522		

PRIMARY DRINKING WATER STANDARDS (PDWS)	
---	--

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Aluminum		mg/L		1	0.6			0.40	ND - 0.80
Well 02	SP 1715789-1	mg/L				2017-12-22	0.80		
Well 03	SP 1703596-1	mg/L				2017-03-23	ND		
Fluoride		mg/L		2	1			0.6	0.6 - 0.6
Well 02	SP 1715789-1	mg/L				2017-12-22	0.6		
Well 03	SP 1703596-1	mg/L				2017-03-23	0.6		
Nitrate as N		mg/L		10	10			1.9	1.7 - 2.1
Well 02	SP 1811887-1	mg/L				2018-09-06	1.7		
Well 03	SP 1802442-1	mg/L				2018-02-22	2.1		
Nitrate + Nitrite as N		mg/L		10	10			2.3	2.0 - 2.6
Well 02	SP 1715789-1	mg/L				2017-12-22	2.0		
Well 03	SP 1703596-1	mg/L				2017-03-23	2.6		
Selenium		ug/L	50	50	30			9	8 - 10
Well 02	SP 1715789-1	ug/L				2017-12-22	8		
Well 03	SP 1703596-1	ug/L				2017-03-23	10		
Gross Alpha		pCi/L		15	(0)			10.37	6.98 - 16.5
Well 02	SP 1703536-2	pCi/L				2017-03-22	7.05		
Well 03	SP 1814872-1	pCi/L				2018-11-08	6.98		
Well 03	SP 1811349-1	pCi/L				2018-08-27	11.9		
Well 03	SP 1806395-1	pCi/L				2018-05-14	9.44		
Well 03	SP 1802442-1	pCi/L				2018-02-22	16.5		
Uranium		pCi/L		20	0.43			6.23	5.86 - 6.59
Well 02	SP 1703536-2	pCi/L				2017-03-22	5.86		
Well 03	SP 1703596-1	pCi/L				2017-03-23	6.59		
Uranium		pCi/L		20	0.43			5.672	4.73 - 6.231
Well 03	SP 1814872-1	pCi/L				2018-11-08	4.73		
Well 03	SP 1811349-1	pCi/L				2018-08-27	6.10		
Well 03	SP 1806395-1	pCi/L				2018-05-14	6.231		
Well 03	SP 1802442-1	pCi/L				2018-02-22	5.628		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			56	54 - 57
Well 02	SP 1715789-1	mg/L				2017-12-22	54		
Well 03	SP 1703596-1	mg/L				2017-03-23	57		
Iron		ug/L		300	n/a			720	ND - 1440
Well 02	SP 1715789-1	ug/L				2017-12-22	1440		
Well 03	SP 1703596-1	ug/L				2017-03-23	ND		
Manganese		ug/L		50	n/a			55	ND - 110
Well 02	SP 1715789-1	ug/L				2017-12-22	110		
Well 03	SP 1703596-1	ug/L				2017-03-23	ND		
Specific Conductance		umhos/cm		1600	n/a			1450	1450 - 1450
Well 02	SP 1715789-1	umhos/cm				2017-12-22	1450		
Well 03	SP 1703596-1	umhos/cm				2017-03-23	1450		
Sulfate		mg/L		500	n/a			502	499 - 504
Well 02	SP 1715789-1	mg/L				2017-12-22	499		
Well 03	SP 1703596-1	mg/L				2017-03-23	504		
Total Dissolved Solids		mg/L		1000	n/a			1060	1030 - 1090
Well 02	SP 1715789-1	mg/L				2017-12-22	1090		
Well 03	SP 1703596-1	mg/L				2017-03-23	1030		
Turbidity		NTU		5	n/a			5.0	0.4 - 9.6
Well 02	SP 1715789-1	NTU				2017-12-22	9.6		
Well 03	SP 1703596-1	NTU				2017-03-23	0.4		
Zinc		mg/L		5	n/a			0.34	ND - 0.68
Well 02	SP 1715789-1	mg/L				2017-12-22	0.68		
Well 03	SP 1703596-1	mg/L				2017-03-23	ND		

The Mutual Water Co of Strickland Tract

CCR Login Linkage - 2018

FGL Code	Lab ID	Date Sampled	Method	Description	Property
Bacti-Rpt-ss01U	SP 1811993-3	2018-09-07	Coliform	4771 Burson St.	Bacti Resample
Bacti-Rout1-Odd	SP 1800186-1	2018-01-05	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
	SP 1802740-1	2018-03-01	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
	SP 1806393-1	2018-05-14	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
	SP 1806973-2	2018-05-25	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
4779 Burson Way	SP 1806981-2	2018-05-26	Coliform	4779 Burson Way	Special Bacteriological Monitoring
	SP 1806984-2	2018-05-27	Coliform	4779 Burson Way	Special Bacteriological Monitoring
Bacti-Rout1-Odd	SP 1809435-1	2018-07-18	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
	SP 1811890-1	2018-09-06	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
	SP 1811993-1	2018-09-07	Coliform	4779 Burson Way	Bacti Resample
	SP 1814870-1	2018-11-08	Coliform	4779 Burson Way	Routine Bacteriological Monitoring - Odd
Bacti-Rpt-ss01D	SP 1811993-2	2018-09-07	Coliform	4807 Burson St.	Bacti Resample
4919 Strickland	SP 1806981-3	2018-05-26	Coliform	4919 Strickland Dr.	Special Bacteriological Monitoring
	SP 1806984-3	2018-05-27	Coliform	4919 Strickland Dr.	Special Bacteriological Monitoring
Bacti-Rout2-Eve	SP 1801493-1	2018-02-05	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1804640-1	2018-04-06	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1806973-1	2018-05-25	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1807738-1	2018-06-13	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1811131-1	2018-08-23	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1814051-1	2018-10-22	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
	SP 1816132-1	2018-12-05	Coliform	4919 Strickland Drive	Routine Bacteriological Monitoring - Even
CuPb-ss05	SP 1711445-5	2017-09-15	Metals, Total	CuPb- 363 Central Ave.	Copper & Lead Monitoring
CuPb-ss02	SP 1711445-2	2017-09-14	Metals, Total	CuPb- 4878 Joan Wy.	Copper & Lead Monitoring
CuPb-ss03	SP 1711445-3	2017-09-16	Metals, Total	CuPb- 4920 Strickland Dr.	Copper & Lead Monitoring
CuPb-ss01	SP 1711445-1	2017-09-15	Metals, Total	CuPb- 4941 Perry Wy.	Copper & Lead Monitoring
CuPb-ss04	SP 1711445-4	2017-09-15	Metals, Total	CuPb- 4979 Burson Wy.	Copper & Lead Monitoring
DBP-Stg2-ss01	SP 1809434-1	2018-07-18	EPA 551.1	STG 2 - 443 Central Ave	DBP Monitoring
	SP 1809434-1	2018-07-18	EPA 552.2	STG 2 - 443 Central Ave	DBP Monitoring
WELL 02	SP 1703536-2	2017-03-22	Radio Chemistry	Well 02	Radio Monitoring
	SP 1715789-1	2017-12-22	Metals, Total	Well 02	Well Monitoring
	SP 1715789-1	2017-12-22	Wet Chemistry	Well 02	Well Monitoring
	SP 1715789-1	2017-12-22	General Mineral	Well 02	Well Monitoring
	SP 1811887-1	2018-09-06	Wet Chemistry	Well 02	Well Monitoring
Well 02 Bact 2	SP 1806933-1	2018-05-25	Coliform	Well 02 Bact 2	Bacteriological Monitoring
Well 02 Bact 3	SP 1806933-2	2018-05-25	Coliform	Well 02 Bact 3	Bacteriological Monitoring
WELL 03	SP 1703596-1	2017-03-23	General Mineral	Well 03	New Well - Title 22
	SP 1703596-1	2017-03-23	Metals, Total	Well 03	New Well - Title 22
	SP 1703596-1	2017-03-23		Well 03	New Well - Title 22
	SP 1703596-1	2017-03-23	Wet Chemistry	Well 03	New Well - Title 22
	SP 1703596-1	2017-03-23	Sub Contracted	Well 03	New Well - Title 22
	SP 1703596-1	2017-03-23	Radio Chemistry	Well 03	New Well - Title 22
	SP 1802442-1	2018-02-22	Metals, Total	Well 03	Well 3 - Water Quality
	SP 1802442-1	2018-02-22	Radio Chemistry	Well 03	Well 3 - Water Quality
	SP 1802442-1	2018-02-22	Wet Chemistry	Well 03	Well 3 - Water Quality
	SP 1806395-1	2018-05-14	Radio Chemistry	Well 03	Well 3 - Water Quality
	SP 1806395-1	2018-05-14	Metals, Total	Well 03	Well 3 - Water Quality
	SP 1811349-1	2018-08-27	Radio Chemistry	Well 03	Well 3 - Water Quality
	SP 1811349-1	2018-08-27	Metals, Total	Well 03	Well 3 - Water Quality
	SP 1814872-1	2018-11-08	Radio Chemistry	Well 03	Well 3 - Water Quality
	SP 1814872-1	2018-11-08	Metals, Total	Well 03	Well 3 - Water Quality