

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL</b>
Water System Number:	<b>CA5602120</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	(     )	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

---



---

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> \_\_\_\_\_
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2023 Consumer Confidence Report

Water System Name: VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL Report Date: March 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** The Assessment was conducted by CDPH District Office. According to CDPH records, Well 1 and Well 2 are Groundwater. This Assessment was done using the Default Groundwater System Method. The VINEYARD MUTUAL WATER COMPANY system is located in Ventura County and serves the surrounding commercial and industrial areas. There are approximately 52 service connections serving a population of 140.

**Your water comes from 2 source(s):** WELL 01 and WELL 02

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held Annually at 5725 Ralston St., Ste. 200 Ventura, CA 93003 every 2nd Monday in April at 10:00A.M.

For more information about this report, or any questions relating to your drinking water, please call (805) 654 - 1077 and ask for John Ferro or email [vmw5725@gmail.com](mailto:vmw5725@gmail.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>							
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>No. of Samples</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Copper (mg/L)	(2021)	5	0.13	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (mg/L)	(2022)	91	90 - 92	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	463	452 - 473	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

<b>Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Fluoride (mg/L)	(2022)	0.6	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (mg/L)	(2023)	1.9	1.8 - 1.9	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	1.8	1.4 - 2.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2022)	7	6 - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2018)	9.72	7.53 - 11.9	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2018)	6.566	5.762 - 7.37	20	0.43	Erosion of natural deposits

**Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	45	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2022)	1340	1320 - 1360	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	391	385 - 397	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	950	940 - 960	1000	n/a	Runoff/leaching from natural deposits

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2022)	0.6	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Perfluorooctanesulfonic Acid [PFOS] (ng/L)	(2022)	1.2	ND - 2.2	6.5	Perfluorooctanesulfonic acid exposures resulted in immune suppression and cancer in laboratory animals.

**Table 6 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	120	117 - 122	n/a	n/a
Magnesium (mg/L)	(2022)	40	39 - 41	n/a	n/a
pH (units)	(2022)	7.33	7.21 - 7.45	n/a	n/a
Alkalinity (mg/L)	(2022)	195	190 - 200	n/a	n/a
Aggressiveness Index	(2022)	12.1	12.0 - 12.2	n/a	n/a
Langelier Index	(2022)	0.19	0.07 - 0.3	n/a	n/a

**Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2022)	19	n/a	80	n/a	No	By-product of drinking water disinfection

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Vineyard Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## **2023 Consumer Confidence Report Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL 01 and the WELL 02 of the VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL water system in March, 2012.

WELL 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

### **Acquiring Information**

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore

District Engineer

805 566 1326

# Vineyard Mutual Water Co.

## Analytical Results By FGL - 2023

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.13	5
162 MTG	SP 2108697-1	mg/L				2021-06-28	ND		
249 MTG	SP 2108697-2	mg/L				2021-06-28	0.09		
319 A LBT	SP 2108697-4	mg/L				2021-06-28	0.15		
3897 NSB Pacific Equip	SP 2108697-5	mg/L				2021-06-28	ND		
4121 NSB	SP 2108697-3	mg/L				2021-06-28	0.11		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			91	90 - 92
WELL 01	SP 2205403-1	mg/L				2022-04-05	90		
WELL 02	SP 2205403-2	mg/L				2022-04-05	92		
<b>Hardness</b>		mg/L		none	none			463	452 - 473
WELL 01	SP 2205403-1	mg/L				2022-04-05	473		
WELL 02	SP 2205403-2	mg/L				2022-04-05	452		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Fluoride</b>		mg/L		2	1			0.6	0.6 - 0.6
WELL 01	SP 2205403-1	mg/L				2022-04-05	0.6		
WELL 02	SP 2205403-2	mg/L				2022-04-05	0.6		
<b>Nitrate as N</b>		mg/L		10	10			1.9	1.8 - 1.9
WELL 01	SP 2305888-1	mg/L				2023-04-19	1.8		
WELL 02	SP 2305888-2	mg/L				2023-04-19	1.9		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			1.8	1.4 - 2.2
WELL 01	SP 2205403-1	mg/L				2022-04-05	1.4		
WELL 02	SP 2205403-2	mg/L				2022-04-05	2.2		
<b>Selenium</b>		ug/L	50	50	30			7	6 - 7
WELL 01	SP 2205403-1	ug/L				2022-04-05	6		
WELL 02	SP 2205403-2	ug/L				2022-04-05	7		
<b>Gross Alpha</b>		pCi/L		15	(0)			9.72	7.53 - 11.9
WELL 01	SP 1805126-1	pCi/L				2018-04-17	7.53		
WELL 02	SP 1805126-2	pCi/L				2018-04-17	11.9		
<b>Uranium</b>		pCi/L		20	0.43			6.566	5.762 - 7.37
WELL 01	SP 1805126-1	pCi/L				2018-04-17	5.762		
WELL 02	SP 1805126-2	pCi/L				2018-04-17	7.37		

### SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			45	45 - 45
WELL 01	SP 2205403-1	mg/L				2022-04-05	45		
WELL 02	SP 2205403-2	mg/L				2022-04-05	45		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			1340	1320 - 1360
WELL 01	SP 2205403-1	umhos/cm				2022-04-05	1320		
WELL 02	SP 2205403-2	umhos/cm				2022-04-05	1360		
<b>Sulfate</b>		mg/L		500	n/a			391	385 - 397
WELL 01	SP 2205403-1	mg/L				2022-04-05	385		
WELL 02	SP 2205403-2	mg/L				2022-04-05	397		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			950	940 - 960
WELL 01	SP 2205403-1	mg/L				2022-04-05	940		



# Vineyard Mutual Water Co.

## CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-Odd	SP 2300749-1	2023-01-18	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
	SP 2302938-1	2023-03-01	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
	SP 2307293-1	2023-05-08	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
	SP 2311777-1	2023-07-11	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
	SP 2315325-1	2023-09-11	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
	SP 2318551-1	2023-11-06	Coliform	162 Montgomery	Bacteriological Monitoring-Odd
DBP-Stg2-ss01	SP 2214554-1	2022-09-12	EPA 551.1	162 Montgomery Avenue - STG 2	Stage 2 DBP - THMs/HAA5
CuPb-ss01	SP 2108697-1	2021-06-28	Metals, Total	162 MTG	Copper & Lead Monitoring
CuPb-ss02	SP 2108697-2	2021-06-28	Metals, Total	249 MTG	Copper & Lead Monitoring
Bacti-Rout-Even	SP 2301595-1	2023-02-02	Coliform	301 Lambert	Bacteriological Monitoring-Even
	SP 2305695-1	2023-04-17	Coliform	301 Lambert	Bacteriological Monitoring-Even
	SP 2309340-1	2023-06-06	Coliform	301 Lambert	Bacteriological Monitoring-Even
	SP 2313234-1	2023-08-03	Coliform	301 Lambert	Bacteriological Monitoring-Even
	SP 2317624-1	2023-10-18	Coliform	301 Lambert	Bacteriological Monitoring-Even
	SP 2320190-1	2023-12-07	Coliform	301 Lambert	Bacteriological Monitoring-Even
CuPb-ss04	SP 2108697-4	2021-06-28	Metals, Total	319 A LBT	Copper & Lead Monitoring
CuPb-ss05	SP 2108697-5	2021-06-28	Metals, Total	3897 NSB Pacific Equip	Copper & Lead Monitoring
CuPb-ss03	SP 2108697-3	2021-06-28	Metals, Total	4121 NSB	Copper & Lead Monitoring
WELL 01	SP 1805126-1	2018-04-17	Radio Chemistry	WELL 01	Radiochem Monitoring
	SP 1805126-1	2018-04-17	Metals, Total	WELL 01	Radiochem Monitoring
	SP 2014088-1	2020-10-13		WELL 01	PFAS Monitoring
	SP 2100981-1	2021-01-25		WELL 01	PFAS Monitoring
	SP 2104896-1	2021-04-13		WELL 01	PFAS Monitoring
	SP 2108771-1	2021-07-01	Asbestos	WELL 01	Compliance Monitoring
	SP 2201320-1	2022-01-25		WELL 01	PFAS Monitoring
	SP 2205403-1	2022-04-05	Metals, Total	WELL 01	Water Quality Monitoring
	SP 2205403-1	2022-04-05	General Mineral	WELL 01	Water Quality Monitoring
	SP 2206761-1	2022-04-25		WELL 01	PFAS Monitoring
	SP 2213648-1	2022-08-23		WELL 01	PFAS Monitoring
	SP 2217060-1	2022-10-25		WELL 01	PFAS Monitoring
	SP 2305888-1	2023-04-19	Wet Chemistry	WELL 01	Water Quality Monitoring
WELL 02	SP 1805126-2	2018-04-17	Radio Chemistry	WELL 02	Radiochem Monitoring
	SP 1805126-2	2018-04-17	Metals, Total	WELL 02	Radiochem Monitoring
	SP 2104896-3	2021-04-13		WELL 02	PFAS Monitoring
	SP 2108771-2	2021-07-01		WELL 02	Compliance Monitoring
	SP 2115278-3	2021-10-27		WELL 02	PFAS Monitoring
	SP 2201320-3	2022-01-25		WELL 02	PFAS Monitoring
	SP 2205403-2	2022-04-05	Metals, Total	WELL 02	Water Quality Monitoring
	SP 2205403-2	2022-04-05	General Mineral	WELL 02	Water Quality Monitoring
	SP 2206761-3	2022-04-25		WELL 02	PFAS Monitoring
	SP 2213648-3	2022-08-23		WELL 02	PFAS Monitoring
	SP 2305888-2	2023-04-19	Wet Chemistry	WELL 02	Water Quality Monitoring
Bacti-Source-W1	SP 2305887-1	2023-04-19	Coliform	Well 1	Bacteriological Monitoring-Quarterly
WELL 01	SP 2312454-1	2023-07-20	Coliform	Well 1	Bacteriological Monitoring-Quarterly
Bacti-Source-W1	SP 2318086-1	2023-10-26	Coliform	Well 1	Bacteriological Monitoring-Quarterly
Bacti-Source-W2	SP 2300750-2	2023-01-18	Coliform	Well 2	Bacteriological Monitoring-Quarterly
	SP 2305887-2	2023-04-19	Coliform	Well 2	Bacteriological Monitoring-Quarterly
WELL 02	SP 2312454-2	2023-07-20	Coliform	Well 2	Bacteriological Monitoring-Quarterly
Bacti-Source-W2	SP 2318086-2	2023-10-26	Coliform	Well 2	Bacteriological Monitoring-Quarterly