

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL
Water System Number:	CA5602120

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

- "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
 - Posted the CCR on the internet at http:// _____
 - Mailed the CCR to postal patrons within the service area (attach zip codes used)
 - Advertised the availability of the CCR in news media (attach a copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Other (attach a list of other methods used)

- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

- For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2024 Consumer Confidence Report

Water System Name: VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL Report Date: March 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: The Assessment was conducted by CDPH District Office. According to CDPH records, Well 1 and Well 2 are Groundwater. This Assessment was done using the Default Groundwater System Method. The VINEYARD MUTUAL WATER COMPANY system is located in Ventura County and serves the surrounding commercial and industrial areas. There are approximately 52 service connections serving a population of 140.

Your water comes from 2 source(s): Well 01 and WELL 02

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held Annually at 5725 Ralston St., Ste. 200 Ventura, CA 93003 every 2nd Monday in April at 10:00A.M.

For more information about this report, or any questions relating to your drinking water, please call (805) 654 - 1077 and ask for John Ferro or email vmw5725@gmail.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2024)	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	5	0.08	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	91	90 - 92	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	463	452 - 473	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant

Fluoride (mg/L)	(2022)	0.6	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2023 - 2024)	1.5	1.3 - 1.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	1.8	1.4 - 2.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2022)	7	6 - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2018 - 2024)	6.42	4.05 - 7.69	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2018)	6.566	5.762 - 7.37	20	0.43	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	45	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2022)	1340	1320 - 1360	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	391	385 - 397	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	950	940 - 960	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2022)	0.6	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Perfluorooctanesulfonic Acid [PFOS] (ng/L)	(2022)	1.2	ND - 2.2	6.5	Perfluorooctanesulfonic acid exposures resulted in immune suppression and cancer in laboratory animals.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	120	117 - 122	n/a	n/a
Magnesium (mg/L)	(2022)	40	39 - 41	n/a	n/a
pH (units)	(2022)	7.33	7.21 - 7.45	n/a	n/a
Alkalinity (mg/L)	(2022)	195	190 - 200	n/a	n/a
Aggressiveness Index	(2022)	12.1	12.0 - 12.2	n/a	n/a
Langelier Index	(2022)	0.19	0.07 - 0.3	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2022)	19	n/a	80	n/a	No	By-product of drinking water disinfection

Chlorine, Free (mg/L)	(2024)	1.00	0.88 - 1.13	4.0	4.0	No	Drinking water disinfectant added for treatment.
-----------------------	--------	------	-------------	-----	-----	----	--

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Vineyard Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2024 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 and the WELL 02 of the VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL water system in March, 2012.

Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Automobile - Body shops
 Automobile - Repair shops
 Sewer collection systems

WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Automobile - Body shops
 Automobile - Repair shops
 Sewer collection systems

Acquiring Information

A copy of the complete assessment may be viewed at:
 SWRCB Division of Drinking Water
 1180 Eugenia Place
 Suite 200
 Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
 Jeff Densmore
 District Engineer
 805 566 1326

Vineyard Mutual Water Co.

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
162 Montgomery	SP 2419215-1					2024-11-21	Absent		
162 Montgomery	SP 2414886-1					2024-09-12	Absent		
162 Montgomery	SP 2411421-1					2024-07-15	Absent		
162 Montgomery	SP 2406652-1					2024-05-01	Absent		
162 Montgomery	SP 2403103-1					2024-03-05	Absent		
162 Montgomery	SP 2400042-1					2024-01-02	Absent		
301 Lambert	SP 2419777-1					2024-12-03	Absent		
301 Lambert	SP 2416468-1					2024-10-08	Absent		
301 Lambert	SP 2412468-1					2024-08-05	Absent		
301 Lambert	SP 2409864-1					2024-06-18	Absent		
301 Lambert	SP 2405754-1					2024-04-16	Absent		
301 Lambert	SP 2401765-1					2024-02-06	Absent		
Well 1	SP 2416480-1					2024-10-08	<1		
Well 1	SP 2411804-1					2024-07-22	<1		
Well 1	SP 2406179-1					2024-04-23	<1		
Well 1	SP 2400563-1					2024-01-11	<1		
Well 2	SP 2416480-2					2024-10-08	<1		
Well 2	SP 2411804-2					2024-07-22	<1		
Well 2	SP 2406179-2					2024-04-23	<1		
Well 2	SP 2400563-2					2024-01-11	<1		
Fecal coliform and E. coli			0		n/a			ND	-
162 Montgomery	SP 2419215-1					2024-11-21	Absent		
162 Montgomery	SP 2414886-1					2024-09-12	Absent		
162 Montgomery	SP 2411421-1					2024-07-15	Absent		
162 Montgomery	SP 2406652-1					2024-05-01	Absent		
162 Montgomery	SP 2403103-1					2024-03-05	Absent		
162 Montgomery	SP 2400042-1					2024-01-02	Absent		
301 Lambert	SP 2419777-1					2024-12-03	Absent		
301 Lambert	SP 2416468-1					2024-10-08	Absent		
301 Lambert	SP 2412468-1					2024-08-05	Absent		
301 Lambert	SP 2409864-1					2024-06-18	Absent		
301 Lambert	SP 2405754-1					2024-04-16	Absent		
301 Lambert	SP 2401765-1					2024-02-06	Absent		
Well 1	SP 2416480-1					2024-10-08	<1		
Well 1	SP 2411804-1					2024-07-22	<1		
Well 1	SP 2406179-1					2024-04-23	<1		
Well 1	SP 2400563-1					2024-01-11	<1		
Well 2	SP 2416480-2					2024-10-08	<1		
Well 2	SP 2411804-2					2024-07-22	<1		
Well 2	SP 2406179-2					2024-04-23	<1		
Well 2	SP 2400563-2					2024-01-11	<1		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
162 MTG	SP 2409491-1	ug/L				2024-06-12	ND		
249 MTG	SP 2409491-2	ug/L				2024-06-12	ND		
319 A LBT	SP 2409491-4	ug/L				2024-06-12	ND		
3897 NSB Pacific Equip	SP 2409491-5	ug/L				2024-06-12	ND		
4121 NSB	SP 2409491-3	ug/L				2024-06-12	ND		
Copper		mg/L		1.3	.3			0.08	5
162 MTG	SP 2409491-1	mg/L				2024-06-12	0.11		

249 MTG	SP 2409491-2	mg/L				2024-06-12	ND		
319 A LBT	SP 2409491-4	mg/L				2024-06-12	ND		
3897 NSB Pacific Equip	SP 2409491-5	mg/L				2024-06-12	0.05		
4121 NSB	SP 2409491-3	mg/L				2024-06-12	0.05		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			91	90 - 92
WELL 01	SP 2205403-1	mg/L				2022-04-05	90		
Well 02	SP 2205403-2	mg/L				2022-04-05	92		
Hardness		mg/L		none	none			463	452 - 473
WELL 01	SP 2205403-1	mg/L				2022-04-05	473		
Well 02	SP 2205403-2	mg/L				2022-04-05	452		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.6	0.6 - 0.6
WELL 01	SP 2205403-1	mg/L				2022-04-05	0.6		
Well 02	SP 2205403-2	mg/L				2022-04-05	0.6		
Nitrate as N		mg/L		10	10			1.5	1.3 - 1.8
Well 01	SP 2406177-1	mg/L				2024-04-23	1.3		
WELL 01	SP 2305888-1	mg/L				2023-04-19	1.8		
Well 02	SP 2406177-2	mg/L				2024-04-23	1.5		
Nitrate + Nitrite as N		mg/L		10	10			1.8	1.4 - 2.2
WELL 01	SP 2205403-1	mg/L				2022-04-05	1.4		
Well 02	SP 2205403-2	mg/L				2022-04-05	2.2		
Selenium		ug/L	50	50	30			7	6 - 7
WELL 01	SP 2205403-1	ug/L				2022-04-05	6		
Well 02	SP 2205403-2	ug/L				2022-04-05	7		
Gross Alpha		pCi/L		15	(0)			6.42	4.05 - 7.69
Well 01	SP 2406176-1	pCi/L				2024-04-23	4.05		
WELL 01	SP 1805126-1	pCi/L				2018-04-17	7.53		
Well 02	SP 2406176-2	pCi/L				2024-04-23	7.69		
Uranium		pCi/L		20	0.43			6.566	5.762 - 7.37
WELL 01	SP 1805126-1	pCi/L				2018-04-17	5.762		
Well 02	SP 1805126-2	pCi/L				2018-04-17	7.37		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			45	45 - 45
WELL 01	SP 2205403-1	mg/L				2022-04-05	45		
Well 02	SP 2205403-2	mg/L				2022-04-05	45		
Specific Conductance		umhos/cm		1600	n/a			1340	1320 - 1360
WELL 01	SP 2205403-1	umhos/cm				2022-04-05	1320		
Well 02	SP 2205403-2	umhos/cm				2022-04-05	1360		
Sulfate		mg/L		500	n/a			391	385 - 397
WELL 01	SP 2205403-1	mg/L				2022-04-05	385		
Well 02	SP 2205403-2	mg/L				2022-04-05	397		
Total Dissolved Solids		mg/L		1000	n/a			950	940 - 960
WELL 01	SP 2205403-1	mg/L				2022-04-05	940		
Well 02	SP 2205403-2	mg/L				2022-04-05	960		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.6	0.6 - 0.6
WELL 01	SP 2205403-1	mg/L				2022-04-05	0.6		

Vineyard Mutual Water Co.

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property	
Bacti-Rout-Odd	SP 2400042-1	2024-01-02	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2400042-1	2024-01-02	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2403103-1	2024-03-05	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2403103-1	2024-03-05	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2406652-1	2024-05-01	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2406652-1	2024-05-01	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2411421-1	2024-07-15	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2411421-1	2024-07-15	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2414886-1	2024-09-12	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2414886-1	2024-09-12	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2419215-1	2024-11-21	Coliform	162 Montgomery	Bacteriological Monitoring-Odd	
	SP 2419215-1	2024-11-21	Field Test	162 Montgomery	Bacteriological Monitoring-Odd	
	DBP-Stg2-ss01	SP 2214554-1	2022-09-12	EPA 551.1	162 Montgomery Avenue - STG 2	Stage 2 DBP - THMs/HAA5
	CA5602120_LCR	SP 2409491-1	2024-06-12	Metals, Total	162 MTG	Copper & Lead Monitoring
		SP 2409491-2	2024-06-12	Metals, Total	249 MTG	Copper & Lead Monitoring
	Bacti-Rout-Even	SP 2401765-1	2024-02-06	Field Test	301 Lambert	Bacteriological Monitoring-Even
SP 2401765-1		2024-02-06	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2405754-1		2024-04-16	Field Test	301 Lambert	Bacteriological Monitoring-Even	
SP 2405754-1		2024-04-16	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2409864-1		2024-06-18	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2409864-1		2024-06-18	Field Test	301 Lambert	Bacteriological Monitoring-Even	
SP 2412468-1		2024-08-05	Field Test	301 Lambert	Bacteriological Monitoring-Even	
SP 2412468-1		2024-08-05	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2416468-1		2024-10-08	Field Test	301 Lambert	Bacteriological Monitoring-Even	
SP 2416468-1		2024-10-08	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2419777-1		2024-12-03	Coliform	301 Lambert	Bacteriological Monitoring-Even	
SP 2419777-1		2024-12-03	Field Test	301 Lambert	Bacteriological Monitoring-Even	
CA5602120_LCR		SP 2409491-4	2024-06-12	Metals, Total	319 A LBT	Copper & Lead Monitoring
		SP 2409491-5	2024-06-12	Metals, Total	3897 NSB Pacific Equip	Copper & Lead Monitoring
		SP 2409491-3	2024-06-12	Metals, Total	4121 NSB	Copper & Lead Monitoring
WELL 01		SP 1805126-1	2018-04-17	Radio Chemistry	WELL 01	Radiochem Monitoring
	SP 1805126-1	2018-04-17	Metals, Total	WELL 01	Radiochem Monitoring	
	SP 2014088-1	2020-10-13		WELL 01	PFAS Monitoring	
	SP 2100981-1	2021-01-25		WELL 01	PFAS Monitoring	
	SP 2104896-1	2021-04-13		WELL 01	PFAS Monitoring	
	SP 2108771-1	2021-07-01	Asbestos	WELL 01	Compliance Monitoring	
	SP 2201320-1	2022-01-25		WELL 01	PFAS Monitoring	
	SP 2205403-1	2022-04-05	General Mineral	WELL 01	Water Quality Monitoring	
	SP 2205403-1	2022-04-05	Metals, Total	WELL 01	Water Quality Monitoring	
	SP 2206761-1	2022-04-25		WELL 01	PFAS Monitoring	
	SP 2213648-1	2022-08-23		WELL 01	PFAS Monitoring	
	SP 2217060-1	2022-10-25		WELL 01	PFAS Monitoring	
	SP 2305888-1	2023-04-19	Wet Chemistry	WELL 01	Water Quality Monitoring	
	SP 2406176-1	2024-04-23	Radio Chemistry	Well 01	Radiochem Monitoring	
	SP 2406177-1	2024-04-23	Wet Chemistry	Well 01	Water Quality Monitoring	
	WELL 02	SP 1805126-2	2018-04-17	Metals, Total	Well 02	Radiochem Monitoring
SP 2104896-3		2021-04-13		Well 02	PFAS Monitoring	
SP 2108771-2		2021-07-01		Well 02	Compliance Monitoring	
SP 2115278-3		2021-10-27		Well 02	PFAS Monitoring	
SP 2201320-3		2022-01-25		Well 02	PFAS Monitoring	
SP 2205403-2		2022-04-05	General Mineral	Well 02	Water Quality Monitoring	
SP 2205403-2		2022-04-05	Metals, Total	Well 02	Water Quality Monitoring	
SP 2206761-3		2022-04-25		Well 02	PFAS Monitoring	
SP 2213648-3		2022-08-23		Well 02	PFAS Monitoring	
SP 2406176-2		2024-04-23	Radio Chemistry	Well 02	Radiochem Monitoring	
SP 2406177-2	2024-04-23	Wet Chemistry	Well 02	Water Quality Monitoring		

Bacti-Source-W1	SP 2400563-1	2024-01-11	Coliform	Well 1	Bacteriological Monitoring-Quarterly
	SP 2406179-1	2024-04-23	Coliform	Well 1	Bacteriological Monitoring-Quarterly
	SP 2411804-1	2024-07-22	Coliform	Well 1	Bacteriological Monitoring-Quarterly
	SP 2416480-1	2024-10-08	Coliform	Well 1	Bacteriological Monitoring-Quarterly
Bacti-Source-W2	SP 2400563-2	2024-01-11	Coliform	Well 2	Bacteriological Monitoring-Quarterly
	SP 2406179-2	2024-04-23	Coliform	Well 2	Bacteriological Monitoring-Quarterly
	SP 2411804-2	2024-07-22	Coliform	Well 2	Bacteriological Monitoring-Quarterly
	SP 2416480-2	2024-10-08	Coliform	Well 2	Bacteriological Monitoring-Quarterly