Consumer Confidence Report
Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	**Solano Verde Mutual Water Company**
Water System Number:	**CA5602130**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on **June 30** (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Greg Myers	
	Signature:	Greg Myers	
	Title:	Water Operator	
	Phone Number:	(805) 258-8697	Date: June 23, 2026

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

[X] CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

By Email

[ ] "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- [ ] Posted the CCR on the internet at http:// _____
- [ ] Mailed the CCR to postal patrons within the service area (attach zip codes used)
- [ ] Advertised the availability of the CCR in news media (attach a copy of press release)
- [ ] Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- [ ] Posted the CCR in public places (attach a list of locations)
- [ ] Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- [ ] Delivery to community organizations (attach a list of organizations)
- [ ] Other (attach a list of other methods used)

[ ] *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following address: http://_____

[ ] *For investor-owned utilities:* Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2025 Consumer Confidence Report

Water System Name: Solano Verde Mutual Water Company Report Date: June 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alquien que lo entienda bien.

Type of water source(s) in use: 100% of water is supplied by Calleguas MWC. According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Calleguas MWD - PURCHASED

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are held every 2nd Tuesday of the month, via Zoom.

For more information about this report, or any questions relating to your drinking water, please call (805) 258-8697 and ask for Greg Myers or visit our website at www.svmwc.org.

TERMS USED IN THIS REPORT	
Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).	**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.	**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.	**ND:** not detectable at testing limit **mg/L:** milligrams per liter or parts per million (ppm) **ug/L:** micrograms per liter or parts per billion (ppb)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants,* such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants,* such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides,* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants,* including synthetic and volatile organic chemicals, that are by-products if industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants,* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1 and 2 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	**Highest No. of Detections**	**No. of Months in Violation**	**MCL**	**MCLG**	**Typical Sources of Contaminant**
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	**Sample Date**	**No. of Samples**	**90th percentile level detected**	**No. Sites Exceeding AL**	**Range**	**AL**	**PHG**	**Typical Sources of Contaminant**
Lead (ug/L)	(2024)	5	0	0	ND -	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	5	0.07	0	0.01 - 0.08	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	**Sample Date**	**Average Level Detected**	**Range of Detections**	**MCL (MRDL)**	**PHG (MCLG)**	**Violation**	**Typical Sources of Contaminant**
Total Trihalomethanes (TTHMs) (ug/L)	(2025)	34	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine, Total (mg/L)	(2025)	2.41	2.05 - 2.81	4.0	4.0	No	Drinking water disinfectant added for treatment.
Chlorine, Free (mg/L)	(2024)	2.20	0.90 - 2.4	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2025)	17	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Solano Verde Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/lead.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information
A Drinking Water Source Assessment has not been completed for the source CALLEGUAS MWD PRUCHASED of the SOLANO VERDE MUTUAL WATER CO water system.

Calleguas MWD - PURCHASED - does not have a DWSAP on file.

Discussion of Vulnerability
Assessment summaries are not available for some sources. This is because:
 The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
 The source is not active. It may be out of service, or new and not yet in service.
 The Assessment was not submitted electronically. This site only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp or contact the health department in the county to which the water system belongs.

Solano Verde Mutual Water Co.

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
6913 Solano Verde Drive	SP 2521789-1					2025-12-18	Absent		
6913 Solano Verde Drive	SP 2520406-1					2025-11-26	Absent		
6913 Solano Verde Drive	SP 2518494-1					2025-10-28	Absent		
6913 Solano Verde Drive	SP 2516532-1					2025-09-29	Absent		
6913 Solano Verde Drive	SP 2514296-1					2025-08-21	Absent		
6913 Solano Verde Drive	SP 2512508-1					2025-07-24	Absent		
6913 Solano Verde Drive	SP 2510936-1					2025-06-26	Absent		
6913 Solano Verde Drive	SP 2508981-1					2025-05-29	Absent		
6913 Solano Verde Drive	SP 2506399-1					2025-04-21	Absent		
6913 Solano Verde Drive	SP 2504774-1					2025-03-27	Absent		
6913 Solano Verde Drive	SP 2502990-1					2025-02-27	Absent		
6913 Solano Verde Drive	SP 2501118-1					2025-01-23	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
6913 Solano Verde Drive	SP 2521789-1					2025-12-18	Absent		
6913 Solano Verde Drive	SP 2520406-1					2025-11-26	Absent		
6913 Solano Verde Drive	SP 2518494-1					2025-10-28	Absent		
6913 Solano Verde Drive	SP 2516532-1					2025-09-29	Absent		
6913 Solano Verde Drive	SP 2514296-1					2025-08-21	Absent		
6913 Solano Verde Drive	SP 2512508-1					2025-07-24	Absent		
6913 Solano Verde Drive	SP 2510936-1					2025-06-26	Absent		
6913 Solano Verde Drive	SP 2508981-1					2025-05-29	Absent		
6913 Solano Verde Drive	SP 2506399-1					2025-04-21	Absent		
6913 Solano Verde Drive	SP 2504774-1					2025-03-27	Absent		
6913 Solano Verde Drive	SP 2502990-1					2025-02-27	Absent		
6913 Solano Verde Drive	SP 2501118-1					2025-01-23	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
6885 Coyote Canyon	SP 2414937-5	ug/L				2024-09-09	ND		
6904 Solano Verde Dr.	SP 2414937-1	ug/L				2024-09-09	ND		
6917 Solano Verde Dr.	SP 2414937-2	ug/L				2024-09-10	ND		
6921 Solano Verde Dr.	SP 2414937-3	ug/L				2024-09-10	ND		
6930 Solano Verde Dr.	SP 2414937-4	ug/L				2024-09-09	ND		
Copper		mg/L		1.3	.3			0.065	5
6885 Coyote Canyon	SP 2414937-5	mg/L				2024-09-09	ND		
6904 Solano Verde Dr.	SP 2414937-1	mg/L				2024-09-09	ND		
6917 Solano Verde Dr.	SP 2414937-2	mg/L				2024-09-10	ND		
6921 Solano Verde Dr.	SP 2414937-3	mg/L				2024-09-10	0.08		
6930 Solano Verde Dr.	SP 2414937-4	mg/L				2024-09-09	0.05		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			34	34 - 34
STG 2 - 6904 SOLANO VERDE DR	SP 2514295-1	ug/L				2025-08-21	34		
Average STG 2 - 6904 SOLANO VERDE DR								34	
Chlorine		mg/L		4.0	4.0			2.41	2.05 - 2.81
6913 Solano Verde Drive	SP 2521789-1	mg/L				2025-12-18	2.05		
6913 Solano Verde Drive	SP 2520406-1	mg/L				2025-11-26	2.07		
6913 Solano Verde Drive	SP 2518494-1	mg/L				2025-10-28	2.52		

6913 Solano Verde Drive	SP 2516532-1	mg/L				2025-09-29	2.53		
6913 Solano Verde Drive	SP 2514296-1	mg/L				2025-08-21	2.65		
6913 Solano Verde Drive	SP 2512508-1	mg/L				2025-07-24	2.32		
6913 Solano Verde Drive	SP 2510936-1	mg/L				2025-06-26	2.31		
6913 Solano Verde Drive	SP 2508981-1	mg/L				2025-05-29	2.40		
6913 Solano Verde Drive	SP 2506399-1	mg/L				2025-04-21	2.81		
6913 Solano Verde Drive	SP 2504774-1	mg/L				2025-03-27	2.80		
6913 Solano Verde Drive	SP 2502990-1	mg/L				2025-02-27	2.05		
6913 Solano Verde Drive	SP 2501118-1	mg/L				2025-01-23	2.40		
Average 6913 Solano Verde Drive								2.41	
Chlorine		mg/L		4.0	4.0			2.20	0.90 - 2.4
6904 Solano Verde Dr.	SP 2410983-4	mg/L				2024-07-08	1.1		
6904 Solano Verde Dr.	SP 2410976-4	mg/L				2024-07-05	0.90		
Average 6904 Solano Verde Dr.								1	
Booster Station	SP 2410983-1	mg/L				2024-07-08	2.0		
Booster Station	SP 2410976-1	mg/L				2024-07-05	2.4		
Average Booster Station								2.2	
Calleguas MWD - PURCHASED	SP 2410983-3	mg/L				2024-07-08	1.2		
Calleguas MWD - PURCHASED	SP 2410976-3	mg/L				2024-07-05	1.01		
Average Calleguas MWD - PURCHASED								1.11	
Tank	SP 2410983-2	mg/L				2024-07-08	1.9		
Tank	SP 2410976-2	mg/L				2024-07-05	1.65		
Average Tank								1.78	
Haloacetic Acids (five)		ug/L		60	n/a			17	17 - 17
STG 2 - 6904 SOLANO VERDE DR	SP 2514295-1	ug/L				2025-08-21	17		
Average STG 2 - 6904 SOLANO VERDE DR								17	

Solano Verde Mutual Water Co.

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CA5602130_LCR	SP 2414937-5	2024-09-09	Metals, Total	6885 Coyote Canyon	Lead & Copper Monitoring
6904 SOLANO VER	SP 2410976-4	2024-07-05	Field Test	6904 Solano Verde Dr.	Boiled Water Notice
	SP 2410983-4	2024-07-08	Field Test	6904 Solano Verde Dr.	Stage 1 DBP Monitoring
CA5602130_LCR	SP 2414937-1	2024-09-09	Metals, Total	6904 Solano Verde Dr.	Lead & Copper Monitoring
6913 Solano Ver	SP 2501118-1	2025-01-23	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2501118-1	2025-01-23	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2502990-1	2025-02-27	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2502990-1	2025-02-27	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2504774-1	2025-03-27	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2504774-1	2025-03-27	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2506399-1	2025-04-21	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2506399-1	2025-04-21	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2508981-1	2025-05-29	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2508981-1	2025-05-29	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2510936-1	2025-06-26	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2510936-1	2025-06-26	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2512508-1	2025-07-24	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2512508-1	2025-07-24	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2514296-1	2025-08-21	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2514296-1	2025-08-21	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2516532-1	2025-09-29	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2516532-1	2025-09-29	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2518494-1	2025-10-28	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2518494-1	2025-10-28	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2520406-1	2025-11-26	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2520406-1	2025-11-26	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2521789-1	2025-12-18	Field Test	6913 Solano Verde Drive	Drinking Water Monitoring
	SP 2521789-1	2025-12-18	Coliform	6913 Solano Verde Drive	Drinking Water Monitoring
CA5602130_LCR	SP 2414937-2	2024-09-10	Metals, Total	6917 Solano Verde Dr.	Lead & Copper Monitoring
	SP 2414937-3	2024-09-10	Metals, Total	6921 Solano Verde Dr.	Lead & Copper Monitoring
	SP 2414937-4	2024-09-09	Metals, Total	6930 Solano Verde Dr.	Lead & Copper Monitoring
BOOSTER STA	SP 2410976-1	2024-07-05	Field Test	Booster Station	Boiled Water Notice
	SP 2410983-1	2024-07-08	Field Test	Booster Station	Drinking Water Monitoring
6913 Solano Ver	SP 2410976-3	2024-07-05	Field Test	Calleguas MWD - PURCHASED	Boiled Water Notice
	SP 2410983-3	2024-07-08	Field Test	Calleguas MWD - PURCHASED	Drinking Water Monitoring
DBP2-6904 Solan	SP 2514295-1	2025-08-21	EPA 551.1	STG 2 - 6904 SOLANO VERDE DR	Stage 2 DBP Monitoring
	SP 2514295-1	2025-08-21	EPA 552.2	STG 2 - 6904 SOLANO VERDE DR	Stage 2 DBP Monitoring
TANK	SP 2410976-2	2024-07-05	Field Test	Tank	Boiled Water Notice
	SP 2410983-2	2024-07-08	Field Test	Tank	Drinking Water Monitoring