

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **RIO MESA HIGH SCHOOL/OXNARD UHS**
Water System Number: **5602407**

The water system above hereby certifies that its Consumer Confidence Report was distributed on July 22nd, 2019 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name Joshua Koenig-Brown
Signature 
Title Director of Maintenance, Operations & Transportation
Phone Number (805) 385.2518 Date 07/22/2019

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

Posted the CCR on the internet at http:// _____

Mailed the CCR to postal patrons within the service area (attach zip codes used)

Advertised the availability of the CCR in news media (attach a copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

Posted the CCR in public places (attach a list of locations) RMHS 545 Central Ave., Oxnard, CA 93036
OUHSD Dist. Office 309 South K St., Bldg. C, Oxnard, CA 93038

Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

Delivery to community organizations (attach a list of organizations)

Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2018 Consumer Confidence Report

Water System Name: RIO MESA HIGH SCHOOL/OXNARD UHS

Report Date: May 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Well 02

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 385 - 2516 and ask for Joshua Brown or visit our website at www.ouhsd.k12.ca.us.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	10 (2018)	3.0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	10 (2018)	0.23	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2018)	104	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2018)	765	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2018)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Fluoride (mg/L)	(2018)	0.6	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2018)	5.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2018)	5.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2018)	10	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2013)	6.98	6.46 - 7.50	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2013)	4.02	3.66 - 4.37	20	0.43	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2018)	73	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2018)	1680	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2018)	594	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2018)	1260	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2018)	2	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2018)	0.07	n/a	5	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2018)	0.7	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (mg/L)	(2018)	0.004	n/a	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2018)	196	n/a	n/a	n/a
Magnesium (mg/L)	(2018)	67	n/a	n/a	n/a
pH (units)	(2018)	8.1	n/a	n/a	n/a
Alkalinity (mg/L)	(2018)	220	n/a	n/a	n/a
Aggressiveness Index	(2018)	13.1	n/a	n/a	n/a
Langelier Index	(2018)	1.2	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	5	n/a	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2018)	1	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Oxnard Union High School District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Systems with nitrate (as nitrogen) above 5 ppm (50% of the MCL), but below 10 ppm (the MCL): Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

About our Specific Conductance: The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCLs were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

About our Total Dissolved Solids: The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

2018 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for WELL 02 of the RIO MESA HIGH SCHOOL/Oxnard UHS water system in July, 2001.

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Junk/scrap/salvage yards
Wells - Agricultural/ Irrigation

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water
1180 Eugenia Place
Suite 200
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
805 566 1326

Oxnard Union High School District

Analytical Results By FGL - 2018

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.23	10
Cafeteria Kitchen Sink	SP 1808518-1	mg/L				2018-06-26	0.23		
Cafeteria Mens RR Sink	SP 1808518-2	mg/L				2018-06-26	0.18		
Gym/Boys RR LAV	SP 1808518-8	mg/L				2018-06-26	0.19		
Gym/Girls RR LAV	SP 1808518-7	mg/L				2018-06-26	0.14		
Maintenance LAV	SP 1808518-4	mg/L				2018-06-26	0.17		
Maintenance Sink	SP 1808518-3	mg/L				2018-06-26	0.30		
Teachers Mail Rm/Mens RR	SP 1808518-10	mg/L				2018-06-26	0.17		
Text Room Sink	SP 1808518-9	mg/L				2018-06-26	0.22		
West Campus Rm.106 Sink	SP 1808518-6	mg/L				2018-06-26	0.22		
West Campus RR LAV	SP 1808518-5	mg/L				2018-06-26	0.15		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			104	104 - 104
Well 02	SP 1805576-1	mg/L				2018-04-26	104		
Hardness		mg/L		none	none			765	765 - 765
Well 02	SP 1805576-1	mg/L				2018-04-26	765		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
Well 02	SP 1805576-1	ug/L				2018-04-26	2		
Fluoride		mg/L		2	1			0.6	0.6 - 0.6
Well 02	SP 1805576-1	mg/L				2018-04-26	0.6		
Nitrate as N		mg/L		10	10			5.2	5.2 - 5.2
Well 02	SP 1805576-1	mg/L				2018-04-26	5.2		
Nitrate + Nitrite as N		mg/L		10	10			5.2	5.2 - 5.2
Well 02	SP 1805576-1	mg/L				2018-04-26	5.2		
Selenium		ug/L	50	50	30			10	10 - 10
Well 02	SP 1805576-1	ug/L				2018-04-26	10		
Gross Alpha		pCi/L		15	(0)			6.98	6.46 - 7.50
Well 02	SP 1307526-1	pCi/L				2013-07-25	6.46		
Well 02	SP 1302544-2	pCi/L				2013-03-12	7.50		
Uranium		pCi/L		20	0.43			4.02	3.66 - 4.37
Well 02	SP 1307526-1	pCi/L				2013-07-25	3.66		
Well 02	SP 1302544-2	pCi/L				2013-03-12	4.37		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			73	73 - 73
Well 02	SP 1805576-1	mg/L				2018-04-26	73		
Specific Conductance		umhos/cm		1600	n/a			1680	1680 - 1680
Well 02	SP 1805576-1	umhos/cm				2018-04-26	1680		
Sulfate		mg/L		500	n/a			594	594 - 594
Well 02	SP 1805576-1	mg/L				2018-04-26	594		
Total Dissolved Solids		mg/L		1000	n/a			1260	1260 - 1260
Well 02	SP 1805576-1	mg/L				2018-04-26	1260		
Turbidity		NTU		5	n/a			2.0	2.0 - 2.0
Well 02	SP 1805576-1	NTU				2018-04-26	2.0		

Oxnard Union High School District

CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-ss01	SP 1800803-1	2018-01-18	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1801362-1	2018-02-01	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1803685-1	2018-03-19	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1805449-1	2018-04-24	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1806254-1	2018-05-10	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1808225-1	2018-06-21	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1809222-1	2018-07-16	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1811435-1	2018-08-28	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1812791-1	2018-09-24	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1813804-1	2018-10-16	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1815559-1	2018-11-26	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
	SP 1817184-1	2018-12-27	Coliform	Boys Gym Restroom Lavatory	Routine Monitoring (Rio Mesa)
CuPb-ss01	SP 1808518-1	2018-06-26	Metals, Total	Cafeteria Kitchen Sink	Lead & Copper Monitoring
CuPb-ss02	SP 1808518-2	2018-06-26	Metals, Total	Cafeteria Mens RR Sink	Lead & Copper Monitoring
CuPb-ss08	SP 1808518-8	2018-06-26	Metals, Total	Gym/Boys RR LAV	Lead & Copper Monitoring
CuPb-ss07	SP 1808518-7	2018-06-26	Metals, Total	Gym/Girls RR LAV	Lead & Copper Monitoring
CuPb-ss04	SP 1808518-4	2018-06-26	Metals, Total	Maintenance LAV	Lead & Copper Monitoring
CuPb-ss03	SP 1808518-3	2018-06-26	Metals, Total	Maintenance Sink	Lead & Copper Monitoring
Bacti-ss03	SP 1800803-3	2018-01-18	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1801362-3	2018-02-01	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1803685-3	2018-03-19	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1805449-3	2018-04-24	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1806254-3	2018-05-10	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1808225-3	2018-06-21	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1809222-3	2018-07-16	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1811435-3	2018-08-28	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1812791-3	2018-09-24	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1813804-3	2018-10-16	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1815559-3	2018-11-26	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
	SP 1817150-3	2018-12-27	Coliform	Room 107 Lavatory	Routine Monitoring (Rio Mesa)
Bacti-ss02	SP 1800803-2	2018-01-18	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1801362-2	2018-02-01	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1803685-2	2018-03-19	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1805449-2	2018-04-24	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1806254-2	2018-05-10	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1808225-2	2018-06-21	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1809222-2	2018-07-16	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1811435-2	2018-08-28	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1812791-2	2018-09-24	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1813804-2	2018-10-16	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1815559-2	2018-11-26	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
	SP 1817150-2	2018-12-27	Coliform	Routine #5 Cafeteria	Routine Monitoring (Rio Mesa)
DBPR-ss01	SP 1812784-1	2018-09-24	EPA 552.2	STG 2- 545 Central Ave	Stage 2 DBP Monitoring
	SP 1812784-1	2018-09-24	EPA 551.1	STG 2- 545 Central Ave	Stage 2 DBP Monitoring
CuPb-ss10	SP 1808518-10	2018-06-26	Metals, Total	Teachers Mail Rm/Mens RR	Lead & Copper Monitoring
CuPb-ss09	SP 1808518-9	2018-06-26	Metals, Total	Text Room Sink	Lead & Copper Monitoring
RIO MESA #2	SP 1302544-2	2013-03-12	Radio Chemistry	Well 02	Rio Mesa - Water Quality
Well 02	SP 1307526-1	2013-07-25	Radio Chemistry	Well 02	Radiochemistry Monitoring
WELL02	SP 1805576-1	2018-04-26	Metals, Total	Well 02	Well #2 Monitoring - 3 Year
	SP 1805576-1	2018-04-26	Wet Chemistry	Well 02	Well #2 Monitoring - 3 Year
	SP 1805576-1	2018-04-26	General Mineral	Well 02	Well #2 Monitoring - 3 Year
CuPb-ss06	SP 1808518-6	2018-06-26	Metals, Total	West Campus Rm.106 Sink	Lead & Copper Monitoring
CuPb-ss05	SP 1808518-5	2018-06-26	Metals, Total	West Campus RR LAV	Lead & Copper Monitoring