

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>SANTA CLARA RESOURCES</b>
Water System Number:	<b>5603117</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	(     )	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

---

---

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2020 Consumer Confidence Report

Water System Name: SANTA CLARA RESOURCES

Report Date: April 2021

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Dutch Brothers Well 01

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 647 - 5603 and ask for Lori Frost.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2018)	85	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2018)	442	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2018)	0.7	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2014)	3.18	n/a	15	(0)	Erosion of natural deposits.

**Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2018)	40	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2018)	8	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2018)	470	n/a	300	n/a	Leaching from natural deposits; Industrial wastes

Manganese (ug/L)	(2020)	165	150 - 180	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2018)	1200	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2018)	377	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2018)	850	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2018)	2.1	n/a	5	n/a	Soil runoff

**Table 4 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2018)	0.6	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

**Table 5 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2018)	116	n/a	n/a	n/a
Magnesium (mg/L)	(2018)	37	n/a	n/a	n/a
pH (units)	(2018)	7.9	n/a	n/a	n/a
Alkalinity (mg/L)	(2018)	190	n/a	n/a	n/a
Aggressiveness Index	(2018)	12.6	n/a	n/a	n/a
Langelier Index	(2018)	0.7	n/a	n/a	n/a

**Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2020)	54	ND - 67	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2016)	0.20	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2020)	19.25	ND - 24	60	n/a	No	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/ Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Santa Clara Resources* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

## 2020 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

A source water assessment was conducted for the DUTCH BROTHERS WELL 01 of the SANTA CLARA RESOURCES water system in April, 2003.

Dutch Brothers Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - low density [<1/acre]

### Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

**Acquiring Information**

A copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water  
1180 Eugenia Place  
Suite 200  
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore  
District Engineer  
805 566 1326

# Santa Clara Resources

## Analytical Results By FGL - 2020

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			85	85 - 85
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	85		
<b>Hardness</b>		mg/L		none	none			442	442 - 442
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	442		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Fluoride</b>		mg/L		2	1			0.7	0.7 - 0.7
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	0.7		
<b>Gross Alpha</b>		pCi/L		15	(0)			3.18	3.18 - 3.18
Dutch Brothers Well 01	SP 1402523-1	pCi/L				2014-03-04	3.18		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			40	40 - 40
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	40		
<b>Color</b>		Units		15	n/a			8	8 - 8
Dutch Brothers Well 01	SP 1816959-1	Units				2018-12-20	8		
<b>Iron</b>		ug/L		300	n/a			470	470 - 470
Dutch Brothers Well 01	SP 1816959-1	ug/L				2018-12-20	470		
<b>Manganese</b>		ug/L		50	n/a			165	150 - 180
Dutch Brothers Well 01	SP 2017526-3	ug/L				2020-12-17	180		
Dutch Brothers Well 01	SP 2012841-3	ug/L				2020-09-17	160		
Dutch Brothers Well 01	SP 2008264-3	ug/L				2020-06-23	170		
Dutch Brothers Well 01	SP 2003790-3	ug/L				2020-03-18	150		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			1200	1200 - 1200
Dutch Brothers Well 01	SP 1816959-1	umhos/cm				2018-12-20	1200		
<b>Sulfate</b>		mg/L		500	n/a			377	377 - 377
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	377		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			850	850 - 850
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	850		
<b>Turbidity</b>		NTU		5	n/a			2.1	2.1 - 2.1
Dutch Brothers Well 01	SP 1816959-1	NTU				2018-12-20	2.1		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>		mg/L		NS	n/a			0.6	0.6 - 0.6
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	0.6		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			116	116 - 116
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	116		
<b>Magnesium</b>		mg/L			n/a			37	37 - 37
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	37		
<b>pH</b>		units			n/a			7.9	7.9 - 7.9
Dutch Brothers Well 01	SP 1816959-1	units				2018-12-20	7.9		
<b>Alkalinity</b>		mg/L			n/a			190	190 - 190
Dutch Brothers Well 01	SP 1816959-1	mg/L				2018-12-20	190		

<b>Aggressiveness Index</b>					n/a			12.6	12.6 - 12.6
Dutch Brothers Well 01	SP 1816959-1					2018-12-20	12.6		
<b>Langelier Index</b>					n/a			0.7	0.7 - 0.7
Dutch Brothers Well 01	SP 1816959-1					2018-12-20	0.7		

[illegible]



# Santa Clara Resources

## CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-ss01	SP 2001379-1	2020-01-29	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2002197-1	2020-02-13	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2003790-1	2020-03-18	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2007016-1	2020-05-28	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2008264-1	2020-06-23	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2010005-1	2020-07-28	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2011607-1	2020-08-26	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2012841-1	2020-09-17	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2014719-1	2020-10-23	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2016322-1	2020-11-24	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2017526-1	2020-12-17	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
Bacti-Rout-ss06	SP 2001379-2	2020-01-29	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2002197-2	2020-02-13	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2003790-2	2020-03-18	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2007016-2	2020-05-28	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2008264-2	2020-06-23	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2010005-2	2020-07-28	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2011607-2	2020-08-26	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2012841-2	2020-09-17	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2014719-2	2020-10-23	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2016322-2	2020-11-24	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2017526-2	2020-12-17	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 0714307-1	2007-12-26	Metals, Total	Dutch Brothers Well 01	
Well 01	SP 1304698-1	2013-05-10	Metals, Total	Dutch Brothers Well 01	Water Quality Monitoring
	SP 1402523-1	2014-03-04	Radio Chemistry	Dutch Brothers Well 01	Santa Clara Resources
WELL01	SP 1816959-1	2018-12-20	Wet Chemistry	Dutch Brothers Well 01	Water Quality Monitoring
	SP 1816959-1	2018-12-20	General Mineral	Dutch Brothers Well 01	Water Quality Monitoring
	SP 2003790-3	2020-03-18	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2008264-3	2020-06-23	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2012841-3	2020-09-17	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2017526-3	2020-12-17	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
Bacti-Rout-ss01	SP 1607380-1	2016-06-29	Field Test	Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
CuPb-ss02	SP 2008494-2	2020-06-30	Metals, Total	Grolink Mens RR	Copper & Lead Monitoring
CuPb-ss01	SP 2005411-2	2020-04-23	Coliform	Grolink Sink	Santa Clara Resources
	SP 2008494-1	2020-06-30	Metals, Total	Grolink Sink	Copper & Lead Monitoring
CuPb-ss03	SP 2008494-3	2020-06-30	Metals, Total	Grolink Womens RR	Copper & Lead Monitoring
DBPR-ss02	SP 2002198-1	2020-02-13	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2002198-1	2020-02-13	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2007015-1	2020-05-28	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2007015-1	2020-05-28	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2011605-1	2020-08-26	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2011605-1	2020-08-26	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2016320-1	2020-11-24	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2016320-1	2020-11-24	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
DBPR-ss01	SP 2002198-2	2020-02-13	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2002198-2	2020-02-13	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2007015-2	2020-05-28	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2007015-2	2020-05-28	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2011605-2	2020-08-26	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2011605-2	2020-08-26	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2016320-2	2020-11-24	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2016320-2	2020-11-24	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
CuPb-ss04	SP 2008494-4	2020-06-30	Metals, Total	Top Star Kitchen Sink	Copper & Lead Monitoring
Bacti-Rout-ss06	SP 2005411-1	2020-04-23	Coliform	Top Star Sink	Santa Clara Resources
CuPb-ss05	SP 2008494-5	2020-06-30	Metals, Total	Top Star Sink	Copper & Lead Monitoring