

2023 Consumer Confidence Report

Water System Name: SANTA CLARA RESOURCES

Report Date: March 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Dutch Brothers Well 01

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 647 - 5603 and ask for Lori Frost.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2023)	5	0.07	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	88	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	461	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2021)	0.7	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021)	39	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2021)	20	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2021)	740	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2023)	223	200 - 240	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2021)	1160	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	353	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	840	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021)	2.4	n/a	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2021)	0.7	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2023)	223	200 - 240	n/a	n/a

Table 6 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021)	122	n/a	n/a	n/a
Magnesium (mg/L)	(2021)	38	n/a	n/a	n/a
pH (units)	(2021)	8.1	n/a	n/a	n/a
Alkalinity (mg/L)	(2021)	200	n/a	n/a	n/a
Aggressiveness Index	(2021)	12.9	n/a	n/a	n/a
Langelier Index	(2021)	1	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2023)	146	69 - 217	80	n/a	Yes	By-product of drinking water disinfection
Chlorine (mg/L)	(2021)	0.50	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2023)	38.75	10 - 61	60	n/a	No	By-product of drinking water disinfection

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking

Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Santa Clara Resources* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Color				Color was found at levels that exceed the secondary MCL. The color MCL was set to protect you against unpleasant aesthetic affects due to color. Violating this MCL does not pose a risk to public health.
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

Total Trihalomethanes (TTHMs)				Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
Haloacetic Acids (five)				Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

2023 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the DUTCH BROTHERS WELL 01 of the SANTA CLARA RESOURCES water system in April, 2003.

Dutch Brothers Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Septic systems - low density [$<1/\text{acre}$]

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:
 SWRCB Division of Drinking Water
 1180 Eugenia Place
 Suite 200
 Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore
 District Engineer
 805 566 1326

Santa Clara Resources

Analytical Results By FGL - 2023

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.07	5
Grolink Mens RR	SP 2310449-2	mg/L				2023-06-20	ND		
Grolink Sink	SP 2310449-1	mg/L				2023-06-20	0.14		
Grolink Womens RR	SP 2310449-3	mg/L				2023-06-20	ND		
Top Star Kitchen Sink	SP 2310449-4	mg/L				2023-06-20	ND		
Top Star Sink	SP 2310449-5	mg/L				2023-06-20	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			88	88 - 88
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	88		
Hardness		mg/L		none	none			461	461 - 461
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	461		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.7	0.7 - 0.7
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	0.7		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			39	39 - 39
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	39		
Color		Units		15	n/a			20	20 - 20
Dutch Brothers Well 01	SP 2107102-1	Units				2021-05-27	20		
Iron		ug/L		300	n/a			740	740 - 740
Dutch Brothers Well 01	SP 2107102-1	ug/L				2021-05-27	740		
Manganese		ug/L		50	n/a			223	200 - 240
Dutch Brothers Well 01	SP 2320411-3	ug/L				2023-12-12	220		
Dutch Brothers Well 01	SP 2316077-3	ug/L				2023-09-21	200		
Dutch Brothers Well 01	SP 2310447-3	ug/L				2023-06-20	230		
Dutch Brothers Well 01	SP 2303437-3	ug/L				2023-03-08	240		
Specific Conductance		umhos/cm		1600	n/a			1160	1160 - 1160
Dutch Brothers Well 01	SP 2107102-1	umhos/cm				2021-05-27	1160		
Sulfate		mg/L		500	n/a			353	353 - 353
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	353		
Total Dissolved Solids		mg/L		1000	n/a			840	840 - 840
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	840		
Turbidity		NTU		5	n/a			2.4	2.4 - 2.4
Dutch Brothers Well 01	SP 2107102-1	NTU				2021-05-27	2.4		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.7	0.7 - 0.7
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	0.7		
Manganese		ug/L		NS	n/a			223	200 - 240
Dutch Brothers Well 01	SP 2320411-3	ug/L				2023-12-12	220		
Dutch Brothers Well 01	SP 2316077-3	ug/L				2023-09-21	200		
Dutch Brothers Well 01	SP 2310447-3	ug/L				2023-06-20	230		

Dutch Brothers Well 01	SP 2303437-3	ug/L				2023-03-08	240		
------------------------	--------------	------	--	--	--	------------	-----	--	--

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			122	122 - 122
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	122		
Magnesium		mg/L			n/a			38	38 - 38
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	38		
pH		units			n/a			8.1	8.1 - 8.1
Dutch Brothers Well 01	SP 2107102-1	units				2021-05-27	8.1		
Alkalinity		mg/L			n/a			200	200 - 200
Dutch Brothers Well 01	SP 2107102-1	mg/L				2021-05-27	200		
Aggressiveness Index					n/a			12.9	12.9 - 12.9
Dutch Brothers Well 01	SP 2107102-1					2021-05-27	12.9		
Langelier Index					n/a			1.0	1.0 - 1.0
Dutch Brothers Well 01	SP 2107102-1					2021-05-27	1.0		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			146	69 - 217
STG 2 - 4105 Gonzales (Grolink	SP 2319591-1	ug/L				2023-11-27	182		
STG 2 - 4105 Gonzales (Grolink	SP 2314177-1	ug/L				2023-08-17	164		
STG 2 - 4105 Gonzales (Grolink	SP 2308685-1	ug/L				2023-05-25	110		
STG 2 - 4105 Gonzales (Grolink	SP 2302558-1	ug/L				2023-02-21	69		
Average STG 2 - 4105 Gonzales (Grolink								131.25	
STG 2 - 4255 Gonzales (Topstar	SP 2319591-2	ug/L				2023-11-27	217		
STG 2 - 4255 Gonzales (Topstar	SP 2314177-2	ug/L				2023-08-17	127		
STG 2 - 4255 Gonzales (Topstar	SP 2308685-2	ug/L				2023-05-25	141		
STG 2 - 4255 Gonzales (Topstar	SP 2302558-2	ug/L				2023-02-21	98		
Average STG 2 - 4255 Gonzales (Topstar								145.75	
Chlorine		mg/L		4.0	4.0			0.50	0.5 - 0.5
Grolink Lunch Rm. Tap	SP 2108491-1	mg/L				2021-06-24	0.5		
Average Grolink Lunch Rm. Tap								0.5	
Haloacetic Acids (five)		ug/L		60	n/a			38.75	10 - 61
STG 2 - 4105 Gonzales (Grolink	SP 2319591-1	ug/L				2023-11-27	61		
STG 2 - 4105 Gonzales (Grolink	SP 2314177-1	ug/L				2023-08-17	16		
STG 2 - 4105 Gonzales (Grolink	SP 2308685-1	ug/L				2023-05-25	10		
STG 2 - 4105 Gonzales (Grolink	SP 2302558-1	ug/L				2023-02-21	42		
Average STG 2 - 4105 Gonzales (Grolink								32.25	
STG 2 - 4255 Gonzales (Topstar	SP 2319591-2	ug/L				2023-11-27	53		
STG 2 - 4255 Gonzales (Topstar	SP 2314177-2	ug/L				2023-08-17	33		
STG 2 - 4255 Gonzales (Topstar	SP 2308685-2	ug/L				2023-05-25	37		
STG 2 - 4255 Gonzales (Topstar	SP 2302558-2	ug/L				2023-02-21	32		
Average STG 2 - 4255 Gonzales (Topstar								38.75	

Santa Clara Resources

CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-ss01	SP 2301020-1	2023-01-23	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2302555-1	2023-02-21	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2303437-1	2023-03-08	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2306671-1	2023-04-28	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2310447-1	2023-06-20	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2312602-1	2023-07-21	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2314178-1	2023-08-17	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2316077-1	2023-09-21	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2317764-1	2023-10-19	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2319592-1	2023-11-27	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
	SP 2320411-1	2023-12-12	Coliform	Bacti-Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
Bacti-Rout-ss06	SP 2301020-2	2023-01-23	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2302555-2	2023-02-21	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2303437-2	2023-03-08	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2306671-2	2023-04-28	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2310447-2	2023-06-20	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2312602-2	2023-07-21	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2314178-2	2023-08-17	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2316077-2	2023-09-21	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2317764-2	2023-10-19	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2319592-2	2023-11-27	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 2320411-2	2023-12-12	Coliform	Bacti-Top Star Sink	Routine Bacteriological Monitoring
	SP 0714307-1	2007-12-26	Metals, Total	Dutch Brothers Well 01	
Well 01	SP 1304698-1	2013-05-10	Metals, Total	Dutch Brothers Well 01	Water Quality Monitoring
WELL01	SP 2107102-1	2021-05-27	General Mineral	Dutch Brothers Well 01	Water Quality Monitoring
	SP 2107102-1	2021-05-27	Wet Chemistry	Dutch Brothers Well 01	Water Quality Monitoring
	SP 2303437-3	2023-03-08	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2310447-3	2023-06-20	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2316077-3	2023-09-21	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
	SP 2320411-3	2023-12-12	Metals, Total	Dutch Brothers Well 01	Routine Bacteriological Monitoring
Bacti-Rout-ss01	SP 2108491-1	2021-06-24	Field Test	Grolink Lunch Rm. Tap	Routine Bacteriological Monitoring
5603117_DST_LCR	SP 2310449-2	2023-06-20	Metals, Total	Grolink Mens RR	Copper & Lead Monitoring
	SP 2310449-1	2023-06-20	Metals, Total	Grolink Sink	SANTA CLARA RESOURCES
	SP 2310449-3	2023-06-20	Metals, Total	Grolink Womens RR	Copper & Lead Monitoring
DBPR-ss02	SP 2302558-1	2023-02-21	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2302558-1	2023-02-21	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2308685-1	2023-05-25	Coliform	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2308685-1	2023-05-25	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2308685-1	2023-05-25	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2314177-1	2023-08-17	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2314177-1	2023-08-17	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2319591-1	2023-11-27	EPA 551.1	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
	SP 2319591-1	2023-11-27	EPA 552.2	STG 2 - 4105 Gonzales (Grolink	Stage 2 DBP Monitoring
DBPR-ss01	SP 2302558-2	2023-02-21	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2302558-2	2023-02-21	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2308685-2	2023-05-25	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2308685-2	2023-05-25	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2308685-2	2023-05-25	Coliform	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2314177-2	2023-08-17	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2314177-2	2023-08-17	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2319591-2	2023-11-27	EPA 552.2	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
	SP 2319591-2	2023-11-27	EPA 551.1	STG 2 - 4255 Gonzales (Topstar	Stage 2 DBP Monitoring
5603117_DST_LCR	SP 2310449-4	2023-06-20	Metals, Total	Top Star Kitchen Sink	Copper & Lead Monitoring
	SP 2310449-5	2023-06-20	Metals, Total	Top Star Sink	Copper & Lead Monitoring