

# 2018 Consumer Confidence Report

Water System Name: BRANDEIS BARDIN INSTITUTE

Report Date: May 2019

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** Information regarding the type of water source in use is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 1 source(s):** Callegaus MWD - Treated

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805)915-0720 and ask for Daniel Maccabee.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

# **2018 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A Drinking Water Source Assessment has not been completed for the Callegaus MWD - Treated of the BRANDEIS BARDIN INSTITUTE water system.

Callegaus MWD - Treated - does not have a completed assessment on file.

### **Discussion of Vulnerability**

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

### **Acquiring Information**

Upon completion, a copy of the complete assessment may be viewed at:

SWRCB Division of Drinking Water  
1180 Eugenia Place  
Suite 200  
Carpinteria, CA 93013

Upon completion, you may request a summary of the assessment be sent to you by contacting:

Jeff Densmore  
District Engineer  
805 566 1326

# American Jewish University

## CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DBP2 60 HIGH RD	SP 1807502-1	2018-06-07	EPA 551.1	60 HIGH ROAD - STG 2 DBP	Stage 2 DBP
	SP 1807502-1	2018-06-07	EPA 552.2	60 HIGH ROAD - STG 2 DBP	Stage 2 DBP
Alfredo Cottage	SP 1713082-10	2017-10-23	Metals, Total	Alfredo Cottage	Lead & Copper Monitoring
Alonim Kitchen	SP 1713082-9	2017-10-23	Metals, Total	Alonim Kitchen	Lead & Copper Monitoring
ALONIM KIT	SP 1810407-1	2018-08-09	Coliform	Alonim Kitchen	Water Monitoring
	SP 1812808-1	2018-09-24	Coliform	Alonim Kitchen	Monthly Bacteriological
	SP 1814538-1	2018-11-01	Coliform	Alonim Kitchen	Monthly Bacteriological
Arturo Cottage	SP 1713082-1	2017-10-23	Metals, Total	Arturo Cottage	Lead & Copper Monitoring
Avelardo Cottag	SP 1713082-2	2017-10-23	Metals, Total	Avelardo Cottage	Lead & Copper Monitoring
BCI Kitchen	SP 1713082-4	2017-10-23	Metals, Total	BCI Kitchen	Lead & Copper Monitoring
BCI KITCH	SP 1805143-1	2018-04-17	Coliform	BCI Kitchen	Monthly Bacteriological
	SP 1601317-1	2016-02-04	Coliform	Callegaus MWD - Treated	Monthly Bacteriological
CTTG 1	SP 1807503-1	2018-06-07	Coliform	Cottage #1	Monthly Bacteriological
COTTAGE 10	SP 1802765-1	2018-03-01	Coliform	Cottage #10	Monthly Bacteriological
	SP 1816203-1	2018-12-06	Coliform	Cottage #10	Monthly Bacteriological
COTTAGE 11	SP 1600199-1	2016-01-07	Coliform	Cottage #11	Monthly Bacteriological
COTTAGE 60	SP 1805918-1	2018-05-03	Coliform	Cottage #60	Monthly Bacteriological
	SP 1814054-1	2018-10-22	Coliform	Cottage #60	Monthly Bacteriological
COTTAGE 09	SP 1800145-1	2018-01-04	Coliform	Cottage #9	Monthly Bacteriological
Cottage 1	SP 1713082-5	2017-10-23	Metals, Total	Cottage 1	Lead & Copper Monitoring
Cottage 11	SP 1713082-7	2017-10-23	Metals, Total	Cottage 11	Lead & Copper Monitoring
Cottage 601 Var	SP 1713082-8	2017-10-23	Metals, Total	Cottage 601 Varble	Lead & Copper Monitoring
Cottage 8	SP 1713082-6	2017-10-23	Metals, Total	Cottage 8	Lead & Copper Monitoring
Sammy Cottage	SP 1713082-3	2017-10-23	Metals, Total	Sammy Cottage	Lead & Copper Monitoring
SAMMYS Cottage	SP 1801384-1	2018-02-01	Coliform	Sammys Cottage	Monthly Bacteriological
	SP 1809121-1	2018-07-12	Coliform	Sammys Cottage	Monthly Bacteriological