

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **LLOYD-BUTLER MUTUAL WATER COMPANY**

Water System Number: **5603302**

The water system above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name _____
 Signature _____
 Title _____
 Phone Number () _____ Date _____

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

_____ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

_____ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

_____ Posted the CCR on the internet at http:// _____

_____ Mailed the CCR to postal patrons within the service area (attach zip codes used)

_____ Advertised the availability of the CCR in news media (attach a copy of press release)

_____ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

_____ Posted the CCR in public places (attach a list of locations)

_____ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

_____ Delivery to community organizations (attach a list of organizations)

_____ Other (attach a list of other methods used)

_____ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

_____ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2018 Consumer Confidence Report

Water System Name: LLOYD-BUTLER MUTUAL WATER COMPANY

Report Date: March 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): JLB-6 and JLB-7
and from 1 treated location(s): Main House

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805)647-5603 and ask for Lori Frost.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/mo. (2018)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2018)	140	128 - 151	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2018)	632	621 - 643	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2018)	0.5	0.4 - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2015)	1.019	ND - 2.13	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2018)	68	63 - 72	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2018)	1115	960 - 1270	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2018)	100	n/a	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2018)	1670	1600 - 1740	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2018)	555	538 - 572	500	n/a	Runoff/leaching from natural deposits; industrial wastes

Table 5 - TREATED DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Iron (ug/L)	(2018)	ND	ND - 130	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2018)	ND	n/a	50	n/a	Leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2018)	0.7	0.6 - 0.7	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2018)	155	149 - 160	n/a	n/a
Magnesium (mg/L)	(2018)	60	54 - 66	n/a	n/a
pH (units)	(2018)	7.8	n/a	n/a	n/a
Alkalinity (mg/L)	(2018)	255	240 - 270	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Lloyd-Butler Mutual Water Company* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Total Coliform Bacteria: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Specific Conductance: The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCLs were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment has not been completed for the JLB 6 and JLB 7 of the LLOYD-BUTLER MUTUAL WATER COMPANY water system.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Lloyd-Butler Mutual Water Company

Analytical Results By FGL - 2018

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
2077 West L.A. Ave. (Hosebib)	SP 1814869-1					2018-11-08	Absent		
2077 West L.A. Ave. (Hosebib)	SP 1812050-1					2018-09-10	Absent		
Arturos HB	SP 1803969-2					2018-03-25	<1.0		
Arturos House (Hosebib)	SP 1816136-1					2018-12-05	Absent		
Arturos House (Hosebib)	SP 1813578-1					2018-10-10	Absent		
Arturos House (Hosebib)	SP 1811233-4					2018-08-24	Absent		
Arturos House (Hosebib)	SP 1809638-2					2018-07-20	<1.0		
Arturos House (Hosebib)	SP 1807603-1					2018-06-11	Absent		
Arturos House (Hosebib)	SP 1804947-2					2018-04-12	Absent		
Arturos House (Hosebib)	SP 1802476-1					2018-02-22	Absent		
Arturos House (Hosebib)	SP 1800662-3					2018-01-16	Absent		
Clubhouse Dr.	SP 1811233-1					2018-08-24	Absent		
Clubhouse Dr.	SP 1809638-1					2018-07-20	<1.0		
Clubhouse Dr.	SP 1809432-1					2018-07-18	Present		
Clubhouse Dr.	SP 1806730-1					2018-05-21	Absent		
Clubhouse Dr.	SP 1804947-4					2018-04-12	Absent		
Clubhouse Dr.	SP 1803969-4					2018-03-25	<1.0		
Clubhouse Dr.	SP 1803954-1					2018-03-23	Present		
Clubhouse Dr.	SP 1800662-1					2018-01-16	Absent		
End of line	SP 1811233-3					2018-08-24	Absent		
End of Line	SP 1809638-4					2018-07-20	<1.0		
End of line	SP 1804947-1					2018-04-12	Absent		
End of Line	SP 1803969-3					2018-03-25	<1.0		
End of Line	SP 1800662-2					2018-01-16	Absent		
Office Sink	SP 1811233-2					2018-08-24	Absent		
RO Sink	SP 1803969-1					2018-03-25	<1.0		
RO Sink	SP 1800662-4					2018-01-16	Absent		
RO Station	SP 1809638-3					2018-07-20	<1.0		
RO Station	SP 1804947-3					2018-04-12	Absent		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			140	128 - 151
JLB-6	SP 1814006-3	mg/L				2018-10-19	128		
JLB-7	SP 1814006-4	mg/L				2018-10-19	151		
Hardness		mg/L		none	none			632	621 - 643
JLB-6	SP 1814006-3	mg/L				2018-10-19	621		
JLB-7	SP 1814006-4	mg/L				2018-10-19	643		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.5	0.4 - 0.5
JLB-6	SP 1814006-3	mg/L				2018-10-19	0.5		
JLB-7	SP 1814006-4	mg/L				2018-10-19	0.4		
Gross Alpha		pCi/L		15	(0)			1.019	ND - 2.13
JLB-6	SP 1512887-1	pCi/L				2015-11-17	ND		
JLB-6	SP 1509182-1	pCi/L				2015-08-18	1.73		
JLB-6	SP 1505747-1	pCi/L				2015-05-21	1.26		
JLB-6	SP 1501374-1	pCi/L				2015-02-05	1.38		
JLB-7	SP 1512886-1	pCi/L				2015-11-17	1.65		

JLB-7	SP 1509185-1	pCi/L				2015-08-18	ND		
JLB-7	SP 1505745-1	pCi/L				2015-05-21	ND		
JLB-7	SP 1501373-1	pCi/L				2015-02-05	2.13		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			68	63 - 72
JLB-6	SP 1814006-3	mg/L				2018-10-19	63		
JLB-7	SP 1814006-4	mg/L				2018-10-19	72		
Iron		ug/L		300	n/a			1115	960 - 1270
JLB-6	SP 1814006-3	ug/L				2018-10-19	960		
JLB-7	SP 1814006-4	ug/L				2018-10-19	1270		
Manganese		ug/L		50	n/a			100	100 - 100
JLB-6	SP 1814006-3	ug/L				2018-10-19	100		
JLB-7	SP 1814006-4	ug/L				2018-10-19	100		
Specific Conductance		umhos/cm		1600	n/a			1670	1600 - 1740
JLB-6	SP 1814006-3	umhos/cm				2018-10-19	1600		
JLB-7	SP 1814006-4	umhos/cm				2018-10-19	1740		
Sulfate		mg/L		500	n/a			555	538 - 572
JLB-6	SP 1814006-3	mg/L				2018-10-19	538		
JLB-7	SP 1814006-4	mg/L				2018-10-19	572		

TREATED SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Iron		ug/L		300	n/a			ND	ND - 130
Main House	SP 1816131-1	ug/L				2018-12-05	130		
Main House	SP 1813426-1	ug/L				2018-10-08	ND		
Main House	SP 1811129-1	ug/L				2018-08-23	ND		
Main House	SP 1807604-1	ug/L				2018-06-11	ND		
Main House	SP 1804935-1	ug/L				2018-04-12	ND		
Main House	SP 1802188-1	ug/L				2018-02-19	130		
Main House	SP 1801302-1	ug/L				2018-01-31	ND		
Manganese		ug/L		50	n/a			ND	ND - ND
Main House	SP 1816131-1	ug/L				2018-12-05	ND		
Main House	SP 1813426-1	ug/L				2018-10-08	ND		
Main House	SP 1811129-1	ug/L				2018-08-23	ND		
Main House	SP 1807604-1	ug/L				2018-06-11	ND		
Main House	SP 1804935-1	ug/L				2018-04-12	ND		
Main House	SP 1802188-1	ug/L				2018-02-19	ND		
Main House	SP 1801302-1	ug/L				2018-01-31	ND		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.7	0.6 - 0.7
JLB-6	SP 1814006-3	mg/L				2018-10-19	0.6		
JLB-7	SP 1814006-4	mg/L				2018-10-19	0.7		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			155	149 - 160
JLB-6	SP 1814006-3	mg/L				2018-10-19	160		
JLB-7	SP 1814006-4	mg/L				2018-10-19	149		
Magnesium		mg/L			n/a			60	54 - 66
JLB-6	SP 1814006-3	mg/L				2018-10-19	54		
JLB-7	SP 1814006-4	mg/L				2018-10-19	66		

pH		units			n/a			7.8	7.8 - 7.8
JLB-6	SP 1814006-3	units				2018-10-19	7.8		
JLB-7	SP 1814006-4	units				2018-10-19	7.8		
Alkalinity		mg/L			n/a			255	240 - 270
JLB-6	SP 1814006-3	mg/L				2018-10-19	240		
JLB-7	SP 1814006-4	mg/L				2018-10-19	270		

Lloyd-Butler Mutual Water Company

CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-ss02	SP 1812050-1	2018-09-10	Coliform	2077 West L.A. Ave. (Hosebib)	Bacteriological Monitoring - Odd
	SP 1814869-1	2018-11-08	Coliform	2077 West L.A. Ave. (Hosebib)	Bacteriological Monitoring - Odd
Arturo's HB	SP 1803969-2	2018-03-25	Coliform	Arturos HB	Lloyd-Butler MW
Bacti-Rout-ss01	SP 1800662-3	2018-01-16	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
	SP 1802476-1	2018-02-22	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
	SP 1804947-2	2018-04-12	Coliform	Arturos House (Hosebib)	Lloyd-Butler MW
	SP 1807603-1	2018-06-11	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
	SP 1809638-2	2018-07-20	Coliform	Arturos House (Hosebib)	Lloyd-Butler Mutual Water
	SP 1811233-4	2018-08-24	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
	SP 1813578-1	2018-10-10	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
	SP 1816136-1	2018-12-05	Coliform	Arturos House (Hosebib)	Bacteriological Monitoring - Even
Bacti-ss04	SP 1800662-1	2018-01-16	Coliform	Clubhouse Dr.	Lloyd-Butler Mutual Water
	SP 1803954-1	2018-03-23	Coliform	Clubhouse Dr.	Bacteriological Monitoring
Clubhouse Dr.	SP 1803969-4	2018-03-25	Coliform	Clubhouse Dr.	Lloyd-Butler MW
Bacti-ss04	SP 1804947-4	2018-04-12	Coliform	Clubhouse Dr.	Lloyd-Butler MW
	SP 1806730-1	2018-05-21	Coliform	Clubhouse Dr.	Bacteriological Monitoring - Lloyd Butler Mutual Water
	SP 1809432-1	2018-07-18	Coliform	Clubhouse Dr.	Bacteriological Monitoring
	SP 1809638-1	2018-07-20	Coliform	Clubhouse Dr.	Lloyd-Butler Mutual Water
	SP 1811233-1	2018-08-24	Coliform	Clubhouse Dr.	Lloyd-Butler Mutual - Bacteriological Monitoring
CuPb-ss03	SP 1506434-4	2015-06-09	Metals, Total	CuPb-Arturos Laundry	EPA Lead & Copper Monitoring - Lloyd-Butler Mutual Water
CuPb-ss01	SP 1506434-5	2015-06-09	Metals, Total	CuPb-Clubhouse Dr.	EPA Lead & Copper Monitoring - Lloyd-Butler Mutual Water
CuPb-ss04	SP 1506434-3	2015-06-09	Metals, Total	CuPb-Green House Laundry	EPA Lead & Copper Monitoring - Lloyd-Butler Mutual Water
CuPb-ss02	SP 1506434-1	2015-06-09	Metals, Total	CuPb-Office Sink	EPA Lead & Copper Monitoring - Lloyd-Butler Mutual Water
Bacti-ss05	SP 1800662-2	2018-01-16	Coliform	End of Line	Bacteriological Monitoring
End of Line	SP 1803969-3	2018-03-25	Coliform	End of Line	Lloyd-Butler MW
ENDLINE	SP 1804947-1	2018-04-12	Coliform	End of line	Lloyd-Butler MW
	SP 1809638-4	2018-07-20	Coliform	End of Line	Lloyd-Butler Mutual Water
	SP 1811233-3	2018-08-24	Coliform	End of line	Bacteriological Monitoring
5603302-007	SP 1501374-1	2015-02-05	Radio Chemistry	JLB-6	JLB 6 - Water Quality
WELL-JLB 6	SP 1505747-1	2015-05-21	Radio Chemistry	JLB-6	JLB 6 - Water Quality
	SP 1509182-1	2015-08-18	Radio Chemistry	JLB-6	JLB 6 - Water Quality
	SP 1512887-1	2015-11-17	Radio Chemistry	JLB-6	JLB 6 - Water Quality
Well 6	SP 1814006-3	2018-10-19	Irrigation Suit	JLB-6	Lloyd-Butler Mutual Water Company
JLB 7	SP 1501373-1	2015-02-05	Radio Chemistry	JLB-7	JLB 7 - Water Quality
WELL-JLB 7	SP 1505745-1	2015-05-21	Radio Chemistry	JLB-7	JLB 7 - Water Quality
	SP 1509185-1	2015-08-18	Radio Chemistry	JLB-7	JLB 7 - Water Quality
	SP 1512886-1	2015-11-17	Radio Chemistry	JLB-7	JLB 7 - Water Quality
Well 7	SP 1814006-4	2018-10-19	Irrigation Suit	JLB-7	Lloyd-Butler Mutual Water Company
Main House	SP 1801302-1	2018-01-31	Metals, Total	Main House	Iron & Manganese Monitoring
MAIN HOUSE	SP 1802188-1	2018-02-19	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
	SP 1804935-1	2018-04-12	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
	SP 1807604-1	2018-06-11	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
	SP 1811129-1	2018-08-23	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
	SP 1813426-1	2018-10-08	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
	SP 1816131-1	2018-12-05	Metals, Total	Main House	Iron & Manganese Monitoring - Non-Reportable
Office Sink	SP 1811233-2	2018-08-24	Coliform	Office Sink	Bacteriological Monitoring

RO Sink	SP 1800662-4	2018-01-16	Coliform	RO Sink	Bacteriological Monitoring
	SP 1803969-1	2018-03-25	Coliform	RO Sink	Lloyd-Butler MW
Bacti-ss06	SP 1506434-2	2015-06-09	Metals, Total	RO Station	EPA Lead & Copper Monitoring - Lloyd-Butler Mutual Water
	SP 1804947-3	2018-04-12	Coliform	RO Station	Lloyd-Butler MW
	SP 1809638-3	2018-07-20	Coliform	RO Station	Lloyd-Butler Mutual Water