

# 2019 Consumer Confidence Report

Water System Name: DEMPSEY ROAD MUTUAL WATER CO

Report Date: May 2020

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well 01 - Standby

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held at 2265 Samuel Ave, Oxnard every second Thursday at 10:00 am.

For more information about this report, or any questions relating to your drinking water, please call (805)483-9014 and ask for Stephanie.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	1/mo. (2019)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

<b>Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>						
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Lead (ug/L)	10 (2019)	3.5	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	10 (2019)	0.68	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (mg/L)	(2012)	125	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2012)	883	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2012)	3	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2012)	0.5	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate + Nitrite as N (mg/L)	(2012)	4.3	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2012)	39	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2012)	14.4	n/a	15	(0)	Erosion of natural deposits.

**Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2012)	70	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2012)	5	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2012)	1010	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2012)	420	n/a	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2012)	2010	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2012)	840	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2012)	1490	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2012)	4.7	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2012)	0.07	n/a	5	n/a	Runoff/leaching from natural deposits

**Table 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2012)	0.8	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

**Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2019)	53	40 - 66	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2019)	1.66	0.58 - 2.56	4.0	4.0	No	Drinking water disinfectant added for treatment.

Haloacetic Acids (five) (ug/L)	(2019)	13.3	6.6 - 20	60	n/a	No	By-product of drinking water disinfection
--------------------------------	--------	------	----------	----	-----	----	---

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Dempsey Road Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Specific Conductance				The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCLs were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.
Sulfate				Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.
Total Dissolved Solids				The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

## 2019 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL 01 - STANDBY of the DEMPSEY ROAD MUTUAL WATER CO water system in August, 2001.

Well 01 - Standby - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Housing - high density [>1 house/0.5 acres]  
Automobile - Gas stations

#### Acquiring Information

A copy of the complete assessment may be viewed at:  
SWRCB Division of Drinking Water  
1180 Eugenia Place  
Suite 200  
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:  
Jeff Densmore  
District Engineer  
805 566 1326

# Dempsey Road Mutual Water Co.

## Analytical Results By FGL - 2019

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			0	-
111 Lark Ave	SP 1914868-5					2019-11-01	Absent		
127 Hughes Drive	SP 1917125-1					2019-12-16	Absent		
127 Hughes Drive	SP 1914868-2					2019-11-01	Absent		
127 Hughes Drive	SP 1914182-1					2019-10-17	<1.0		
127 Hughes Drive	SP 1913985-1					2019-10-15	Present		
127 Hughes Drive	SP 1910836-1					2019-08-15	Absent		
127 Hughes Drive	SP 1907974-1					2019-06-18	Absent		
127 Hughes Drive	SP 1904959-1					2019-04-15	Absent		
127 Hughes Drive	SP 1902173-1					2019-02-15	Absent		
2253 Cloyne Street	SP 1915545-1					2019-11-15	Absent		
2253 Cloyne Street	SP 1914868-3					2019-11-01	Absent		
2253 Cloyne Street	SP 1914182-4					2019-10-17	<1.0		
2253 Cloyne Street	SP 1912338-1					2019-09-16	Absent		
2253 Cloyne Street	SP 1909260-1					2019-07-15	Absent		
2253 Cloyne Street	SP 1906445-1					2019-05-15	Absent		
2253 Cloyne Street	SP 1903504-1					2019-03-15	Absent		
2253 Cloyne Street	SP 1900610-1					2019-01-15	Absent		
2265 Samuel Avenue	SP 1914868-1					2019-11-01	Absent		
2265 Samuel Avenue	SP 1914182-3					2019-10-17	<1.0		
2265 Samuel Avenue	SP 1911748-1					2019-09-04	Absent		
2265 Samuel Avenue	SP 1908653-1					2019-07-01	Absent		
2265 Samuel Avenue	SP 1905712-1					2019-05-01	Absent		
2265 Samuel Avenue	SP 1902852-1					2019-03-01	Absent		
2265 Samuel Avenue	SP 1900038-1					2019-01-02	Absent		
243 James Avenue	SP 1916311-1					2019-12-02	Absent		
243 James Avenue	SP 1914868-4					2019-11-01	Absent		
243 James Avenue	SP 1914182-2					2019-10-17	<1.0		
243 James Avenue	SP 1913260-1					2019-10-01	Absent		
243 James Avenue	SP 1910097-1					2019-08-01	Absent		
243 James Avenue	SP 1907187-1					2019-06-03	Absent		
243 James Avenue	SP 1904303-1					2019-04-01	Absent		
243 James Avenue	SP 1901497-1					2019-02-01	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Lead</b>		ug/L	0	15	0.2			3.5	10
120 Huges Dr.	SP 1907980-9	ug/L				2019-06-18	11.2		
136 McMillian Ave.	SP 1907980-4	ug/L				2019-06-18	ND		
143 Robert St.	SP 1907980-3	ug/L				2019-06-18	ND		
143 Thomas Ave.	SP 1907980-1	ug/L				2019-06-18	ND		
175 Hughes Dr.	SP 1907980-2	ug/L				2019-06-18	ND		
175 Lark St.	SP 1907980-5	ug/L				2019-06-18	ND		
2102 Cloyne St.	SP 1907980-7	ug/L				2019-06-18	ND		
216 Frank Ave.	SP 1907980-8	ug/L				2019-06-18	ND		
224 James Ave.	SP 1907980-10	ug/L				2019-06-18	ND		
436-438 Channel Island Blvd.	SP 1907980-6	ug/L				2019-06-18	ND		
<b>Copper</b>		mg/L		1.3	.3			0.68	10
120 Huges Dr.	SP 1907980-9	mg/L				2019-06-18	0.87		
136 McMillian Ave.	SP 1907980-4	mg/L				2019-06-18	0.05		
143 Robert St.	SP 1907980-3	mg/L				2019-06-18	0.15		
143 Thomas Ave.	SP 1907980-1	mg/L				2019-06-18	0.27		

175 Hughes Dr.	SP 1907980-2	mg/L				2019-06-18	0.68		
175 Lark St.	SP 1907980-5	mg/L				2019-06-18	0.12		
2102 Cloyne St.	SP 1907980-7	mg/L				2019-06-18	0.36		
216 Frank Ave.	SP 1907980-8	mg/L				2019-06-18	0.06		
224 James Ave.	SP 1907980-10	mg/L				2019-06-18	0.22		
436-438 Channel Island Blvd.	SP 1907980-6	mg/L				2019-06-18	0.26		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			125	125 - 125
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	125		
<b>Hardness</b>		mg/L		none	none			883	883 - 883
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	883		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			3	3 - 3
Well 01 - Standby	SP 1202706-1	ug/L				2012-03-16	3		
<b>Fluoride</b>		mg/L		2	1			0.5	0.5 - 0.5
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	0.5		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			4.3	4.3 - 4.3
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	4.3		
<b>Selenium</b>		ug/L	50	50	30			39	39 - 39
Well 01 - Standby	SP 1202706-1	ug/L				2012-03-16	39		
<b>Gross Alpha</b>		pCi/L		15	(0)			14.4	14.4 - 14.4
Well 01 - Standby	SP 1202706-1	pCi/L				2012-03-16	14.4		

### SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			70	70 - 70
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	70		
<b>Color</b>		Units		15	n/a			5	5 - 5
Well 01 - Standby	SP 1202706-1	Units				2012-03-16	5		
<b>Iron</b>		ug/L		300	n/a			1010	1010 - 1010
Well 01 - Standby	SP 1202706-1	ug/L				2012-03-16	1010		
<b>Manganese</b>		ug/L		50	n/a			420	420 - 420
Well 01 - Standby	SP 1202706-1	ug/L				2012-03-16	420		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			2010	2010 - 2010
Well 01 - Standby	SP 1202706-1	umhos/cm				2012-03-16	2010		
<b>Sulfate</b>		mg/L		500	n/a			840	840 - 840
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	840		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			1490	1490 - 1490
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	1490		
<b>Turbidity</b>		NTU		5	n/a			4.7	4.7 - 4.7
Well 01 - Standby	SP 1202706-1	NTU				2012-03-16	4.7		
<b>Zinc</b>		mg/L		5	n/a			0.07	0.07 - 0.07
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	0.07		

### UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>		mg/L		NS	n/a			0.8	0.8 - 0.8
Well 01 - Standby	SP 1202706-1	mg/L				2012-03-16	0.8		

### DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE





# Dempsey Road Mutual Water Co.

## CCR Login Linkage - 2019

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
111 LARK	SP 1914868-5	2019-11-01	Coliform	111 Lark Ave	DBP - Samuel Ave.
	SP 1914868-5	2019-11-01	Field Test	111 Lark Ave	DBP - Samuel Ave.
120 Hugues Dr.	SP 1907980-9	2019-06-18	Metals, Total	120 Hugues Dr.	Lead & Copper Monitoring
127 Hughes Driv	SP 1902173-1	2019-02-15	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1902173-1	2019-02-15	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1904959-1	2019-04-15	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1904959-1	2019-04-15	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1907974-1	2019-06-18	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1907974-1	2019-06-18	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1910836-1	2019-08-15	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1910836-1	2019-08-15	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1913985-1	2019-10-15	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1913985-1	2019-10-15	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1914182-1	2019-10-17	Coliform	127 Hughes Drive	DBP - Hughes Dr.
	SP 1914182-1	2019-10-17	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1914868-2	2019-11-01	Coliform	127 Hughes Drive	DBP - Samuel Ave.
	SP 1914868-2	2019-11-01	Field Test	127 Hughes Drive	DBP - Samuel Ave.
	SP 1917125-1	2019-12-16	Field Test	127 Hughes Drive	DBP - Hughes Dr.
	SP 1917125-1	2019-12-16	Coliform	127 Hughes Drive	DBP - Hughes Dr.
136 McMillian A	SP 1907980-4	2019-06-18	Metals, Total	136 McMillian Ave.	Lead & Copper Monitoring
143 Robert St.	SP 1907980-3	2019-06-18	Metals, Total	143 Robert St.	Lead & Copper Monitoring
143 Thomas Ave.	SP 1907980-1	2019-06-18	Metals, Total	143 Thomas Ave.	Lead & Copper Monitoring
175 Hughes Dr.	SP 1907980-2	2019-06-18	Metals, Total	175 Hughes Dr.	Lead & Copper Monitoring
175 Lark St.	SP 1907980-5	2019-06-18	Metals, Total	175 Lark St.	Lead & Copper Monitoring
2102 Cloyne St.	SP 1907980-7	2019-06-18	Metals, Total	2102 Cloyne St.	Lead & Copper Monitoring
216 Frank Ave.	SP 1907980-8	2019-06-18	Metals, Total	216 Frank Ave.	Lead & Copper Monitoring
224 James Ave.	SP 1907980-10	2019-06-18	Metals, Total	224 James Ave.	Lead & Copper Monitoring
2253 Cloyne Str	SP 1900610-1	2019-01-15	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1900610-1	2019-01-15	Field Test	2253 Cloyne Street	DBP - Cloyne St.
	SP 1903504-1	2019-03-15	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1903504-1	2019-03-15	Field Test	2253 Cloyne Street	DBP - Cloyne St.
	SP 1906445-1	2019-05-15	Field Test	2253 Cloyne Street	DBP - Cloyne St.
	SP 1906445-1	2019-05-15	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1909260-1	2019-07-15	Field Test	2253 Cloyne Street	DBP - Cloyne St.
	SP 1909260-1	2019-07-15	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1912338-1	2019-09-16	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1912338-1	2019-09-16	Field Test	2253 Cloyne Street	DBP - Cloyne St.
	SP 1914182-4	2019-10-17	Field Test	2253 Cloyne Street	Drinking Water Monitoring
	SP 1914182-4	2019-10-17	Coliform	2253 Cloyne Street	Drinking Water Monitoring
	SP 1914868-3	2019-11-01	Field Test	2253 Cloyne Street	DBP - Samuel Ave.
	SP 1914868-3	2019-11-01	Coliform	2253 Cloyne Street	DBP - Samuel Ave.
	SP 1915545-1	2019-11-15	Coliform	2253 Cloyne Street	DBP - Cloyne St.
	SP 1915545-1	2019-11-15	Field Test	2253 Cloyne Street	DBP - Cloyne St.
2265 Samuel Ave	SP 1900038-1	2019-01-02	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1900038-1	2019-01-02	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1902852-1	2019-03-01	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1902852-1	2019-03-01	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1905712-1	2019-05-01	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1905712-1	2019-05-01	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1908653-1	2019-07-01	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1908653-1	2019-07-01	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1911748-1	2019-09-04	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1911748-1	2019-09-04	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1914182-3	2019-10-17	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1914182-3	2019-10-17	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.

	SP 1914868-1	2019-11-01	Field Test	2265 Samuel Avenue	DBP - Samuel Ave.
	SP 1914868-1	2019-11-01	Coliform	2265 Samuel Avenue	DBP - Samuel Ave.
243 James Avenu	SP 1901497-1	2019-02-01	Coliform	243 James Avenue	DBP - James Ave.
	SP 1901497-1	2019-02-01	Field Test	243 James Avenue	DBP - James Ave.
	SP 1904303-1	2019-04-01	Field Test	243 James Avenue	DBP - James Ave.
	SP 1904303-1	2019-04-01	Coliform	243 James Avenue	DBP - James Ave.
	SP 1907187-1	2019-06-03	Field Test	243 James Avenue	DBP - James Ave.
	SP 1907187-1	2019-06-03	Coliform	243 James Avenue	DBP - James Ave.
	SP 1910097-1	2019-08-01	Coliform	243 James Avenue	DBP - James Ave.
	SP 1910097-1	2019-08-01	Field Test	243 James Avenue	DBP - James Ave.
	SP 1913260-1	2019-10-01	Coliform	243 James Avenue	DBP - James Ave.
	SP 1913260-1	2019-10-01	Field Test	243 James Avenue	DBP - James Ave.
	SP 1914182-2	2019-10-17	Coliform	243 James Avenue	DBP - James Ave.
	SP 1914182-2	2019-10-17	Field Test	243 James Avenue	DBP - James Ave.
	SP 1914868-4	2019-11-01	Coliform	243 James Avenue	DBP - Samuel Ave.
	SP 1914868-4	2019-11-01	Field Test	243 James Avenue	DBP - Samuel Ave.
	SP 1916311-1	2019-12-02	Field Test	243 James Avenue	DBP - James Ave.
	SP 1916311-1	2019-12-02	Coliform	243 James Avenue	DBP - James Ave.
436-438 Channel	SP 1907980-6	2019-06-18	Metals, Total	436-438 Channel Island Blvd.	Lead & Copper Monitoring
DBP2 2265Samuel	SP 1908651-1	2019-07-01		STG2-2265 SAMUEL AVENUE	Stage 2 D/DBPR
	SP 1908651-1	2019-07-01	EPA 551.1	STG2-2265 SAMUEL AVENUE	Stage 2 D/DBPR
	SP 1915546-1	2019-11-15	EPA 552.2	STG2-2265 SAMUEL AVENUE	Stage 2 D/DBPR
	SP 1915546-1	2019-11-15	EPA 551.1	STG2-2265 SAMUEL AVENUE	Stage 2 D/DBPR
	SP 1202706-1	2012-03-16	Radio Chemistry	Well 01 - Standby	
	SP 1202706-1	2012-03-16	General Mineral	Well 01 - Standby	
	SP 1202706-1	2012-03-16	Metals, Total	Well 01 - Standby	
	SP 1202706-1	2012-03-16	Wet Chemistry	Well 01 - Standby	