

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	YERBA BUENA WATER COMPANY
Water System Number:	CA5610006

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<i>ROBERT M. BERRY</i>	
	Signature:	<i>Robert M. Berry</i>	
	Title:	<i>President</i>	
	Phone Number:	<i>(805) 227-6168</i>	Date: <i>5/17/2022</i>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or ~~other direct delivery methods~~. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2021 Consumer Confidence Report

Water System Name: YERBA BUENA WATER COMPANY

Report Date: April 2022

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: YBWC has 5 active producing wells that are pumped, tested, and monitored by Redtail Groundwater Solution's Santa Paula, CA. According to SWRCB records, the Sources are Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 5 source(s): Well 05, Well 06, Well 07, Well 08 and Well 09

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805)227-6168 and ask for Robert M. Berry.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

ppt: parts per trillion or nanograms per liter (ng/L)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2019)	10	0.17	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2019 - 2021)	114	79 - 155	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2019 - 2021)	267	120 - 420	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (mg/L)	(2019 - 2021)	ND	ND - 0.08	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Copper (mg/L)	(2019 - 2021)	ND	ND - 0.07	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Fluoride (mg/L)	(2019 - 2021)	0.8	0.5 - 1.1	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2015 - 2020)	2.393	ND - 4.20	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2017)	ND	ND - 1.31	20	0.43	Erosion of natural deposits
Dibromochloropropane (DBCP) (ppt)	(2016 - 2020)	ND	ND - 10	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Ethylene Dibromide (EDB) (ppt)	(2016 - 2020)	ND	ND - 20	50	10	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2019 - 2021)	63	57 - 71	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2019 - 2021)	2	ND - 10	15	n/a	Naturally-occurring organic materials
Copper (mg/L)	(2019 - 2021)	ND	ND - 0.07	1.0	1.0	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
MBAS (ug/L)	(2019 - 2021)	ND	n/a	500	n/a	Municipal and industrial waste discharges.
Specific Conductance (umhos/cm)	(2019 - 2021)	1045	855 - 1260	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2019 - 2021)	134	44.2 - 249	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2019 - 2021)	630	510 - 840	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2019 - 2021)	0.91	0.4 - 1.5	5	n/a	Soil runoff
Zinc (mg/L)	(2019 - 2021)	0.05	ND - 0.26	5	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2019 - 2021)	0.3	0.2 - 0.4	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2019 - 2021)	38	15 - 86	n/a	n/a
Magnesium (mg/L)	(2019 - 2021)	42	20 - 58	n/a	n/a
pH (units)	(2019 - 2021)	7.6	7.3 - 8.1	n/a	n/a
Alkalinity (mg/L)	(2019 - 2021)	312	300 - 330	n/a	n/a
Aggressiveness Index	(2019 - 2021)	12	11.6 - 13.0	n/a	n/a
Langelier Index	(2019 - 2021)	0.121	-0.3 - 1.1	n/a	n/a

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2021)	1	n/a	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2021)	1	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Yerba Buena Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2021 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 05 of the YERBA BUENA WATER COMPANY water system in May, 2002. A source water assessment was conducted for the WELL 06 of the YERBA BUENA WATER COMPANY water system in March, 2003. A source water assessment was conducted for the WELL 07 of the YERBA BUENA WATER COMPANY water system in January, 2008. A source water assessment was conducted for the Well 08 of the YERBA BUENA WATER COMPANY water system in May, 2010.

Well 05 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Campgrounds Recreational areas
 Surface water - streams/lakes/rivers
 Transportation corridors - roads/streets

Well 06 - is considered most vulnerable to the following activities not associated with any detected contaminants:
 Surface water - streams/lakes/rivers
 Transportation corridors - roads/streets
 Wells - Water supply

Well 07 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Surface water - streams/lakes/rivers
Transportation corridors - roads/streets
Wells - Water supply

Well 08 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Surface water-streams/lakes/rivers
Transportation corridors-roads /streets
Wells - Water supply

Well 09 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Surface water-streams/lakes/rivers
Transportation corridors-roads /streets
Wells - Water supply

Discussion of Vulnerability

There have been no contaminants detected in the Well 05 water supply, however the source is still considered vulnerable to activities located near the drinking water source. There is a stream, a campground, and a road near the Well 05. There have been no contaminants detected in the Well 06 water supply, however the source is still considered vulnerable to activities located near the drinking water source. There have been no contaminants detected in the Well 07 water supply, however the source is still considered vulnerable to activities located near the drinking water source. There have been no contaminants detected in the Well 8 water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water
1180 Eugenia Place
Suite 200
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
805 566 1326