

APPENDIX B: eCCR Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	City of Davis
Water System Number:	CA5710001

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 1, 2021 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Matt Deussenberry	Title: Water Division Manager
Signature: 	Date: September 10, 2021
Phone number: (530) 757-5686	Blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☒ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☒ Posting the CCR at the following URL: www.cityofdavis.org/city-hall/public-works-utilities-and-operations/water/water-quality/annual-water-quality-report/2020-water-quality-report
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)

- ☐ Advertising the availability of the CCR in news media (attach copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☒ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserve (attach a copy of the article or notice)
- ☒ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☒ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☒ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www.cityofdavis.org/waterquality
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

The 2020 Water Quality Report (CCR) was posted on the City's webpage at the link above. A utility bill insert was included with the June utility bill through the mail and the insert provided the direct URL and directions on how customers could obtain a PDF version or hard copy of the report. An e-mail with a link to the June Utility Bill Insert on the 2020 Water Quality Report was sent on 6/11/2021 to apartment property managers in Davis in order to be posted in common areas at rental properties. An ad was included in the Davis Enterprise (the local newspaper) on 6/13/2021 and included information on how to view the report through the direct URL. The City included the link to the 2020 Water Quality Report in an e-blast that was sent out via the GreenerDavis – City of Davis Conservation News listserve on 6/8/2021. Social media postings of the 2020 Water Quality Report and its availability were posted on the GreenerDavis Facebook page on 6/16/2021, 6/29/2021, and 7/13/2021 and on the GreenerDavis Instagram page on 6/13/2021 and 6/29/2021.

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c) of the California Code of Regulations.

Attachment A

City of Davis 2020 Water Quality Report





2020 WATER QUALITY REPORT

(CONSUMER CONFIDENCE REPORT)

PWS #5710001

Important Information about Your Water Quality

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

此份有关你的食水报告, 内有重要资料和讯息, 请找他人帮你翻译及解释清楚。



Message to Our Valued Water Customers

The City of Davis is pleased to provide the 2020 Water Quality Report to you. Last year, as in years past, your tap water met all State and Federal drinking water standards. We are proud to report that our system did not have any violations of any maximum contaminant levels for water quality in 2020.

The City collected more than 1,400 water samples throughout the year and tested for over 125 contaminants, of which only those described in this report were detected. Additionally, numerous tests are conducted on the surface water at the Woodland-Davis Regional Water Treatment Facility prior to the finished water being delivered to Davis.

This report is a summary of last year’s water quality. It shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data. Included are helpful details about where your water comes from, what it contains, and how it compares to State water quality standards.

Sincerely,
Stan Gryczko
Public Works Utilities and Operations Director

Matt Deusenberry
Water Division Manager

Community Participation

The [Davis City Council](#) and relevant [City Commissions](#) receive public comments at their regularly scheduled meetings. For City Council meeting dates and times, please check the City’s website at [CityofDavis.org](#) or call the City Clerk’s Office at (530) 757-5602. Commission meeting dates, times and topics can be found at <https://www.cityofdavis.org/city-hall/commissions-and-committees>. Additionally, you can sign up to receive email notifications for meeting dates and topics at <https://www.cityofdavis.org/city-hall/enotification>.

To Our Water Customers

This report is prepared in accordance with the [United States Environmental Protection Agency \(U.S. EPA\)](#) and the [State Water Resources Control Board – Division of Drinking Water \(State Water Board\)](#) regulations under the [Safe Drinking Water Act](#) that requires water providers to report annual water quality information to their customers. This publication lists all constituents detected in your water supply and information about your water source, what it contains, how it compares to State and Federal standards, and other related information.

Our Continuing Commitment to You

Our staff of highly trained and certified operators are available around the clock to provide service for any emergency related to the City’s water supply. Through teamwork, professionalism, and hard work, the City of Davis Public Works Utilities and Operations Water Division provides drinking water that meets or exceeds all State and Federal health standards.

Topics within Report	Page(s)
Information on Water Sources	2
Topics related to water in the home	3
Information on how to read tables	5
Important health information	4
Detection Tables	6-8




For more information about this report, or for any questions relating to your drinking water, please contact City of Davis Public Works Utilities and Operations at Water@CityofDavis.org or (530) 757-5686.

Where Does Our Water Come From?

The City of Davis water system is a conjunctive use system, which means it utilizes both surface water and groundwater for its drinking water supply.

The primary water source is surface water (water that collects on the surface of the ground), supplied from the Sacramento River and treated at the Woodland-Davis Regional Water Treatment Facility. The City's maximum surface water allotment (or how much the City is allowed to get) is 10.2 million gallons per day.

The City currently has 5 deep aquifer wells and 4 intermediate wells. The majority of groundwater delivered is from the deep aquifer wells, while the intermediate aquifer wells are typically only operated to ensure they are exercised properly, as required for water quality testing, or to meet peak demand.



Source Water Assessments

Surface Water

The Sacramento River Watershed Sanitary Survey 2020 Update Report, a source water assessment, was conducted by several agencies and can be obtained at <https://www.wdcwa.com/project-history/>. The report identified eight potential source water/watershed contaminant sources to the Sacramento River: agricultural drainage; livestock; forest activities; river corridor and river recreation; stormwater and urban runoff; industrial NPDES dischargers; wastewater facilities; and watershed spills. The report stated that, "overall, the Sacramento River continued to provide good quality raw water. The raw water can currently be treated to meet all drinking water standards using conventional water treatment processes. There are no long-term constituent trends prevalent in the raw water that necessitates special treatment processes at this time."

Groundwater

A source water assessment for the City of Davis' groundwater wells was completed in 2002 and an assessment was conducted for Well 34 in January 2017. The City's groundwater sources are most vulnerable to historic and present-day land use activities, including agricultural and light industrial use. Additionally, the water source is vulnerable to naturally occurring contaminants such as selenium and chromium. Overall, there is a slight to moderate threat that the City's water source could become contaminated by these land use activities and naturally occurring contaminants. For information on the summary of the assessment, contact City Water Quality Staff at (530) 757-5686 or e-mail Water@CityofDavis.org

Water Treatment Process

Surface Water: Surface water is taken in from the Sacramento River and pumped to the Regional Water Treatment Facility in Woodland. This raw water is treated by traditional surface water techniques, including flash mixing and granular media filtration to remove microorganisms and other contaminants. The treated water is dosed with sodium hypochlorite (chlorine) for disinfection and with phosphoric acid to create ortho-phosphate for corrosion control. For more information on the treatment process, visit <http://www.wdcwa.com/faq>.

Groundwater: Groundwater is treated at each well head with chlorine for disinfection. There is a manganese treatment facility at Well 32, which removes manganese from the source water at that well before entering the distribution system.

No fluoride is added to either the surface water or the groundwater. Fluoride is naturally occurring in low levels in the groundwater.

Distribution System Operations

After treatment at the Regional Water Treatment Facility in Woodland, the surface water is pumped into the transmission line and travels six miles to Davis. Surface water enters into the City's distribution system at three main turn-outs located in west, central, and south Davis.

The City's wells pump groundwater directly from underlying aquifers into either the transmission line or the distribution system, depending on the well. The four deep aquifer wells used primarily for drinking water delivery pump groundwater into the transmission line which is then blended with the surface water prior to entering the distribution system and arriving at the tap.

The ratio of surface water to groundwater varies throughout the year. In warmer months when there is higher water demand, groundwater is supplemented to meet demand. Wells are still operated periodically during the low demand months to ensure that they are exercised properly and as required for water quality testing.

Water Quality Testing

The City's water quality monitoring program consists of sampling certain constituents on a weekly, monthly, quarterly, or annual basis. Water samples are collected at sampling stations within the distribution system, at groundwater wells, and at the point of entry for surface water entering the City's water system. During the past year, the drinking water was tested for over 125 regulated and unregulated constituents. Samples are analyzed externally by certified contract laboratories and results of all regulatory required samples are submitted to the State Water Board to ensure compliance.

Water Hardness and Water Softeners

The City frequently receives questions on the current level of hardness of the drinking water and whether water softeners are recommended.

While water softness is often a matter of personal preference, when the City relied 100% on groundwater prior to 2016, water softeners had been installed in many Davis homes because of high hardness levels. Now that the City's primary water source is surface water and the majority of groundwater used is pumped from the deep aquifer, the level of hardness is significantly lower. For example, in 2015, the weighted average for hardness was 306 parts per million (ppm) or 18 grains per gallon (gpg); whereas in 2020, the weighted average for hardness was reduced to 77 ppm or 4.5 gpg.

Water hardness within Davis may fluctuate throughout the year, but rarely exceeds 120 ppm. During the winter months, when the City delivers mostly surface water, the level of hardness of the water may be lower than it is during the summer months when demand is enough that groundwater wells have to run regularly. The City does collect monthly hardness samples throughout the year in order to better understand the current level of hardness. Visit the [Water Quality Results](#) webpage to view results.

If you are still using a water softener at your home, please consider bypassing it to determine if the current level of water hardness is acceptable for your home, or adjust the grains setting on the water softener accordingly. Reducing or eliminating the use of water softeners can also save water and energy costs.

Minimizing the use of water softeners is also important to protect water quality, as some water softeners release large quantities of salts into the City's wastewater system. These salts are not removed, even after the water is processed through the City's wastewater treatment plant. The salts remain in the treated water that feeds the local wetlands, increasing the salt loading of the wetlands and rivers, and contributes to a variety of problems for the Sacramento Valley.



Water Conservation and Dry Weather

During the most recent drought, many residents in Davis instituted long-term changes to their water use by replacing turf areas with low-water use plantings, replacing older appliances and fixtures with water and energy efficient models, and making changes in everyday water use habits. As 2021 is predicted to be another dry year, it is particularly important for each of us to monitor our water usage and to repair any leaks as quickly as possible.

Whether we are in a dry or wet year, there are always actions we can take to increase long-term water use efficiency. For more information on water use efficiency in California, visit <https://water.ca.gov/Programs/Water-Use-And-Efficiency>.

The AquaHawk online customer water use portal is available to City of Davis water customers. The AquaHawk portal allows customers to view their hourly water usage and set and then receive usage alerts. For more water savings tips and information on AquaHawk, water-wise landscaping, and links to helpful indoor and outdoor water use efficiency websites, visit www.SaveDavisWater.org.

Water Usage & Water Leaks

One of the questions frequently received regarding water usage on their City utility bill is "What is a CCF?" A CCF (hundred cubic feet) is 748 gallons. This is the equivalent of the amount of water it would take to fill 17.8 bathtubs (each bathtub = 42 gallons). Davis water customers may also see water usage displayed in AquaHawk and other sources as cubic feet (cf), and/or gallons. 1 cf = 7.48 gallons. In addition to AquaHawk, mentioned above, the city's online utility billing site allows customers to view past utility bills, water consumption reports, and make payments online.



Water customers are often surprised by the amount of water typical leaks can waste over time. A leaky faucet that drips at the rate of one drip per second can waste more than 3,000 gallons per year. An irrigation system that has a hole 0.031 inches in diameter (about the thickness of the tip of a ballpoint pen) can waste about 6,300 gallons of water per month. One of the most common leaks reported to the city are toilet leaks. The volume for toilet leaks can vary greatly depending upon the type of leak. Many toilet leaks are silent, especially if they are toilet flapper leaks. AquaHawk can be used to assist in finding leaks in the home and around the property. Visit [SaveDavisWater.org](http://www.SaveDavisWater.org) for more information on leak detection.

The Safe Drinking Water Act requires all water purveyors to sample their source and treated water for biological, inorganic, organic, and radioactive constituents. The State Water Board allows systems to monitor for certain constituents less than once per year because the concentration of these contaminants do not change frequently. Some of the data in this year’s report, though representative, are more than one year old.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial Contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic Contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and Herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive Contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.



Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Nitrate in Drinking Water

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

Arsenic in Drinking Water

While your drinking water meets the Federal and State standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. The U.S. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.



Report a Water Quality Concern

Do you have a question or concern about your water quality? Are you experiencing any problems with your drinking water supply, such as discolored water or unusual taste or odor? Contact the Public Works Utilities and Operations Department during regular business hours at (530) 757-5686 or contact the non-emergency Police Department number after hours at (530) 747-5400.

The City of Davis is required to monitor drinking water for specific constituents on a regular basis and monitors several constituents more frequently than required by the regulations. While most monitoring was conducted in 2020, the State Water Board allows us to monitor for some constituents less than once per year because the concentrations do not change frequently. Some of the data points, though representative, are more than one year old.

The results of the City’s monitoring are reporting in the tables of detected constituents on the following pages. For help with interpreting this table, see “Definitions” and “Key to Abbreviations” below.

- 1. Start with a Constituent and read across.
- 2. Year is the year tests were conducted. For most constituents this is 2020, but could be a previous year.
- 3. Unit is the specific unit of measurement for each constituent.
- 4. Maximum Contaminant Level shows the highest level of substance/constituent allowed by regulations. This is reflected by either MCL, SMCL, or MCLG.
- 5. Public Health Goal is the goal level for that substance (this may be lower than what is regulatorily allowed). This is reflected by either PHG, MCLG, or MRDLG.
- 6. Range Detected tells the highest and lowest amounts detected in the drinking water.
- 7. Weighted Average is the average amount of a constituent detected in the drinking water and is based on the detected result for each water source and the percentage of each source to the system.
- 8. Major Sources in Drinking Water tells where the substance usually originates and describes the most likely ways a constituent enters the drinking water.

Water Quality Definitions and Abbreviations

AL (Regulatory Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the US EPA.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A: Not Applicable

ND: Not Detected

NL (Notification Level): Health based advisory set by the State Water Board for constituents without an MCL. This is not an enforceable standard, although requirements and recommendations may apply if detected above this level.

NS: No Standard

NTU: Nephelometric Turbidity Units (a measure of clarity)

pCi/L: Picocuries per liter (a measure of radioactivity)

PDWS (Primary Drinking Water Standard): MCLs, MRDLs, and treatment techniques (TTs) for contaminants that affect health along with their monitoring and reporting requirements.

PHG (Public Health Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

PPM: Parts per million or milligrams per liter (mg/L)

PPB: Parts per billion or micrograms per liter (µg/L)

SMCL (Secondary Maximum Contaminant Level): SMCLs are set to protect the odor, taste, and appearance of drinking water.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

µS/cm: Microsiemens per centimeter (a unit expressing the amount of electrical conductivity of a solution).

90th Percentile: The levels reported for lead and copper represent the 90th percentile of the total number of sites tested. The 90th percentile is equal to or greater than 90% of our lead and copper detections.



Did you know Last year the City delivered 3.42 billion gallons of drinking water.



Summary of Detected Constituents

PRIMARY DRINKING WATER STANDARDS – Regulated to protect your health

Constituent	Unit	Year	MCL or (MRDL)	PHG, (MCLG), or [MRDLG]	Range	Weighted Average	Major Sources
Arsenic	ppb	2020	10	0.004	ND – 8.1	ND	Erosion of natural deposits; runoff from orchards; glass & electronics production wastes
Barium	ppm	2020	1000	(2000)	ND – 180	ND	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (Total)	ppb	2020	50	(100)	ND – 45	ND	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
E. coli	# of detections	2020	0	(0)	ND – 1*	N/A	Human and animal fecal waste
Fluoride	ppm	2020	2	1	ND – 0.36	ND	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as N)	ppm	2020	10	10	ND – 6.6	ND	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium	ppb	2020	50	30	ND – 25	ND	Discharge from petroleum, glass, & metal refineries; erosion of natural deposits; discharge from mines & chemical manufacturers; runoff from livestock lots (feed additive)
Total Trihalomethanes	ppb	2020	80	NS	ND – 7.4	5.7	Byproduct of water chlorination ^A
Gross Alpha	pCi/L	2018	15	0	ND – 12.1	ND	Erosion of natural deposits
Gross Beta ^B	pCi/L	2018	50	(0)	ND – 10.45	ND	Decay of natural and man-made deposits
Combined Radium	pCi/L	2018	5	0	ND – 3.95	ND	Erosion from natural deposits
Uranium ^C	pCi/L	2018	20	0.43	ND – 4.6	ND	Erosion from natural deposits
Point of Entry for Surface Water							
Total Organic Carbon	ppm	2020	TT	N/A	0.6 – 1.1	0.86 ^D	Various natural and manmade sources
Distribution System							
Total Trihalomethanes	ppb	2020	80	N/A	6.5 – 20	17.0 ^E	Byproduct of water chlorination
Total Haloacetic Acids	ppb	2020	60	N/A	ND – 5.9	4.4 ^E	Byproduct of water chlorination
Chlorine	ppm	2020	(4.0)	[4.0]	0.14 – 1.88	0.75 ^D	Drinking water disinfectant added for treatment

LEAD AND COPPER RULE – Tap water samples collected from sample sites throughout the community

Constituent	Unit	Year	AL	PHG	90 th Percentile	Sites Above AL/Total Sites	Major Sources
Lead ^F	ppb	2019	15	0.2	ND	0/37	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper	ppm	2019	1.3	0.3	0.089	0/37	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

SECONDARY DRINKING WATER STANDARDS – Regulated for aesthetic qualities

Constituent	Unit	Year	SMCL	Range	Weighted Average	Major Sources
Chloride	ppm	2020	500	23 – 87	27.2	Runoff/leaching from natural deposits; seawater influence
Iron	ppm	2020	300	ND – 180	ND	Leaching from natural deposits; industrial wastes
Manganese	ppb	2020	50	ND – 32	ND	Leaching from natural deposits
Specific Conductance	µS/cm	2020	1600	250 – 1400	322.5	Substances that form ions when in water; seawater influence
Sulfate	ppm	2020	500	6.6 – 140	15.7	Runoff/leaching from natural deposits; industrial waste
Total Dissolved Solids (TDS)	ppm	2020	1000	140 – 880	189.2	Runoff/leaching from natural deposits
Turbidity	NTU	2020	5	ND – 0.6	ND	Soil runoff

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Davis is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.



Testing for Cryptosporidium

Cryptosporidium is a microbial pathogen found in surface water throughout the United States. Cryptosporidium was detected three times in the untreated surface water during 2020. However, the Regional Water Treatment Facility is designed to remove and/or deactivate these pathogens to ensure that this pathogen is not present in the finished water.

CONSTITUENTS WITH NO DRINKING WATER STANDARD^G

Constituent	Unit	Year	Range	Weighted Average
Alkalinity	ppb	2020	82 – 540	116.9
Boron	ppb	2020	69 – 1000*	176.4
Bicarbonate	ppb	2020	100 – 660	136.2
Calcium	ppm	2020	14 – 55	14.8
Carbonate	ppm	2020	3 – 5.4	0.7
Hardness as CaCO ₃	ppm	2020	63 – 630	77.2
Hexavalent Chromium ^H	ppb	2020	ND – 46	ND
Potassium	ppm	2020	ND – 2.7	1.3
Magnesium	ppm	2020	6.3 – 120	9.8
Sodium	ppm	2020	25 – 120	39.5
pH		2020	7.9 – 8.4	8.1

UNREGULATED CONTAMINANT MONITORING RULE 4^I

Constituent	Unit	Year	Range	Average
Manganese	ppb	2018	ND – 200	ND
Bromochloroacetic Acid (BCAA)	ppb	2018	0.67 – 3.6	2.0
Bromodichloroacetic Acid (BDCAA)	ppb	2018	0.59 – 2.6	1.4
Chlorodibromoacetic Acid (CDBAA)	ppb	2018	0.37 – 1.3	0.8
Dibromoacetic Acid (DBAA)	ppb	2018	0.43 – 1.7	1.1
Dichloroacetic Acid (DCAA)	ppb	2018	0.96 – 5.6	2.5
Trichloroacetic Acid (TCAA)	ppb	2018	0.72 – 3.8	1.6

Footnotes

- * Constituents in bold text were exceedances, see the section below for more information.
- (A) Total Trihalomethanes may also occur naturally.
- (B) The State Water Board considers 50 pCi/L to be the level of concern for beta particles.
- (C) The uranium result in pCi/L is based on a calculation.
- (D) This displays the regular average of sample results, not weighted average.
- (E) Average given is maximum of all local running annual averages calculated during 2020.
- (F) In addition to residential lead and copper sampling, fifteen schools in 2017 and one school in 2018 requested lead sampling to test their internal plumbing.
- (G) These constituents are of interest to some consumers; however, they have no regulatory thresholds.
- (H) There is currently no MCL for hexavalent chromium. The previous MCL of 10 ppb was withdrawn on September 11, 2017.
- (I) Unregulated contaminant monitoring helps U.S. EPA and the State Water Resources Control Board to determine where certain contaminants occur and whether the contaminants need to be regulated.

About Our Exceedances

Boron. Boron is not a regulated constituent but it is considered by the State Water Board to be constituent of concern. One municipal well, Well 27, had a concentration of boron equal to the notification level of 1000 ppb in a sample collected on August 12, 2020. Well 27 did not produce any drinking water in 2020. Laboratory studies have shown that boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

E. coli. On November 17, 2020, the City collected bacteriological samples from all groundwater wells during quarterly sampling. We were notified on November 18 from our contract laboratory that the sample collected from the Well 32-RAW sample tap tested positive for E. coli. This well has two sample taps: a sample tap for raw water and a sample tap for treated water after the manganese treatment process. The sample tap after treatment was negative for E. coli. On November 18, we took one additional sample and on November 19, we took four additional samples. All follow-up samples were negative for E. coli and Total Coliform. The City treats all groundwater with chlorine for disinfection prior to entering the distribution system. Additionally, all distribution system bacteriological samples in 2020 were negative for Total Coliform and E. coli.

Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Attachment B

CCR Notification





INFORMATION REGARDING THE 2020 WATER QUALITY REPORT (CONSUMER CONFIDENCE REPORT)

This notice provides instructions on how to obtain important information about your drinking water.

Este reporte contiene las instrucciones mas recientes para obtener informacion importante sobre su agua potable.

此份有关你的食水报告,内有重要资料和讯息,请找他人为你翻译及解释清楚。



The 2020 Water Quality Report (also called the Consumer Confidence Report) provides information regarding your drinking water and covers water quality data from January 1, 2020, through December 31, 2020. This report contains details about the constituents detected in your drinking water, general information regarding the sources of water and how that water is delivered to your home, as well as other related topics, such as water conservation tips.

In 2020, the City's water supply met all State and Federal drinking water standards. The City delivered 3.4 billion gallons of drinking water in 2020 - 76% of which was surface water from the Sacramento River and 24% was groundwater from underlying aquifers. The delivery of surface water and using groundwater from primarily the deep aquifer has significantly improved the quality of the City's drinking water.

The City is required to monitor drinking water for specific constituents on a regular basis, either weekly, monthly, quarterly or annually depending on the constituent. Samples are collected from sampling stations within the distribution system, at municipal groundwater wells and as surface water enters the City.

The report includes both the range and the weighted average for each detected constituent. The range accounts for the lowest and highest reported concentration for the constituent in samples collected during the year. The weighted average takes into consideration the general chemical makeup of the source water and the total volume that each source contributed during the year.

There are several ways to view the 2020 Water Quality Report:

- Visit [CityofDavis.org](https://cityofdavis.org) and type "water quality report" in the search box.
- Use the following URL: <https://cityofdavis.org/waterquality>
- To request an electronic or paper copy of the report or to speak with someone about the report:
 - Send an email to: Water@CityofDavis.org
 - Call the Public Works Utilities and Operations Department at (530) 757-5686
- Scan the QR code using a tablet or mobile device (data rates may apply) to visit the Water Quality Report webpage.



Attachment C

Publication of the CCR in an
Electronic City
Newsletter/Listserve



Jennifer Gilbert

From: City of Davis <news@cityofdavis.ccsend.com> on behalf of City of Davis <news@cityofdavis.org>
Sent: Tuesday, June 8, 2021 1:16 PM
To: Jennifer Gilbert
Subject: Greener Davis (City of Davis Conservation News) - June 2021

CAUTION: External email. Please verify sender before opening attachments or clicking on links.



City of Davis
Public Works Utilities and Operations
Environmental Resources

Greener Davis

Working together for a Greener Davis

Greener Davis Conservation News - June 2021

In This Issue

Water Quality Report --- Drought Declarations and City Water Supplies
Supplemental Summer Tree Watering --- Share Your Thoughts on Leaf Blowers
Please Leash Your Dog to Keep Them Safe --- Moving-Out? --- Ask Greener Davis

Water Quality Report

The 2020 Water Quality Report is now available! This report contains details about the constituents detected in your drinking water, where your water comes from, how that water is delivered to your home, water conservation tips, and other water-related topics. In 2020, the City's water supply met all State and Federal drinking water standards.

To view the 2020 Water Quality Report, visit <https://cityofdavis.org/waterquality>



Attachment D

Electronic Announcement of the CCR Availability Via Social Media Outlets





PUBLIC WORKS UTILITIES & OPERATIONS DEPARTMENT


23 Russell Boulevard – Davis, California 95616

530.757.5686 - cityofdavis.org


The following social media outlets were utilized for electronic announcement of the 2020 Water Quality Report/CCR availability:


- Facebook – via GreenerDavis
 - Postings were scheduled for 6/16/2021, 6/29/2021, and 7/13/2021
- Instagram – via GreenerDavis
 - Postings were scheduled for 6/13/2021 and 6/29/2021


Facebook


**GreenerDavis**
June 16 · 🌐


The City of Davis' 2020 Annual Water Quality Report is now available! This report contains important information about the quality of the City's drinking water. In 2020, the City's water supply met all State and Federal drinking water standards. To view this report, visit <http://cityofdavis.org/waterquality>




 1

 Like

 Comment

 Share





GreenerDavis

June 29 · 🌐



Do you have questions about drinking water quality in Davis? The City has answers! The 2020 Annual Water Quality Report is now available online at cityofdavis.org/waterquality. The City is pleased to report that as in past years, the drinking water supplied to Davis water customers in 2020 has met all drinking water standards.

The U.S. Safe Drinking Water Act requires all community water systems to report annually on any regulated contaminants that were detected in the drinki... [See More](#)



1



GreenerDavis

July 13 · 🌐



The 2020 Annual Water Quality Report is now available online at <http://cityofdavis.org/waterquality>. As in past years, the drinking water supplied to Davis water customers in 2020 met all state and federal drinking water standards.

In addition to listing the various minerals and other elements (that are known collectively as "constituents") that were detected in the City's drinking water, the report also contains mandatory report on topics such as the sources of drinking wa... [See More](#)



1



Like



Comment



Share



Instagram



greenerdavis



greenerdavis The City of Davis' 2020 Annual Water Quality Report is now available! This report contains important information about the quality of the City's drinking water. In 2020, the City's water supply met all State and Federal drinking water standards. To view this report, visit CityofDavis.org/WaterQuality.

Jun 16, 2021



greenerdavis



greenerdavis Do you have questions about drinking water quality in Davis? The City has answers! The 2020 Annual Water Quality Report is now available online at CityofDavis.org/WaterQuality. The City is pleased to report that as in past years, the drinking water supplied to Davis water customers in 2020 has met all drinking water standards.

Jun 29, 2021

Attachment E

Other Methods





PUBLIC WORKS UTILITIES & OPERATIONS DEPARTMENT

23 Russell Boulevard – Davis, California 95616


530.757.5686 - cityofdavis.org

Other outlets were used to notify Davis residents of the availability of the 2020 Water Quality Report, including:

- An ad was included in the Davis Enterprise (local newspaper) on 6/13/2021 and included information on how to view the report through the direct URL.
- An e-mail with a link to the June Utility Bill Insert on the 2020 Water Quality Report was sent on 6/11/2021 to apartment property managers in Davis in order to be posted in common areas at rental properties.

2020 Water Quality Report Now Available!

- ✓ Available to view online
- ✓ City of Davis tap water meets all State and Federal drinking water standards
- ✓ Report includes information about water sources, contents, and other related information



CityofDavis.org/WaterQuality

CityofDavis.org/WaterQuality
Water@CityofDavis.org



Hello City of Davis Water Customer,

We are writing to you with information on the Annual Water Quality Report, the City's customer water use portal, AquaHawk, and a reminder of the City of Davis water use restrictions. This email is being sent out to all property managers in Davis.

2020 Annual Water Quality Report

The 2020 City of Davis Annual Water Quality Report is now available. Please distribute this flier to your tenants or post it in a prominent area, such as a common area or mailroom. The flier provides directions on how your tenants can access important information about their drinking water in the City of Davis.

2020 City of Davis Annual Water Quality Report Flyer

<https://www.cityofdavis.org/home/showdocument?id=16049&t=637588460933941153>

AquaHawk is Available for Multi-Family Properties

AquaHawk is an online customer water use portal included with your City of Davis water service. You can use AquaHawk to monitor hourly water usage and set and receive usage alerts for properties you own or manage. You can also view all of your accounts and/or meters under one main account registration in AquaHawk.

Visit <http://www.SaveDavisWater.org> to learn more and register.

City of Davis Water Use Restrictions

With a dry spring and summer, monitoring water usage and repairing leaks as quickly as possible is essential and can potentially save money on your utility bill. The City of Davis has a number of permanent water-use restrictions in place. The restrictions most relevant to multi-family properties during the summer months are listed below. The full list of water-use restrictions can be found at <http://www.SaveDavisWater.org>.

- No watering outdoors between 9 a.m. and 6 p.m., except with a hand-held container or hose with a shut-off nozzle, or for very short periods when adjusting a sprinkler system.
- No excessive water flow or runoff onto pavement, gutters or ditches from watering or irrigating landscapes or vegetation of any kind.
- No washing down paved surfaces unless for safety or sanitation, in which case a bucket, a hose with a shut-off nozzle, a cleaning machine that recycles water or a low-volume/high-pressure water broom must be used.
- All property owners must fix leaks, breaks or malfunctions when they find them, or within 72 hours of receiving a notice from the city of Davis.

Please feel free to reach out to me with any questions.

Regards,

Dawn Calciano
Conservation Coordinator